

ATTACHMENT 2 TO AEP:NRC:1215D

COOK NUCLEAR PLANT UNIT 1
TECHNICAL SPECIFICATION PAGE 3/4 6-9
MARKED TO REFLECT THE PROPOSED CHANGES

9602220308 960216
PDR ADCK 05000315
P PDR

CONTAINMENT SYSTEMS

CONTAINMENT STRUCTURAL INTEGRITY

LIMITING CONDITION FOR OPERATION

[NRC suggested revision]



3.6.1.6 The structural integrity of the containment ~~structure and steel liner~~ shall be maintained at a level consistent with the acceptance criteria in Specification 4.6.1.6.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With the structural integrity of the containment ~~structure or steel liner~~ not conforming to the above requirements, restore their structural integrity to within the limits prior to increasing the Reactor Coolant System temperature above 200°F.

SURVEILLANCE REQUIREMENTS

4.6.1.6 The structural integrity of the containment structure and steel liner shall be determined during the shutdown for each Type A containment leakage rate test (reference Specification 4.6.1.2) by a visual inspection of all accessible surfaces of the structure and steel liner and verifying no apparent changes in appearance of the surfaces or other abnormal degradation.

An initial report of any abnormal degradation of the containment structure or liner detected during these inspections shall be made within 10 days after detection.

Replace
with
C.

C. 4.6.1.6 The structural integrity of the containment structure and steel liner shall be determined in accordance with 10 CFR 50 Appendix J Option B and Regulatory Guide 1.163, dated September 1995.

ATTACHMENT 3 TO AEP:NRC:1215D

PROPOSED REVISED COOK NUCLEAR PLANT
UNIT 1 TECHNICAL SPECIFICATION PAGE 3/4 6-9

3/4 LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS
3/4.6 CONTAINMENT SYSTEMS

CONTAINMENT STRUCTURAL INTEGRITY

LIMITING CONDITION FOR OPERATION

3.6.1.6 The structural integrity of the containment shall be maintained at a level consistent with the acceptance criteria in Specification 4.6.1.6.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With the structural integrity of the containment not conforming to the above requirements, restore the structural integrity to within the limits prior to increasing the Reactor Coolant System temperature above 200°F.

SURVEILLANCE REQUIREMENTS

4.6.1.6 The structural integrity of the containment structure and steel liner shall be determined in accordance with 10 CFR 50 Appendix J Option B and Regulatory Guide 1.163, dated September 1995.

