

ATTACHMENT 2 TO AEP:NRC:1243
CURRENT TECHNICAL SPECIFICATION PAGES
WITH CHANGES MARKED

7602260308 760222
PDR ADOCK 05000315
P PDR

TABLE 4.8-1

DIESEL GENERATOR TEST SCHEDULE

Number of Failures in
Last 20 Valid Tests*

Test Frequency

Less than or equal to 1

At least once per 31 days

Greater than or equal to 2

At least once per 7 days**

1.9 *Criteria for determining number of failures and number of valid tests shall be in accordance with Regulatory Position C.2.6 of Regulatory Guide 1.108, Revision 3, ~~August 1977~~, where the number of tests and failures is determined on a per diesel generator basis. For the purposes of this test schedule, only valid tests conducted after the OL issuance date shall be included in the computation of the "last 20 valid tests."

**This test frequency shall be maintained until seven consecutive failure free demands have been performed and the number of failures in the last 20 valid demands has been reduced to one or less.

TABLE 4.8-1
DIESEL GENERATOR TEST SCHEDULE

<u>Number of Failures in Last 20 Valid Tests*</u>	<u>Test Frequency</u>
Less than or equal to 1	At least once per 31 days
Greater than or equal to 2	At least once per 7 days**

*Criteria for determining number of failures and number of valid tests shall be in accordance with Regulatory Position C.2.4 of Regulatory Guide 1.9-1.108, Revision 3, ~~August 1977~~, where the number of tests and failures is determined on a per diesel generator basis. For the purposes of this test schedule, only valid tests conducted after the OL issuance date shall be included in the computation of the "last 20 valid tests."

**This test frequency shall be maintained until seven consecutive failure free demands have been performed and the number of failures in the last 20 valid demands has been reduced to one or less.

ATTACHMENT 3 TO AEP:NRG:1243

PROPOSED TECHNICAL SPECIFICATION PAGES

TABLE 4.8-1

DIESEL GENERATOR TEST SCHEDULE

Number of Failures in
Last 20 Valid Tests*

Test Frequency

Less than or equal to 1

At least once per 31 days

Greater than or equal to 2

At least once per 7 days**

* Criteria for determining number of failures and valid tests shall be in accordance with Regulatory Position C.2.1 of Regulatory Guide 1.9, Revision 3, where the number of tests and failures is determined on a per diesel generator basis. For the purposes of this test schedule, only valid tests conducted after the OL issuance date shall be included in the computation of the "last 20 valid tests."

** This test frequency shall be maintained until seven consecutive failure free demands have been performed and the number of failures in the last 20 valid demands has been reduced to one or less.

TABLE 4.8-1

DIESEL GENERATOR TEST SCHEDULE

Number of Failures in
Last 20 Valid Tests*

Test Frequency

Less than or equal to 1

At least once per 31 days

Greater than or equal to 2

At least once per 7 days**

* Criteria for determining number of failures and valid tests shall be in accordance with Regulatory Position C.2.1 of Regulatory Guide 1.9, Revision 3, where the number of tests and failures is determined on a per diesel generator basis. For the purposes of this test schedule, only valid tests conducted after the OL issuance date shall be included in the computation of the "last 20 valid tests."

** This test frequency shall be maintained until seven consecutive failure free demands have been performed and the number of failures in the last 20 valid demands has been reduced to one or less.