

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9604260187 DOC. DATE: 96/04/19 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana M 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana M 05000316
 AUTH. NAME AUTHOR AFFILIATION
 FITZPATRICK, E.E Indiana Michigan Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Provides follow-up to 951011 response to NOV in insp rept
 95-09. Procedural guidance & shift training provided to
 operating crew to reduce power immediately in response to
 any confirmed loss of vacuum condition.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES:

| RECIPIENT ID CODE/NAME | COPIES LTTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL |
|----------------------------|---------------------|---------------------------|---------------------|
| PD3-1 PD | 1 | HICKMAN, J | 1 |
| INTERNAL: AEOD/SPD/RAB | 1 | AEOD/TTC | 1 |
| DEDRO | 1 | <u>FILE CENTER</u> | 1 |
| NRR/DISP/PIPB | 1 | NRR/DRCH/HHFB | 1 |
| NRR/DRPM/PECB | 1 | NRR/DRPM/PERB | 1 |
| NUDOCS-ABSTRACT | 1 | OE DIR | 1 |
| OGC/HDS2 | 1 | RGN3 FILE 01 | 1 |
| EXTERNAL: LITCO BRYCE, J H | 1 | NOAC | 1 |
| NRC PDR | 1 | | |

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 17 ENCL 0

C
A
T
E
R
Y
O
R
Y
1
D
O
C
U
M
E
N
T



Indiana Michigan
Power Company
PO Box 16631
Columbus, OH 43216



April 19, 1996

AEP:NRC:1224B1

Docket Nos.: 50-315
50-316

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Donald C. Cook Nuclear Plant Units 1 and 2
NRC INSPECTION REPORTS NO. 50-315/95009 (DRP)
AND 50-316/95009 (DRP)
FOLLOW-UP RESPONSE TO NOTICE OF VIOLATION

This letter is a follow-up to our response to the Notice of Violation contained in Inspection Report #95009, forwarded to Indiana Michigan Power in a letter from W. L. Axelson dated September 12, 1995. The original notice cited three examples of failure to follow procedures, of which one involved operators not reducing power during a loss of main turbine condenser vacuum transient. In the response provided in AEP:NRC:1224B, dated October 11, 1995, we stated that we considered the actions to be taken for the loss of main condenser vacuum to be an open issue. We committed to continue our evaluation of this event to determine the most appropriate actions for loss of main condenser vacuum. This evaluation has been completed.

Our evaluation concluded that the decision to not decrease power in response to the loss of vacuum was not in line with our conservative operating philosophy, or with that of the industry in general. Consequently, we have provided procedural guidance and shift training to direct the operating crew to reduce power immediately in response to any confirmed loss of vacuum condition. This results in actions more in keeping with our conservative operating philosophy and minimizes the magnitude of the transient should the need to trip the plant arise.

We have also determined the need for a "rapid shutdown" procedure to guide operating crews for conditions in which a rapid power reduction would be prudent. To meet this need, a rapid shutdown procedure has been developed for the Donald C. Cook Nuclear Plant, and training on this procedure has commenced.

260012

9604260187 960419
PDR ADDCK 05000315
Q PDR

LEOL
1/10

This event has provided us with the opportunity to review our past practices and training and to improve upon them. In summary, we consider it appropriate that the open item on the loss of condenser vacuum be closed with our actions.

Sincerely,



E. E. Fitzpatrick
Vice President

llg

cc: A. A. Blind
G. Charnoff
H. J. Miller
NFEM Section Chief
NRC Resident Inspector - Bridgman
J. R. Padgett

