

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9707220354 DOC. DATE: 97/06/30 NOTARIZED: NO DOCKET #
 FACIL: 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana M 05000316
 AUTH. NAME AUTHOR AFFILIATION
 MINOR, J.W. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 CENTER, J.F. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 SAMPSON, J.R. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for June 1997 for DC Cook Nuclear
 Plant Unit 2.W/970707 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD3-3 PD	1 1	HICKMAN, J	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	<u>FILE CENTER 01</u>	1 1
	NRR/DRPM/PECB	1 1	OC/DBA/PAD	1 1
	RGN3	1 1		
EXTERNAL:	LITCO BRYCE, J H	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM OWFN SD-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 10

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

Indiana Michigan
Power Company
Cook Nuclear Plant
One Cook Place
Bridgman, MI 49106



U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

July 7, 1997

Gentlemen,

Pursuant to the requirements of Donald C. Cook Nuclear Plant Unit 2
Technical Specification 6.9.1.10, the attached Monthly Operating Report
for the month of June 1997 is submitted.

Sincerely,

J.R. Sampson

J.R. Sampson
Plant Manager

/jc

Attachment

c: NRC Region III
D.R. Hahn
R.C. Callen
S. Hamming
B. Lewis
INPO Records Center
ANI Nuclear Engineering Department
E.E. Fitzpatrick
A.A. Blind
P.A. Barrett
S.J. Brewer
D.W. Paul
J.A. Kobyra
D.L. Noble
W.H. Schalk
D.G. Turner
B.L. Bartlett
M.E. Russo

220014

1/1
Lezy



N.R.C. OPERATING DATA REPORT

DOCKET NO.	50 - 316
DATE	June 4, 1997
COMPLETED BY	JW Minor
TELEPHONE	616-465-5901

OPERATING STATUS

1. Unit Name	D. C. Cook Unit 2
2. Reporting Period	Jun-97
3. Licensed Thermal Power (MWt)	3411
4. Name Plate Rating (Gross MWe)	1133
5. Design Electrical Rating (Net MWe)	1090
6. Maximum Dependable Capacity (GROSS MWe)	1100
7. Maximum Dependable Capacity (Net MWe)	1060

Notes:

8. If Changes Occur in Capacity Ratings (Items no. 3 through 7) Since Last Report Give Reasons:

9. Power Level To Which Restricted, If Any (Net MWe):

10. Reasons For Restrictions, If Any:

	This Month	Year-to-Date	Cumulative
11. Hours in Reporting Period	720.0	4344.0	170904.0
12. No. of Hrs. Reactor Was Critical	720.0	4079.1	120091.0
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator on Line	720.0	4025.8	116473.4
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Gen. (MWH)	2449927.6	13122447.4	360300714.4
17. Gross Electrical Energy Gen. (MWH)	781990.0	4291330.0	116795720.0
18. Net Electrical Energy Gen. (MWH)	755969.0	4147178.0	112529744.0
19. Unit Service Factor	100.0	92.7	69.1
20. Unit Availability Factor	100.0	92.7	69.1
21. Unit Capacity Factor (MDC Net)	99.1	90.1	62.9
22. Unit Capacity Factor (DER Net)	96.3	87.6	61.3
23. Unit Forced Outage Rate	0.0	7.3	14.0

24. Shutdowns Scheduled over Next Six Months (Type, Date, and Duration):

Refueling outage to begin September 26, 1997 for an estimated duration of 48 days

25. If Shut Down At End of Report Period, Estimated Date of Startup:

26. Units in Test Status (Prior to Commercial Operation):

INITIAL CRITICALITY
INITIAL ELECTRICITY
COMMERCIAL OPERATION

Forecast

Achieved

DOCKET NO.
UNIT NAME
DATE
COMPLETED BY
TELEPHONE

50 - 316
D.C. Cook Unit 2
June 4, 1997
JW Minor
616-465-5901

AVERAGE DAILY POWER LEVEL (MWe-Net)

JUNE 1997

DAY	AVERAGE DAILY POWER LEVEL	DAY	AVERAGE DAILY POWER LEVEL
6/1/97	1076	6/17/97	1051
6/2/97	1075	6/18/97	1059
6/3/97	1077	6/19/97	1049
6/4/97	1070	6/20/97	1041
6/5/97	1069	6/21/97	1034
6/6/97	1067	6/22/97	1030
6/7/97	1064	6/23/97	1025
6/8/97	1067	6/24/97	1025
6/9/97	1066	6/25/97	1027
6/10/97	1064	6/26/97	1024
6/11/97	1060	6/27/97	1028
6/12/97	1058	6/28/97	1029
6/13/97	1053	6/29/97	1026
6/14/97	1050	6/30/97	1034
6/15/97	1054		
6/16/97	1048		

DOCKET NO.
UNIT NAME
DATE
COMPLETED BY
TELEPHONE
PAGE

50 - 316
D.C. Cook Unit 2
July 7, 1997
JF Center
616-697-5098
1 of 1

MONTHLY OPERATING ACTIVITIES - JUNE 1997

HIGHLIGHTS

The unit entered this reporting period in Mode 1 at 100% RTP.

The unit exited this reporting period in Mode 1 at 100% RTP.

There were no challenges to the pressurizer safety valves or power operated relief valves.

Gross electrical generation for the month of June was 781990.0 MWh.

DETAILS:

* All time entries are Eastern Standard Time (EST).

DOCKET NO.	50 - 316
UNIT NAME	D.C. Cook Unit-2
DATE	July 7, 1997
COMPLETED BY	JF Center
TELEPHONE	616-697-5098
PAGE	1 of 1

UNIT SHUTDOWNS AND POWER REDUCTIONS - JUNE 1997

NO.	DATE	TYPE ¹	DURATION HOURS	REASON ²	METHOD OF SHUTTING DOWN REACTOR ³	LICENSEE EVENT REPORT NO.	SYSTEM CODE ⁴	COMPONENT CODE ⁵	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
-----	------	-------------------	-------------------	---------------------	---	---------------------------------	-----------------------------	--------------------------------	--

None	There were no unit shutdowns or significant power reductions from 100 % RTP this month.							
------	---	--	--	--	--	--	--	--

1 TYPE:
F: Forced
S: Scheduled

2 REASON:
A: Equipment Failure (Explain)
B: Maintenance or Test
C: Refueling
D: Regulatory Restriction
E: Operator Training and License Examination
F: Administrative
G: Operational Error (Explain)
H: Other (Explain)

3 METHOD:
1: Manual
2: Manual Scram
3: Automatic Scram
4: Other (Explain)

4 SYSTEM:
Exhibit G - Instructions for preparation of data entry sheets for Licensee Event Report (LER) File (NUREG 0161)

5 COMPONENT:
Exhibit I: Same Source

