THIRD 10-YEAR INTERVAL LONG-TERM INSERVICE EXAMINATION PLAN FOR CLASS 1, 2, AND 3 SYSTEMS AND COMPONENTS FOR DONALD C. COOK NUCLEAR PLANT, UNIT 2

VOLUME I
FINAL PLAN
SwRI Project 17-7208

Prepared for

American Electric Power Service Corporation
1 Riverside Plaza
Columbus, Ohio 43216-6631

Prepared by

Nondestructive Evaluation Science and Technology Division

November 1995

Written by

Alfred R. Anderson
Project Manager
NDE Engineering Section
Department of NDE Services

Approved by

Bruce M. Jacobs
Director
Department of NDE Services
Nondestructive Evaluation Science and Technology Division

9601310032 960125
PDR ADOCK 05000315
Q PDR

TABLE OF CONTENTS

Page

VOLUME I--FINAL PLAN

LIST OF ABBREVIATIONS v

I. INTRODUCTION 1

A. Applicable Documents 1
B. Examination Areas 2

II. LONG-TERM EXAMINATION PLAN 5

A. Introduction to the Long-Term Examination Tables 5
B. Examination Area Identification System 6

III. BASIS FOR PREPARATION 9

A. Class 1 Components 9
B. Class 2 Components 9
C. Class 3 Components 9
D. Class 1, 2, and 3 Component Supports 9
E. Code Relief 10
F. System Pressure Test 10

IV. LONG-TERM EXAMINATION TABLE-CLASS 1 COMPONENTS (Reference ASME Section XI; Subsection IWB)

V. LONG-TERM EXAMINATION TABLE-CLASS 2 COMPONENTS (Reference ASME Section XI; Subsection IWC)

VI. LONG-TERM EXAMINATION TABLE-CLASS 3 COMPONENTS (Reference ASME Section XI; Subsection IWD)

VII. LONG-TERM EXAMINATION TABLE-CLASS 1, 2, AND 3 COMPONENTS (Reference ASME Section XI; Subsection IWF)

VOLUME II--APPENDICES

APPENDICES

A Weld Identification Figures - Class 1
B Weld Identification Figures - Class 2
C Ultrasonic Calibration Block Drawings/Sketches and Certifications
D Allocation Tables for Class 1, 2, and 3 Components
E Donald C. Cook Nuclear Plant, Unit 2, Relief Requests
F Donald C. Cook Nuclear Plant, Unit 2, Line Listing

LIST OF ABBREVIATIONS

AEP	-	American Electric Power Service Corporation
ASME	-	American Society of Mechanical Engineers
CL	-	Cladding
CS	-	Chemical and Volume Control System
Cook 2	-	Donald C. Cook Nuclear Plant, Unit 2
FB	-	Flange Bolting
FW	-	Feedwater System
HL	-	Hanger Lug
HT	-	Hydrostatic Test
I	-	Inside or Inlet
IE	-	Integral Extension
IMP	-	Indianan & Michigan Electric Company
IRS	-	Inside Radius Section
ISI	-	Inservice Examination
IST	-	Inservice Testing
LD	-	Longitudinal Seam Downstream
LHM	-	Lower Head Meridional
Lig	-	Ligament
L_o	-	Zero Reference Location
LT	-	Leak Test
LTP	-	Long-Term Plan
LU	-	Longitudinal Seam Upstream
M	-	Meridional
MB	-	Manway Bolting
M	-	Meridional
MB	-	Manway Bolting
MEF	-	Moderate Energy Fluid System
MS	-	Main Steam System
MT	-	Magnetic Particle Examination
N	-	Nozzle
O	-	Outside or Outlet
PR	-	Pipe Restraint
PRZ	-	Pressurizer
PS	-	Pipe Support
PT	-	Liquid Penetrant Examination
RC	-	Reactor Coolant System
RH	-	Residual Heat Removal
RHE	-	Regenerative Heat Exchanger
RHRHEX	-	Residual Heat Removal Heat
RPV	-	Reactor Pressure Vessel
RT	-	Radiographic Examination
SI	-	Safety Injection System
STM	-	Steam Generator
SwRI	-	Southwest Research Institute
USNRC	-	United States Nuclear Regulatory Commission
UT	-	Ultrasonic Examination
Vol	-	Volumetric
VS	-	Vessel Support
VT	-	Visual Examination
WD	-	Waster Disposal System

I. INTRODUCTION

This document presents the Long-Term Plan (LTP) for inservice examination of Class 1, 2, and 3 systems and components for Indiana Michigan Power Company's (IMP) Donald C. Cook Nuclear Plant, Unit 2 (Cook 2). The examinations are scheduled to be performed during the third 10-year interval for Class 1, 2, and 3 systems and components. The third 10-year interval begins on July 1, 1996, and continues through June 30, 2006.

Volumes I and II contain the plan for Class 1, 2, and 3 systems and components (Subsection IWB, IWC, IWD, and IWF) examinations. The inservice testing (IST) of pumps and valves (Subsections IWP and IWV) will be submitted separately from the ISI program.

A. Applicable Documents

The areas to be examined were selected in accordance with the following documents.

1. Section XI of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, "Rules for Inservice Inspection of Nuclear Power Plant Components," 1989 Edition

2. Section XI of the ASME Boiler and Pressure Vessel Code, "Rules for Inservice Inspection of Nuclear Power Plant Components," 1974 Edition with Addenda through Summer 1975 (for Class 1 B-J piping welds only).

3. Cook 2 Technical Specifications

4. Southwest Research Institute (SwRI) "Second 10-year interval Long-Term Inservice Testing Plan for Class 1, 2, and 3 Systems and Components for Donald C. Cook Nuclear Power Plant, Unit 2," December 1985

5. "Rules and Regulations, Title 10, Chapter 1, Code of Federal Regulations, Part 50.55a"

6. United States Nuclear Regulatory Commission (USNRC) Regulatory Guide 1.150, Revision 1, "Ultrasonic Testing of Reactor Vessel Welds During Preservice and Inservice Examinations"

7. USNRC Regulatory Guide 1.65, "Materials and Inspections for Reactor Vessel Closure Studs," October 1973

8. USNRC Regulatory Guide 1.14, Revision 1, "Reactor Coolant Pump Flywheel Integrity," August 1975

9. USNRC Regulatory Guide 1.26, Revision 3, "Quality Group Classifications and Standards for Water, Steam, and Radioactive Waste Containing Components of Nuclear Power Plants"

10. USNRC I. E. Bulletin 82-02, "Degradation of Threaded Fasteners in the Reactor Coolant Pressure Boundary of PWR Plants"

11. USNRC Bulletin 88-08, Supplement 2, "Thermal Stresses in Piping Connected to Reactor Coolant Systems"

12. USNRC Information Notice 90-30, "Ultrasonic Inspection Techniques for Dissimilar Metal Welds"

13. ASME Code Case N-491-1, "Alternative Rules for Examination of Class 1, 2, 3, and MC Component Supports of Light Water Cooled Power Plants," Section XI, Division 1

14. ASME Code Case N-498-1, "Alternative Rules for 10-year Hydrostatic Pressure Testing for Class 1 and Class 2 Systems," Section XI, Division 1

15. ASME Code Case N-509, "Alternative Rules for the Selection and Examination of Class 1, 2, and 3 Integrally Welded Attachments"

16. ASME Code Case N-521, Supplement 6, "Alternative Rules for Deferral of Inspections of Nozzle-to-Vessel Welds, Inside Radius Sections, and Nozzle-to-Safe End Welds of a Pressurized Water Reactor (PWR) Vessel," Section XI, Division 1

17. ASME Code Case N-524, "Alternative Examination Requirements for Longitudinal Welds in Class 1 and Class 2 Piping," Section XI, Division 1

18. ASME Code Case N-481, "Alternative Examination Requirements for Cast Austenitic Pump Casings"

B. Examination Areas

The components included in this LTP are as follows:

Class 1

Vessels

Reactor Pressure Vessel and Closure Head
Pressurizer
Steam Generators (Primary side)

Piping

Reactor Coolant System
Safety Injection System
Chemical and Volume Control System
Residual Heat Removal System
Waste Disposal System

Pumps

Reactor Coolant Pumps

Valves

Reactor Coolant System
Safety Injection System
Chemical and Volume Control System
Residual Heat Removal System
Waste Disposal System

Class 2

Vessels

Steam Generators (Secondary Side)
Regenerative Heat Exchanger
Chemical and Volume Control Tank
Containment Spray Heat Exchangers
Residual Heat Removal Heat Exchangers
Boron Injection Tank

Piping

Emergency Core Cooling System
Chemical and Volume Control System
Containment Spray System
Feedwater System
Main Steam System

Pumps

Safety Injection Pumps
Residual Heat Removal Pumps

Valves

Main Steam Isolation Valves

Piping (Cont'd)

Emergency Core Cooling System

Class 3

Piping

Auxiliary Feedwater System
Component Cooling Water System
Emergency Service Water System
Feedwater System
Spent Fuel Cooling System

Class 1, 2, and 3 Component Supports

Class 1 Component Supports
Class 2 Component Supports
Class 3 Component Supports
Class 3 Integral Attachments

THIS PAGE INTENTIONALLY LEFT BLANK

II. LONG-TERM EXAMINATION PLAN

A. Introduction to the Long-Term Examination Tables

The accompanying LTP examination tables present an outline of the examinations scheduled for the Class 1, 2, and 3 components for Cook 2. Also included in this plan are the components shared between Units 1 and 2.

Not all items listed in the tables are scheduled for examination, but for accountability purposes and to allow future flexibility in the program, each nonexempt component or system identified by SwRI and IMP has been listed.

These tables are separated into sections according to major systems or components and further subdivided to list the actual component, area, or weld to be examined. A discussion of the format and content of these tables follows and is presented in the order of the column headings appearing on each page of the tables. Figure 1, Page 11, provides further explanation of the LTP table format.

1. Summary Number

The number provides a unique sequential, six-digit reference for each table entry. It also provides a future reference to an Examination Summary Sheet which will precede the data package for each inspection area.

2. Examination Area Identification

Each component or system in this column is identified either by listing the name of the component or by a unique coded character as discussed in Section B.

3. ASME Section XI Category and Item Number

ASME Section XI Item Numbers and Categories are assigned for each component and are listed in the first and second columns, respectively. The items and categories are specified in ASME Section XI, 1989 Edition.

4. NDE Method

The nondestructive examination method is listed in this column. The various methods are used :

(a) VT-1, VT-2, and VT-3 (Visual)

(b) PT (Liquid Penetrant)

(c) MT (Magnetic Particle)

(d) UT (Ultrasonic)

(e) AUT (Automated Ultrasonic)

(f) RT (Radiographic)

At the request of IMP, RT is listed for those Class 2 nonexempt feedwater and main steam pipe welds requiring volumetric examinations (ASME Item Nos. C5.51 and C5.52).

The examination method assigned to a given component is based on the requirements of the 1989 Edition of Section XI for the Category and Item Number of that component.

5. Plan Status

The plan status is divided into ten columns to allow for ten 12-month refueling cycles for the inspection interval. For this program, six 18-month refueling outages were scheduled (two outages for each of the three periods). An "X" is placed to designate the cycle each component is scheduled, a "P" is placed to designate a partial examination is completed, and a "C" is placed to designate those examinations completed. The unused columns for each period allow flexibility in scheduling during the 10-year interval should the requirement arise.

6. Instructions

The Instructions column is used to provide additional information pertinent to the examinations. Typical information includes the following:

(a) Basic Calibration blocks(s) for each component scheduled for a UT examination. This is to facilitate the users of this plan in selecting the correct calibration block(s) for use during a UT examination.

(b) Special examination requirements unique to a given component or system.

(c) Other information necessary to explain unique examination results or limitations.

B. Examination Area Identification System

In the column, entitled "EXAMINATION AREA IDENTIFICATION," each component is identified either by listing the name of the component or by a unique coded character.

In most cases, component identifiers are preceded by the numeral 2, indicating Cook 2.

1. Vessels

a. Reactor Pressure Vessel (RPV)

Circumferential Welds. Circumferential weld numbers are of the form 2-RPV-X, where X is a particular circumferential weld (e.g., A=vessel-to-flange weld, B= upper shell-to-middle shell weld, etc.).

Longitudinal Welds. Longitudinal weld numbers are of the form 2-RPV-V (XY), where X is the location of the longitudinal weld in a particular shell, and Y is the unique number of that particular weld. For example, 2-RPV-VA1 is the first longitudinal weld (numbered clockwise from the vessel 0° position) located in the upper shell of the reactor pressure vessel.

Nozzle welds. Nozzle weld numbers are of the form 2-N (XA) or N (XB), where X is the number of the loop in which the nozzle functions and A or B designates the particular function of the nozzle (A for inlet or B for outlet). For example, N2B is the outlet nozzle for loop 2.

Safe End Welds. Safe end welds associated with the RPV nozzles are numbered 2-RPV-X-YY, where X is the loop number and YY the unique number of that weld. For example, 2-RPV-3-01 is the outlet nozzle-to-safe end weld in loop 3.

Closure Head Welds. The closure head weld numbers follow the pattern of 2- XX-YY, where XX are letter(s) designating the type of weld and YY are number(s) designating the unique number of a particular weld.

b. Pressurizer

General Welds. For all welds other than nozzle inner radii, the designation is 2-PRZ-XX, where the XX is a unique number for each weld.

Nozzle Inner Radii. For nozzle inner radii numbers, XX-2-RC-YY designates each nozzle, where XX is the diameter of the piping that is associated with that nozzle and YY the particular line number which is associated with that same nozzle. For example, 14-2-RC-5 is the surge nozzle of the pressurizer since the 14-inch diameter surge line is designated as 2-RC-5.

c. Steam Generator

The identifying character for the steam generator welds is STM-XX-YY, where XX is the number assigned to the particular steam generator and YY is the unique number of the weld. For example, STM-21-01 is the lower head-to-tube sheet weld on steam generator number 21.

d. Regenerative Heat Exchanger

The identifying character for the regenerative heat exchanger weld is "RHE-1-" followed by the individual weld number , assigned sequentially in the direction of flow (e.g., RHE-1-01, RHE-1-02, etc.).

e. Chemical and Volume Control Tank

Circumferential Welds. Circumferential weld numbers are of the form X-CVCT-2VS-Y, where VS designates vessel support and X is a unique number for each weld.

Vessel Support Welds. Support weld numbers are of the form 2-CVCT-2VS-X, where VS designates vessel support and X is a unique number for each weld.

f. CTS Heat Exchanger

Circumferential Welds. Circumferential weld numbers are of the form X-CTSHEX-Y, where X designates CTS heat exchanger (East) or W (West) and Y in a unique number for each weld.

Vessel Support Welds. Support weld numbers are of the form X-CTSHEX-YVS, where VS designates vessel support and X is a unique number for each weld.

g. RHR Heat Exchanger

Circumferential Welds. Circumferential weld numbers are of the form X-RHRHEX-Y, where X designates RHR heat exchanger E (East) or W (West) and Y in a unique number for each weld.

Vessel Support Welds. Support weld numbers are of the form X-RHRHEX-YVS where VS designates vessel support and Y is a unique number for each weld.

h. Boron Injection Tank

Circumferential Welds. Circumferential weld numbers are of the form 2-BIT-X, where X is a unique number for each weld.

Nozzle-to-Shell Welds. Nozzle weld numbers are of the form 2-BIT-VS-X, where X designates the flow direction. Also, (i) refers to the inlet nozzle and (0) refers to the outlet nozzles.

Vessel Support Welds. Support weld numbers are of the form 2-BIT-VX-X, where X is a unique number for each weld.

2. Piping

a. Reactor Coolant System Piping Welds

Circumferential Weld and Branch Connection Weld. The general designation for each circumferential weld and branch connection weld is 2-RC-XXX-YY, where XXX is the system line number and YY is unique weld number assigned sequentially in the direction of flow.

Longitudinal Weld. Each longitudinal weld is either upstream or downstream form a circumferential weld and, as a result, each longitudinal weld is numbered with reference to the adjacent circumferential weld number (see above). The letters LU or LD are added to the reference weld number to indicate whether the longitudinal weld is upstream (LU) or downstream (LD) from the reference weld; the letter I or O is added to the LU or LD to indicate that the weld is on the inside (I) or outside (O) radius for the elbow. Therefore, the general designation for a longitudinal weld is 2-RC-XXX-YY (LD or LU)-(I or 0). For example, 2-RC-1-O5LD-I is the longitudinal weld on the inside of the elbow downstream from weld 05 on the RC line 1.

b. Piping Welds, Exclusive of Reactor Cooling Piping

Circumferential Welds. For the remainder of the piping systems, the general format used to identify circumferential welds is 2-XX-YYY-ZZ.

The first group of characters, XX, indicates the system or function as shown in part (a) above (i.e., SI, CS, RH, WD). The second group of characters, YYY, indicates the line number as used on the isometric drawings. The individual weld number is then added, represented by the characters ZZ, sequentially numbered in the direction of flow. For example, weld number 2-SI-29-19 denotes safety injection system, line 29, weld No. 19.

Welds Other than Circumferential Welds. To identify those welds adjacent to but other than circumferential welds, the above format for circumferential welds is combined with the characters -BB-C; i.e., the general designation for such noncircumferential welds is 2-XX-YYY-ZZ-BB-C. The characters BB describe the weld as follows:

HL-Integrally welded hanger lug
PS-Integrally welded pipe support

Should there be more than one component of any certain BB category between successive circumferential welds, a unique number (C in the general designation above) is added to number each such weld, increasing either sequentially from the upstream weld or clockwise from L_o.

3. Component Supports

The general designation for component supports is 2-XXY-ZZZ, where XXX gives the general system designation and Y-ZZZ is the unique number assigned to the support.

III. BASIS FOR PREPARATION

A. Class 1 Components

In accordance with Subarticle IWB-2420 of Section XI, the sequence of component weld examinations established during the second 10-year interval was repeated during the third 10-year interval to the extent practical. The selection and allocation of Class 1 piping welds (Category B-J) were based on the 1974 Edition of Section XI with Addenda through Summer 1975, as allowed by 10CFR50.55a. The selection and allocation of Class 1 vessels, pumps, and valves were based on the 1989 Section XI requirements. The examination methods for all Class 1 components are based on the 1989 Section XI. Class 1 components were allocated among 6 outages occurring at approximately 18-month intervals.

B. Class 2 Components

The selection and allocation of Class 2 vessels, pumps, valves, and piping welds were based on the 1989 Code requirements. The examination methods for all Class 2 components are based on the 1989 Section XI requirements. Based on IWC-1221 requirements, several new safety injection welds were added to the third interval program. Also, AEP/IMP determined that the High Pressure Safety Injection Systems which experienced pressures greater than 600 psi needed to be added to the third interval program. An "H" has been placed after the ASME Section XI Category, i.e., C-F-1H in the database tables.

Class 2 components were allocated among 6 outages occurring at approximately 18-month intervals. The examination sequence, as established during the first and second 10-year intervals, was repeated for this interval to the extent practical.

C. Class 3 Components

Class 3 components were developed and incorporated into the Class 3 tables based on the requirements of IWD-2500 of the 1989 Code. The requirements for Class 3 components are visual examination of components during system pressure test and visual examinations of integral attachments. It should be noted that the requirements for examination of integral attachments are the same as the requirements of Subsection IWF for system component supports. Since the Class 3 integral attachments and associated examinations correspond to those component supports listed in the component supports examination tables, a Class 3 table was not generated. Instead, the Class 3 tables list only the systems requiring examinations (see also Paragraph III.D).

D. Class 1, 2, and 3 Component Supports

Examination tables for Class 1, 2, and 3 component supports were developed in accordance with the requirements for Subsection IWF of the 1989 Code. The component supports are organized in the same order as the Class 1, 2, and 3 tables for ease of identification.

The guidelines of Code Case N-509, which do not require examinations for the third and fourth intervals, will be used in the performance and scheduling of examinations in lieu of the IWF, Category F-A requirements of the 1989 Edition of Section XI.

Scope of examination --10 percent of the integral attachments will receive a surface examination on 100 percent of the required areas of each welded attachment. In the case of multiple components within a system of similar design, function, and service, only one of the integral attachments of only one of the multiple components shall be examined. The integral attachments selected for examination shall correspond to those component supports selected by IWF-2510(B).

The guidelines of Code Case N-491 will be used to determine the component supports subject to examination and will establish examination requirements for Class 1, 2, and 3 components under Subsection IWF, Section XI.

Supports, hangers, and snubbers (and associated integral attachments) which support the weight of or provide structural stability for nonexempt Class 1, 2, and 3 components were selected for examination.

The requirements of IWF-5000 for snubber testing will be performed by IMP personnel in accordance with Cook 2 technical specifications and plant maintenance schedules. Scheduling of snubber testing is not included in this plan.

E. Code Relief

A number of welds cannot be examined due to inaccessibility or component configuration. Code relief for these areas was granted by the USNRC during the first and second intervals. Since accessibility or configuration for these welds has not changed, and where Code examination requirements are the same, Code relief is requested for the third interval. Alternate examinations or supplementary requirements specified by the USNRC in granting Code relief have been scheduled and will be performed as originally required. These instances are noted in the "Remarks Column" of the summary tables.

F. System Pressure Test

The same Code reliefs which were granted by USNRC letters dated June 28 and August 13, 1985, for Unit 1 are also necessary for both units during the third inspection interval. Unless advised otherwise, we consider these Code relief request granted for the third inspection interval.

DATE:
REVISION:

COOK NUCLEAR PLANT UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 1 ALL STATUS COMPONENTS

PAGE:

				INSPECTION INTERVAL	PLAN STATUS		
REACTOR PRESSURE VESSEL AND CLOSURE HEAD				FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	
		ASME SEC. XI					
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATGY ITEM NO	NDE METH	1 2 3	OUTAGE 1 2 3 4	1 2 3	INSTRUCTIONS **CALIBRATION BLOCK**

The Instructions/Calibration Block column is used to provide additional information such as limitations, amount of weld to be inspected, ultrasonic calibration blocks to be used, etc.

The Inspection Interval column is subdivided into three periods. These periods are then subdivided into 10 cycles. Within each of the cycle columns, an "X" is placed to designate the cycle each component or weld is scheduled, a "P" is placed to designate a partial examination has been completed, and a "C" is placed to designate those examinations which have been completed. The third or fourth cycle, as applicable, for each period does not have examinations scheduled to provide flexibility in scheduling during the 10-year interval should the requirement arise.

The NDE method used for the inspection is listed in this column.

The ASME Section XI Item Number and Category of the inspection area are listed in these columns.

Each Examination Area Identification is listed here. Details of the Weld ID System are located in Section II of Volume I.

This column lists the individual weld or component reference number.

Figure 1. Explanation of the Long-Term Plan Table Format

THIS PAGE INTENTIONALLY LEFT BLANK

REACTOR PRESSURE VESSEL AND CLOSURE HEAD

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	VESSEL CIRCUMFERENTIAL WELDS (FIG NO A-1)													
000100	2-RPV-B	B-A	AUT	1	-	-	-	-	-	-	-	C	-	EXAMINE IN ACCORDANCE WITH
	UPPER SHELL TO MIDDLE SHELL	B1.11		2	-	-	-	-	-	-	-	X	-	REG. GUIDE 1.150, REV. 1.
	U. CONT.			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	**RV-1/11-CSCL-5-DCC**
000200	2-RPV-C	B-A	AUT	1	-	-	-	-	-	-	-	C	-	EXAMINE IN ACCORDANCE WITH
	MIDDLE SHELL TO LOWER SHELL	B1.11		2	-	-	-	-	-	-	-	X	-	REG. GUIDE 1.150, REV. 1.
	U. CONT.			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	**RV-1/11-CSCL-5-DCC**
000300	2-RPV-D	B-A	AUT	1	-	-	-	-	-	-	-	C	-	EXAMINE IN ACCORDANCE WITH
	LOWER SHELL TO LOWER HEAD	B1.11		2	-	-	-	-	-	-	-	X	-	REG. GUIDE 1.150, REV. 1.
	U. CONT.			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	**RV-3/11-CSCL-5-DCC**
	VESSEL LONGITUDINAL WELDS (FIG NO A-1)													
000400	2-RPV-VA1	B-A	AUT	1	-	-	-	-	-	-	-	C	-	EXAMINE IN ACCORDANCE WITH
	UPPER SHELL AT 22 DEG.	B1.12		2	-	-	-	-	-	-	-	X	-	REG. GUIDE 1.150, REV. 1.
	U. CONT.			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	**11-CSCL-5-DCC**
000500	2-RPV-VA2	B-A	AUT	1	-	-	-	-	-	-	-	C	-	EXAMINE IN ACCORDANCE WITH
	UPPER SHELL AT 113 DEG.	B1.12		2	-	-	-	-	-	-	-	X	-	REG. GUIDE 1.150, REV. 1.
	U. CONT.			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	**11-CSCL-5-DCC**
000600	2-RPV-VA3	B-A	AUT	1	-	-	-	-	-	-	-	C	-	EXAMINE IN ACCORDANCE WITH
	UPPER SHELL AT 247 DEG.	B1.12		2	-	-	-	-	-	-	-	X	-	REG. GUIDE 1.150, REV. 1.
	U. CONT.			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	**11-CSCL-5-DCC**
000700	2-RPV-VB1	B-A	AUT	1	-	-	-	-	-	-	-	C	-	EXAMINE IN ACCORDANCE WITH
	MIDDLE SHELL AT 170 DEG.	B1.12		2	-	-	-	-	-	-	-	X	-	REG. GUIDE 1.150, REV. 1.
	U. CONT.			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	**RV-1/11-CSCL-5-DCC**

REACTOR PRESSURE VESSEL AND CLOSURE HEAD

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	VESSEL LONGITUDINAL WELDS (FIG NO A-1)															
000800	2-RPV-VB2	B-A	AUT	1	-	-	-	-	-	-	-	-	C	-		EXAMINE IN ACCORDANCE WITH
	MIDDLE SHELL AT 350 DEG.	B1.12		2	-	-	-	-	-	-	-	-	X	-		REG. GUIDE 1.150, REV. 1.
	U. CONT.			3	-	-	-	-	-	-	-	-	X	-		
				4	-	-	-	-	-	-	-	-	-	-		**RV-1/11-CSCL-5-DCC**
000900	2-RPV-VC1	B-A	AUT	1	-	-	-	-	-	-	-	-	C	-		EXAMINE IN ACCORDANCE WITH
	LOWER SHELL AT 90 DEG.	B1.12		2	-	-	-	-	-	-	-	-	X	-		REG. GUIDE 1.150, REV. 1.
	U. CONT.			3	-	-	-	-	-	-	-	-	X	-		
				4	-	-	-	-	-	-	-	-	-	-		**RV-1/11-CSCL-5-DCC**
001000	2-RPV-VC2	B-A	AUT	1	-	-	-	-	-	-	-	-	C	-		EXAMINE IN ACCORDANCE WITH
	LOWER SHELL AT 270 DEG.	B1.12		2	-	-	-	-	-	-	-	-	X	-		REG. GUIDE 1.150, REV. 1.
	U. CONT.			3	-	-	-	-	-	-	-	-	X	-		
				4	-	-	-	-	-	-	-	-	-	-		**RV-1/11-CSCL-5-DCC**
	CLOSURE HEAD DOLLAR PLATE WELD (FIG NO A-2)															
001100	2-CHC-02	B-A	UT	1	-	-	-	-	C	-	-	-	-	-		VT PERFORMED DURING SYSTEM
	DOLLAR PLATE WELD	B1.21		2	-	-	-	-	-	-	-	-	-	-		PRESSURE TEST IN FIRST
	CONT.			3	-	-	-	-	-	-	-	-	-	-		INTERVAL. WELD IS
				4	-	-	-	-	-	-	-	-	-	-		INACCESSIBLE FOR EXAMINATION DUE TO INTERFERENCE OF THE CRD SHROUD. **RV-2**
	CLOSURE HEAD MERIDIONAL WELDS (FIG NO A-2)															
001200	2-CHM-01	B-A	UT	1	C	-	-	-	-	-	-	-	-	-		EXAMINE ACCESSIBLE LENTH OF
	MERIDIONAL WELD AT 26 DEG.	B1.22		2	-	-	-	C	-	-	-	-	-	-		WELD IN ACCORDANCE WITH REG.
	CONT.			3	-	-	-	X	-	-	-	-	-	-		GUIDE 1.150, REV. 1.
				4	-	-	-	-	-	-	-	-	-	-		**RV-2**
001300	2-CHM-02	B-A	UT	1	-	-	-	C	-	-	-	-	-	-		EXAMINE ACCESSIBLE-LENTH OF
	MERIDIONAL WELD AT 77 DEG.	B1.22		2	-	-	-	-	-	-	-	-	-	-		WELD IN ACCORDANCE WITH REG.
	CONT.			3	-	-	-	X	-	-	-	-	-	-		GUIDE 1.150, REV. 1.
				4	-	-	-	-	-	-	-	-	-	-		**RV-2**

REACTOR PRESSURE VESSEL AND CLOSURE HEAD

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	CLOSURE HEAD MERIDIONAL WELDS (FIG NO A-2)													
001400	2-CHM-03	B-A	UT	1	-	-	-	-	-	-	C	-	-	EXAMINE ACCESSIBLE LENGTH OF
	MERIDIONAL WELD AT 129 DEG.	B1.22		2	-	-	-	-	-	-	-	-	-	WELD IN ACCORDANCE WITH REG.
	CONT.			3	-	-	-	X	-	-	-	-	-	GUIDE 1.150, REV. 1.
				4	-	-	-	-	-	-	-	-	-	**RV-2**
001500	2-CHM-04	B-A	UT	1	-	-	-	-	-	-	C	-	-	EXAMINE ACCESSIBLE LENTH OF
	MERIDIONAL WELD AT 180 DEG.	B1.22		2	-	-	-	-	-	-	-	-	-	WELD IN ACCORDANCE WITH REG.
	CONT.			3	-	-	-	X	-	-	-	-	-	GUIDE 1.150, REV. 1.
				4	-	-	-	-	-	-	-	-	-	**RV-2**
001600	2-CHM-05	B-A	UT	1	-	-	-	C	-	-	-	-	-	EXAMINE ACCESSIBLE LENTH OF
	MERIDIONAL WELD AT 231 DEG.	B1.22		2	-	-	-	-	-	-	-	-	-	WELD IN ACCORDANCE WITH REG.
	CONT.			3	-	-	-	X	-	-	-	-	-	GUIDE 1.150, REV. 1.
				4	-	-	-	-	-	-	-	-	-	**RV-2**
001700	2-CHM-06	B-A	UT	1	C	-	-	-	-	-	-	-	-	EXAMINE ACCESSIBLE LENTH OF
	MERIDIONAL WELD AT 283 DEG.	B1.22		2	-	-	-	-	-	-	-	-	-	WELD IN ACCORDANCE WITH REG.
	CONT.			3	-	-	-	X	-	-	-	-	-	GUIDE 1.150, REV. 1.
				4	-	-	-	-	-	-	-	-	-	**RV-2**
001705	2-CHM-07	B-A	UT	1	C	-	-	-	-	-	-	-	-	EXAMINE ACCESSIBLE LENTH OF
	MERIDIONAL WELD AT 334 DEG.	B1.22		2	-	-	-	-	-	-	C	-	-	WELD IN ACCORDANCE WITH REG.
	U. CONT.			3	-	-	-	X	-	-	-	-	-	GUIDE 1.150, REV. 1.
				4	-	-	-	-	-	-	-	-	-	**RV-2**
	REACTOR VESSEL LOWER HEAD DOLLAR PLATE WELD (FIG NO A-1)													
001710	2-LHC-01	B-A	AUT	1	-	-	-	-	-	-	-	-	-	WELD IS INACCESSIBLE DUE TO
	DOLLAR PLATE WELD	B1.21		2	-	-	-	-	-	-	-	-	-	INTERFERENCE OF THE LOWER HEAD
	CONT.			3	-	-	-	-	-	-	-	-	-	INSTRUMENT PENETRATIONS.
				4	-	-	-	-	-	-	-	-	-	
	REACTOR VESSEL LOWER HEAD MERIDIONAL WELDS (FIG NO A-1)													
001720	2-LHM-01	B-A	AUT	1	-	-	-	-	-	-	-	C	-	
	MERIDIONAL WELD AT 26 DEG.	B1.22		2	-	-	-	-	-	-	-	-	-	
	CONT.			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	**RV-3/11-CSCL-5-DCC**

REACTOR PRESSURE VESSEL AND CLOSURE HEAD

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	REACTOR VESSEL LOWER HEAD MERIDIONAL WELDS (FIG NO A-1)														
001730	2-LHM-02	B-A	AUT	1	-	-	-	-	-	-	-	C	-		
	MERIDIONAL WELD AT 77 DEG.	B1.22		2	-	-	-	-	-	-	-	-	-		
	CONT.			3	-	-	-	-	-	-	-	X	-		
				4	-	-	-	-	-	-	-	-	-		**RV-3/11-CSCL-5-DCC**
001740	2-LHM-03	B-A	AUT	1	-	-	-	-	-	-	-	C	-		
	MERIDIONAL WELD AT 129 DEG.	B1.22		2	-	-	-	-	-	-	-	X	-		
	U. CONT.			3	-	-	-	-	-	-	-	X	-		
				4	-	-	-	-	-	-	-	-	-		**RV-3/11-CSCL-5-DCC**
001750	2-LHM-04	B-A	AUT	1	-	-	-	-	-	-	-	C	-		
	MERIDIONAL WELD AT 180 DEG.	B1.22		2	-	-	-	-	-	-	-	-	-		
	CONT.			3	-	-	-	-	-	-	-	X	-		
				4	-	-	-	-	-	-	-	-	-		**RV-3/11-CSCL-5-DCC**
001760	2-LHM-05	B-A	AUT	1	-	-	-	-	-	-	-	C	-		
	MERIDIONAL WELD AT 231 DEG.	B1.22		2	-	-	-	-	-	-	-	-	-		
	CONT.			3	-	-	-	-	-	-	-	X	-		
				4	-	-	-	-	-	-	-	-	-		**RV-3/11-CSCL-5-DCC**
001770	2-LHM-06	B-A	AUT	1	-	-	-	-	-	-	-	C	-		
	MERIDIONAL WELD AT 283 DEG.	B1.22		2	-	-	-	-	-	-	-	-	-		
	CONT.			3	-	-	-	-	-	-	-	X	-		
				4	-	-	-	-	-	-	-	-	-		**RV-3/11-CSCL-5-DCC**
001780	2-LHM-07	B-A	AUT	1	-	-	-	-	-	-	-	C	-		
	MERIDIONAL WELD AT 334 DEG.	B1.22		2	-	-	-	-	-	-	-	-	-		
	CONT.			3	-	-	-	-	-	-	-	X	-		
				4	-	-	-	-	-	-	-	-	-		**RV-3/11-CSCL-5-DCC**
	VESSEL TO FLANGE WELD (FIG NO A-1)														
001800	2-RPV-A	B-A	AUT	1	-	C	-	-	-	-	-	C	-		PARTIAL EXAMS FROM SEAL
	VESSEL TO FLANGE	B1.30	UT	2	C	-	-	-	-	-	-	X	-		SURFACE DEFERRED TO 3RD
	U. CONT.			3	-	-	-	-	-	-	-	X	-		PERIOD. EXAMINE FROM VESSEL
				4	-	-	-	-	-	-	-	-	-		WALL INSIDE SURFACE DURING 3RD PERIOD. EXAM TO BE PERFORMED IN ACCORDANCE WITH REG. GUIDE 1.150, REV. 1. **CSCL-5-DCC/CSCL-34-DCC**

REACTOR PRESSURE VESSEL AND CLOSURE HEAD

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	PLAN STATUS FIRST PERIOD 2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	CLOSURE HEAD TO FLANGE WELD (FIG NO A-2)													
001900	2-CHC-01	B-A	MT	C	-	-	C	-	-	-	C	-	-	EXAMINE 33% (172") IN
	HEAD TO FLANGE	B1.40	UT	-	-	-	P	-	-	-	C	X	-	ACCORDANCE WITH REG. GUIDE
	U. CONT.			-	-	-	X	-	-	-	X	-	-	1.150, REV. 1 DURING EACH
				-	-	-	-	-	-	-	-	-	-	DESIGNATED OUTAGE.
														RV-2
	NOZZLE TO SHELL AND SHELL TO NOZZLE WELDS (FIG NO A-1)													
002000	2-N1-I	B-D	AUT	-	-	-	-	-	-	-	-	C	-	EXAMINE IN ACCORDANCE WITH
	INLET NOZZLE TO SHELL AT 293	B3.90		-	-	-	-	-	-	-	-	X	-	REG. GUIDE 1.150, REV. 1, AND
	DEG.			-	-	-	-	-	-	-	-	X	-	CC-N-521.
	U. CONT.			-	-	-	-	-	-	-	-	-	-	**CSCL-5-DCC/CSCL-7-DCC**
002100	2-N1-O	B-D	AUT	-	C	-	-	-	-	-	-	C	-	EXAMINE IN ACCORDANCE WITH
	SHELL TO OUTLET NOZZLE AT 338	B3.90		C	-	-	-	-	-	-	-	X	-	REG. GUIDE 1.150, REV. 1, AND
	DEG.			-	-	-	-	-	-	-	-	X	-	CC-N-521.
	U. CONT.			-	-	-	-	-	-	-	-	-	-	**CSCL-5-DCC/CSCL-7-DCC**
002200	2-N2-I	B-D	AUT	-	-	-	-	-	-	-	-	C	-	EXAMINE IN ACCORDANCE WITH
	INLET NOZZLE TO SHELL AT 247	B3.90		-	-	-	C	-	-	-	-	X	-	REG. GUIDE 1.150, REV. 1, AND
	DEG.			-	-	-	-	-	-	-	-	X	-	CC-N-521.
	U. CONT.			-	-	-	-	-	-	-	-	-	-	**CSCL-5-DCC/CSCL-7-DCC**
002300	2-N2-O	B-D	AUT	-	C	-	-	-	-	-	-	C	-	EXAMINE IN ACCORDANCE WITH
	SHELL TO OUTLET NOZZLE AT 202	B3.90		C	-	-	-	-	-	-	-	X	-	REG. GUIDE 1.150, REV. 1, AND
	DEG.			X	-	-	-	-	-	-	-	X	-	CC-N-521.
	U. CONT.			-	-	-	-	-	-	-	-	-	-	**CSCL-5-DCC/CSCL-7-DCC**
002400	2-N3-I	B-D	AUT	-	-	-	-	-	-	-	-	C	-	EXAMINE IN ACCORDANCE WITH
	INLET NOZZLE TO SHELL AT 113	B3.90		-	-	-	-	-	-	-	-	X	-	REG. GUIDE 1.150, REV. 1, AND
	DEG.			-	-	-	-	-	-	-	-	X	-	CC-N-521.
	U. CONT.			-	-	-	-	-	-	-	-	-	-	**CSCL-5-DCC/CSCL-7-DCC**

REACTOR PRESSURE VESSEL AND CLOSURE HEAD

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	NOZZLE TO SHELL AND SHELL TO NOZZLE WELDS (FIG NO A-1)															
002500	2-N3-O	B-D	AUT	1	-	-	-	-	C	-	-	-	C	-		EXAMINE IN ACCORDANCE WITH
	SHELL TO OUTLET NOZZLE AT 158	B3.90		2	-	-	-	-	-	-	-	-	X	-		REG. GUIDE 1.150, REV. 1, AND
	DEG.			3	-	-	-	-	-	-	-	-	X	-		CC-N-521.
	U. CONT.			4	-	-	-	-	-	-	-	-	-	-		**11-CSCL-5-DCC**
002600	2-N4-I	B-D	AUT	1	-	-	-	-	-	-	-	-	C	-		EXAMINE IN ACCORDANCE WITH
	INLET NOZZLE TO SHELL AT 67	B3.90		2	-	-	-	-	-	-	-	-	X	-		REG. GUIDE 1.150, REV. 1, AND
	DEG.			3	-	-	-	-	-	-	-	-	X	-		CC-N-521.
	U. CONT.			4	-	-	-	-	-	-	-	-	-	-		**CSCL-5-DCC/CSCL-7-DCC**
002700	2-N4-O	B-D	AUT	1	-	-	-	-	C	-	-	-	C	-		EXAMINE IN ACCORDANCE WITH
	SHELL TO OUTLET NOZZLE AT 22	B3.90		2	-	-	-	-	-	-	-	-	X	-		REG. GUIDE 1.150, REV. 1, AND
	DEG.			3	-	-	-	-	-	-	-	-	X	-		CC-N-521.
	U. CONT.			4	-	-	-	-	-	-	-	-	-	-		**CSCL-5-DCC/CSCL-7-DCC**
	NOZZLE INSIDE RADIUS SECTIONS (FIG NO A-3)															
002800	2-N1-I-IRS	B-D	AUT	1	-	-	-	-	-	-	-	-	C	-		EXAMINE IN ACCORDANCE WITH
	INLET NOZZLE AT 293 DEG.	B3.100		2	-	-	-	-	-	-	-	-	X	-		CC-N-521.
	U. CONT.			3	-	-	-	-	-	-	-	-	X	-		
				4	-	-	-	-	-	-	-	-	-	-		**IR-CSCL-8-DCC**
002900	2-N1-O-IRS	B-D	AUT	1	-	C	-	-	-	-	-	-	-	-		EXAMINE IN ACCORDANCE WITH
	OUTLET NOZZLE AT 338 DEG.	B3.100		2	C	-	-	-	-	-	-	-	-	-		CC-N-521.
				3	-	-	-	-	-	-	-	-	X	-		
				4	-	-	-	-	-	-	-	-	-	-		**IR-CSCL-8-DCC**
003000	2-N2-I-IRS	B-D	AUT	1	-	-	-	-	-	-	-	-	C	-		EXAMINE IN ACCORDANCE WITH
	INLET NOZZLE AT 247 DEG.	B3.100		2	-	-	-	-	-	-	-	-	X	-		CC-N-521.
	U. CONT.			3	-	-	-	-	-	-	-	-	X	-		
				4	-	-	-	-	-	-	-	-	-	-		**IR-CSCL-8-DCC**
003100	2-N2-O-IRS	B-D	AUT	1	-	C	-	-	-	-	-	-	-	-		EXAMINE IN ACCORDANCE WITH
	OUTLET NOZZLE AT 202 DEG.	B3.100		2	C	-	-	-	-	-	-	-	-	-		CC-N-521.
				3	-	-	-	-	-	-	-	-	X	-		
				4	-	-	-	-	-	-	-	-	-	-		**IR-CSCL-8-DCC**

REACTOR PRESSURE VESSEL AND CLOSURE HEAD

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	NOZZLE INSIDE RADIUS SECTIONS (FIG NO A-3)													
003200	2-N3-I-IRS	B-D	AUT	1	-	-	-	-	-	-	-	C	-	EXAMINE IN ACCORDANCE WITH
	INLET NOZZLE AT 113 DEG.	B3.100		2	-	-	-	-	-	-	-	X	-	CC-N-521.
	U. CONT.			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	**IR-CSCL-8-DCC**
003300	2-N3-O-IRS	B-D	AUT	1	-	-	-	-	C	-	-	-	-	EXAMINE IN ACCORDANCE WITH
	OUTLET NOZZLE AT 158 DEG.	B3.100		2	-	-	-	-	-	-	-	X	-	CC-N-521.
	U. CONT.			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	**IR-CSCL-8-DCC**
003400	2-N4-I-IRS	B-D	AUT	1	-	-	-	-	-	-	-	C	-	EXAMINE IN ACCORDANCE WITH
	INLET NOZZLE AT 67 DEG.	B3.100		2	-	-	-	-	-	-	-	X	-	CC-N-521.
	U. CONT.			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	**IR-CSCL-8-DCC**
003500	2-N4-O-IRS	B-D	AUT	1	-	-	-	-	C	-	-	-	-	EXAMINE IN ACCORDANCE WITH
	OUTLET NOZZLE AT 22 DEG.	B3.100		2	-	-	-	-	-	-	-	X	-	CC-N-521.
	U. CONT.			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	**IR-CSCL-8-DCC**
	REACTOR VESSEL PENETRATIONS (FIG NO A-3)													
003550	LOWER HEAD PENETRATIONS	B-E	VT-2	1	-	C	-	C	-	-	-	C	-	-	EXAMINE 25% (15 WELDS) DURING
	58 PENETRATIONS	B4.13		2	-	-	-	-	-	-	-	-	X	-	SYSTEM LEAKAGE TEST PER
	CONT.			3	-	-	-	-	-	-	-	-	X	-	CC-N-498-1.
				4	-	-	-	-	-	-	-	-	-	-	
	REACTOR VESSEL PENETRATIONS (FIG NO A-2)													
003600	CLOSURE HEAD CRD PENETRATIONS	B-E	VT-2	1	-	C	-	C	-	-	-	C	-	-	EXAMINE 25% (20 WELDS) DURING
	78 PENETRATIONS	B4.12		2	-	-	-	-	-	-	-	-	X	-	SYSTEM LEAKAGE TEST PER
	CONT.			3	-	-	-	-	-	-	-	-	X	-	CC-N-498-1.
				4	-	-	-	-	-	-	-	-	-	-	

REACTOR PRESSURE VESSEL AND CLOSURE HEAD

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	REACTOR VESSEL PENETRATIONS (FIG NO A-2)													
003610	CLOSURE HEAD VENT LINE 1 PENETRATION CONT.	B-E B4.11	VT-2	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION TO BE PERFORMED DURING SYSTEM LEAKAGE TEST PER CC-N-498-1.
				2 -	-	-	-	-	-	-	-	X	-	
				3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	
	NOZZLE TO SAFE-END AND SAFE-END TO NOZZLE WELDS (FIG NO A-3)													
003700	2-RPV-1-01 NOZZLE TO SAFE-END "HOT LEG"	B-F B5.10	PT AUT	1 -	C	-	-	-	-	-	-	-	-	PERFORM AUT FROM ID IN LIEU OF PT.
				2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-DCC/46-DCC**
003800	2-RPV-1-02 SAFE-END TO NOZZLE "COLD LEG" SNDBX L1CL	B-F B5.10	PT AUT	1 -	-	-	-	-	-	-	C	C	-	PERFORM AUT FROM ID IN LIEU OF PT.
				2 -	-	-	-	-	-	-	-	X	-	
				3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-DCC/46-DCC**
003900	2-RPV-2-01 NOZZLE TO SAFE-END "HOT LEG"	B-F B5.10	PT AUT	1 -	C	-	-	-	-	-	-	-	-	PERFORM AUT FROM ID IN LIEU OF PT.
				2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	**PL-3.0-CSCL-4-DCC**
004000	2-RPV-2-02 SAFE-END TO NOZZLE "COLD LEG" SNDBX L2CL	B-F B5.10	PT AUT	1 -	-	-	-	-	-	-	C	C	-	PERFORM AUT FROM ID IN LIEU OF PT.
				2 -	-	-	-	-	-	-	-	X	-	
				3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	**PL-3.0-CSCL-4-DCC**
004100	2-RPV-3-01 NOZZLE TO SAFE-END "HOT LEG" SNDBX L3HL	B-F B5.10	PT AUT	1 -	-	-	-	C	-	-	-	-	-	PERFORM AUT FROM ID IN LIEU OF PT.
				2 -	-	-	-	-	-	-	-	X	-	
				3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	**PL-3.0-CSCL-4-DCC**
004200	2-RPV-3-02 SAFE-END TO NOZZLE "COLD LEG" SNDBX L3CL	B-F B5.10	PT AUT	1 -	-	-	-	-	-	-	C	C	-	PERFORM AUT FROM ID IN LIEU OF PT.
				2 -	-	-	-	-	-	-	-	X	-	
				3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-DCC/46-DCC**

REACTOR PRESSURE VESSEL AND CLOSURE HEAD

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	NOZZLE TO SAFE-END AND SAFE-END TO NOZZLE WELDS (FIG NO A-3)													
004300	2-RPV-4-01	B-F	PT	1 -	-	-	-	C	-	-	-	-	-	PERFORM AUT FROM ID IN LIEU OF
	NOZZLE TO SAFE-END "HOT LEG"	B5.10	AUT	2 -	-	-	-	-	-	-	-	X	-	PT.
	SNDBX L4HL			3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	**PL-3.0-CSCL-4-DCC**
004400	2-RPV-4-02	B-F	PT	1 -	-	-	-	-	-	-	C	C	-	PERFORM AUT FROM ID IN LIEU OF
	SAFE-END TO NOZZLE "COLD LEG"	B5.10	AUT	2 -	-	-	-	-	-	-	-	X	-	PT.
	SNDBX L4CL			3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	**PL-3.0-CSCL-4-DCC**
	CLOSURE STUDS													
004500	2-RPV-STUD	B-G-1	MT	1 C	C	-	C	-	-	-	C	-	-	EXAMINE 33% (18 STUDS) EACH
	1 THROUGH 54	B6.30	UT	2 -	-	-	P	-	-	-	C	-	-	DESIGNATED OUTAGE.
	650' AUX.			3 -	X	-	X	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**7-.750-8-CS-10-DCC**
	CLOSURE NUTS													
004600	2-RPV-NUT	B-G-1	MT	1 C	C	-	C	-	-	-	C	-	-	EXAMINE 33% (18 NUTS) EACH
	1 THROUGH 54	B6.10		2 -	-	-	P	-	-	-	C	-	-	DESIGNATED OUTAGE.
	650' AUX.			3 -	X	-	X	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	VESSEL FLANGE THREADS													
004700	2-RPV-FLANGE THREADS	B-G-1	UT	1 C	C	-	C	-	-	-	C	-	-	EXAMINE 33% (18) OF THE
	1 THROUGH 54	B6.40		2 -	-	-	P	-	-	-	C	-	-	THREADS EACH DESIGNATED
	U. CONT.			3 -	X	-	X	-	-	-	X	-	-	OUTAGE.
				4 -	-	-	-	-	-	-	-	-	-	**7-.750-8-CS-10-DCC**
	CLOSURE WASHERS													
004800	2-RPV-WASHER	B-G-1	VT-1	1 C	C	-	C	-	-	-	C	-	-	EXAMINE 33% (18 WASHERS) EACH
	1 THROUGH 54	B6.50	MT	2 -	-	-	P	-	-	-	C	-	-	DESIGNATED OUTAGE. PERFORM PT
	650' AUX.			3 -	X	-	X	-	-	-	X	-	-	IN ACCORDANCE WITH REG. GUIDE
				4 -	-	-	-	-	-	-	-	-	-	1.65.

REACTOR PRESSURE VESSEL AND CLOSURE HEAD

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	FIRST PERIOD 2	FIRST PERIOD 3	OUTAGE 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	RPV INTERIOR SURFACES AND CORE SUPPORT STRUCTURES													
006010	RPV UPPER INTERNALS & SURFACES	B-N-1	VT-3	1	C	-	C	-	-	-	-	C	-	EXAMINE EACH PERIOD. AUGMENTED
	AREAS ACCESSIBLE DURING NORMAL	B13.10		2	C	-	-	C	-	-	-	X	-	VT-1 ON BAFFLE PLATE
	REFUELING			3	X	-	-	X	-	-	-	X	-	FASTENERSIN ONE QUADRANT (90
	U. CONT.			4	-	-	-	-	-	-	-	-	-	DEG.) OF LOWER INTERNALS.
006021	RPV-CS-LUGS 1 THROUGH 6	B-N-2	VT-3	1	-	-	-	-	-	-	-	C	-	EXAMINE WHEN CORE BARREL IS
	CORE SUPPORT LUGS	B13.60		2	-	-	-	-	-	-	-	X	-	REMOVED.
	U. CONT.			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	
006040	2-RPV CORE SUPPORT STRUCTURE	B-N-3	VT-3	1	-	-	-	-	-	-	-	C	-	EXAMINE WHEN REMOVED.
	(WHEN REMOVED)	B13.70		2	-	-	-	-	-	-	-	X	-	
	U. CONT.			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	
	CONTROL ROD DRIVE HOUSING WELDS													
006060	CONTROL ROD DRIVE HOUSING WELD	B-O	PT	1	-	-	C	-	-	-	-	-	-	EXAMINE THE WELD ON 10% (8) OF
	78 WELDS	B14.10		2	-	-	-	-	-	-	-	X	-	THE PERIPHERAL CRDS.
	U. CONT.			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	

PRESSURIZER

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	CIRCUMFERENTIAL WELDS (FIG NO A-4)													
006100	2-PRZ-11	B-B	UT	1 C	-	-	-	-	-	-	-	-	-	
	LOWER SHELL TO LOWER HEAD	B2.11		2 -	-	-	C	-	-	-	-	-	-	
	CONT.			3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**RV-3**
006200	2-PRZ-12	B-B	--	1 C	-	-	-	-	-	-	-	-	-	
	SHELL TO SHELL	--		2 -	-	-	-	-	-	-	-	-	-	
	CONT.			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
006300	2-PRZ-13	B-B	--	1 -	-	-	-	-	-	-	C	-	-	
	SHELL TO SHELL	--		2 -	-	-	-	-	-	-	-	-	-	
	CONT.			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
006400	2-PRZ-14	B-B	--	1 -	-	-	-	-	-	-	C	-	-	
	SHELL TO SHELL	--		2 -	-	-	-	-	-	-	-	-	-	
	CONT.			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
006500	2-PRZ-15	B-B	UT	1 -	-	-	C	-	-	-	-	-	-	
	UPPER HEAD TO UPPER SHELL	B2.11		2 -	-	-	-	C	-	-	-	-	-	
	PRESS. DH			3 -	-	-	-	X	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**RV-3**
	LONGITUDINAL WELDS (FIG NO A-4)													
006600	2-PRZ-16	B-B	UT	1 C	-	-	-	-	-	-	-	-	-	EXAMINE 1 FOOT OF WELD LENGTH
	LONGITUDINAL SEAM	B2.12		2 -	-	-	C	-	-	-	-	-	-	NEAR HEAD.
	CONT.			3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**RV-3**
006700	2-PRZ-17	B-B	--	1 C	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	--		2 -	-	-	-	-	-	-	-	-	-	
	CONT.			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

PRESSURIZER

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LONGITUDINAL WELDS (FIG NO A-4)													
006800	2-PRZ-18	B-B	--	1	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	--		2	-	-	-	-	-	-	-	-	-	
	CONT.			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
006900	2-PRZ-19	B-B	UT	1	-	-	-	C	-	-	-	-	-	-	EXAMINE 1 FOOT OF WELD LENGTH
	LONGITUDINAL SEAM	B2.12		2	-	-	-	-	C	-	-	-	-	-	NEAR HEAD.
	PRESS. DH			3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**RV-3**
	NOZZLE TO SHELL AND SHELL TO NOZZLE WELDS (FIG NO A-4)													
006920	4"-2-RC-28	B-D	UT	1	-	-	-	-	-	-	-	C	-	-	
	UPPER HEAD TO SPRAY NOZZLE	B3.110		2	-	-	-	-	-	-	-	C	-	-	
	PRESS. DH			3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**PL-3.0-CSCL-4-DCC**
006930	6"-2-RC-22	B-D	UT	1	-	-	-	C	-	-	-	-	-	-	
	UPPER HEAD TO RELIEF NOZZLE	B3.110		2	-	-	-	C	-	-	-	-	-	-	
	PRESS. DH			3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**PL-3.0-CSCL-4-DCC**
006940	6"-2-RC-25	B-D	UT	1	C	-	-	-	-	-	-	-	-	-	
	UPPER HEAD TO RELIEF NOZZLE	B3.110		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**PL-3.0-CSCL-4-DCC**
006950	6"-2-RC-26	B-D	UT	1	C	-	-	-	-	-	-	-	-	-	
	UPPER HEAD TO RELIEF NOZZLE	B3.110		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**PL-3.0-CSCL-4-DCC**
006960	6"-2-RC-27	B-D	UT	1	-	-	-	C	-	-	-	-	-	-	
	UPPER HEAD TO RELIEF NOZZLE	B3.110		2	-	-	-	C	-	-	-	-	-	-	
	PRESS. DH			3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**PL-3.0-CSCL-4-DCC**

PRESSURIZER

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	NOZZLE TO SHELL AND SHELL TO NOZZLE WELDS (FIG NO A-4)													
006970	14"-2-RC-21	B-D	MT	1	-	-	C	-	-	-	C	-	-	CODE RELIEF GRANTED FIRST
	SURGE NOZZLE TO LOWER HEAD	B2.2	UT	2	-	-	-	-	-	-	-	X	-	INTERVAL FROM PERFORMING UT
	CONT. PRT			3	X	-	-	-	-	-	-	-	-	EXAMINATION FROM NOZZLE SIDE
				4	-	-	-	-	-	-	-	-	-	PROVIDED THAT (1) A FULL VEE
														VOLUMETRIC EXAMINATION IS
														PERFORMED FROM THE VESSEL SIDE
														WHEN ACCESS
														PL-3.0-CSCL-4-DCC
	NOZZLE INSIDE RADIUS SECTIONS (FIG NO A-4)													
007000	4"-2-RC-28-IRS	B-D	UT	1	-	-	-	-	-	-	C	-	-	
	UPPER HEAD TO SPRAY NOZZLE	B3.120		2	-	-	-	-	-	-	C	-	-	
	PRESS. DH			3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**IR-CSCL-24-DCC**
007100	6"-2-RC-22-IRS	B-D	UT	1	-	-	C	-	-	-	-	-	-	
	UPPER HEAD TO RELIEF NOZZLE	B3.120		2	-	-	C	-	-	-	-	-	-	
	PRESS. DH			3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**CSCL-24-DCC/CS-33-DCC**
007200	6"-2-RC-25-IRS	B-D	UT	1	C	-	-	-	-	-	-	-	-	
	UPPER HEAD TO RELIEF NOZZLE	B3.120		2	-	-	C	-	-	-	-	-	-	
	PRESS. DH			3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**CSCL-24-DCC/CS-33-DCC**
007300	6"-2-RC-26-IRS	B-D	UT	1	C	-	-	-	-	-	-	-	-	
	UPPER HEAD TO RELIEF NOZZLE	B3.120		2	-	-	C	-	-	-	-	-	-	
	PRESS. DH			3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**CSCL-24-DCC/CS-33-DCC**
007400	6"-2-RC-27-IRS	B-D	UT	1	-	-	C	-	-	-	-	-	-	
	UPPER HEAD TO RELIEF NOZZLE	B3.120		2	-	-	C	-	-	-	-	-	-	
	PRESS. DH			3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**CSCL-24-DCC/CS-33-DCC**

PRESSURIZER

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	NOZZLE INSIDE RADIUS SECTIONS (FIG NO A-4)														
007500	14"-2-RC-21-IRS	B-D	UT	1	-	-	-	-	-	-	-	C	-	-	
	SURGE NOZZLE TO LOWER HEAD	B3.120		2	-	-	-	-	-	-	-	-	X	-	
	CONT. PRT			3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**IR-CS-33-DCC**
	HEATER CONNECTIONS/INSTRUMENT AND SAMPLE PENETRATI (FIG NO A-5)														
007600	PRZ HEATER WELL PENETRATIONS	B-E	VT-2	1	-	C	-	C	-	-	-	C	-	-	EXAMINE ALL WELDS DURING
	78 PENETRATIONS	B4.20		2	-	-	-	-	-	-	-	-	X	-	SYSTEM LEAKAGE TEST PER
	CONT. PRT			3	-	-	-	-	-	-	-	-	X	-	CC-N-498-1.
				4	-	-	-	-	-	-	-	-	-	-	
007700	PRZ INSTRUMENT AND SAMPLE NOZZ	B-E	VT-2	1	-	C	-	C	-	-	-	C	-	-	EXAMINE 25% (3 WELDS) DURING
	9 PENETRATIONS	B4.13		2	-	-	-	-	-	-	-	-	X	-	SYSTEM LEAKAGE TEST PER
	CONT. PRT			3	-	-	-	-	-	-	-	-	X	-	CC-N-498-1.
				4	-	-	-	-	-	-	-	-	-	-	
	NOZZLE TO SAFE-END AND SAFE-END TO NOZZLE WELDS (FIG NO A-4)														
008000	2-PRZ-21	B-F	PT	1	-	-	-	-	-	-	-	C	-	-	AUGMENTED UT EXAMINATION
	NOZZLE TO SAFE-END	B5.40	UT	2	-	-	-	-	-	-	-	C	-	-	REQUIRED USING 45 DEG.
	PRESS. DH			3	-	-	-	-	-	-	-	X	-	-	REFRACTED LONGITUDINAL WAVE
				4	-	-	-	-	-	-	-	-	-	-	PER NRC I.N. 90-30.
															3378028 (6-SS-160-.71)
008100	2-PRZ-22	B-F	PT	1	C	-	-	-	-	-	-	-	-	-	AUGMENTED UT EXAMINATION
	NOZZLE TO SAFE-END	B5.40	UT	2	C	-	-	-	-	-	-	-	-	-	REQUIRED USING 45 DEG.
				3	X	-	-	-	-	-	-	-	-	-	REFRACTED LONGITUDINAL WAVE
				4	-	-	-	-	-	-	-	-	-	-	PER NRC I.N. 90-30.
															3378028 (6-SS-160-.71)
008200	2-PRZ-23	B-F	PT	1	C	-	-	-	-	-	-	-	-	-	AUGMENTED UT EXAMINATION
	NOZZLE TO SAFE-END	B5.40	UT	2	C	-	-	-	-	-	-	-	-	-	REQUIRED USING 45 DEG.
				3	X	-	-	-	-	-	-	-	-	-	REFRACTED LONGITUDINAL WAVE
				4	-	-	-	-	-	-	-	-	-	-	PER NRC I.N. 90-30.
															3378028 (6-SS-160-.71)

PRESSURIZER

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	NOZZLE TO SAFE-END AND SAFE-END TO NOZZLE WELDS (FIG NO A-4)													
008300	2-PRZ-24	B-F	PT	1 -	-	-	C	-	-	-	-	-	-	AUGMENTED UT EXAMINATION
	NOZZLE TO SAFE-END	B5.40	UT	2 -	-	-	C	-	-	-	-	-	-	REQUIRED USING 45 DEG.
	PRESS. DH			3 -	-	-	X	-	-	-	-	-	-	REFRACTED LONGITUDINAL WAVE
				4 -	-	-	-	-	-	-	-	-	-	PER NRC I.N. 90-30.
														3378028 (6-SS-160-.71)
008400	2-PRZ-25	B-F	PT	1 -	-	-	C	-	-	-	-	-	-	AUGMENTED UT EXAMINATION
	NOZZLE TO SAFE-END	B5.40	UT	2 -	-	-	C	-	-	-	-	-	-	REQUIRED USING 45 DEG.
	PRESS. DH			3 -	-	-	X	-	-	-	-	-	-	REFRACTED LONGITUDINAL WAVE
				4 -	-	-	-	-	-	-	-	-	-	NRC I.N. 90-30.
														3378028 (6-SS-160-.71)
008500	2-PRZ-26	B-F	PT	1 -	-	-	-	-	-	-	C	-	-	AUGMENTED UT EXAMINATION
	SAFE-END TO NOZZLE	B5.40	UT	2 -	-	-	-	-	-	-	-	X	-	REQUIRED USING 45 DEG.
	CONT. PRT			3 -	-	-	-	-	-	-	-	X	-	REFRACTED LONGITUDINAL WAVE
				4 -	-	-	-	-	-	-	-	-	-	PER NRC I.N. 90-30.
														3378032 (14-SS-160-1.40)
	LOWER HEAD TO SUPPORT SKIRT WELD (FIG NO A-4)													
008505	2-PRZ-20	B-H	MT	1 C	-	-	-	C	-	-	-	-	-	EXAMINE 100% OF WELD LENGTH.
	VESSEL SUPPORT	B8.20	UT	2 -	-	-	P	-	-	-	-	X	-	
	CONT., PRT			3 -	-	-	X	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**PL-1.5-CS-78**
	PRESSURE RETAINING BOLTING (2" AND LESS) (FIG NO A-4)													
008515	2-PRZ-MB 1 THROUGH 16	B-G-2	VT-1	1 -	C	-	C	-	-	-	C	-	-	MT EXAMINATION TO BE PERFORMED
	MANWAY BOLTING	B7.20	MT	2 C	-	-	-	-	-	-	-	-	-	IN ACCORDANCE WITH I.E.
				3 X	-	-	-	-	-	-	-	-	-	BULLETIN 82-02 IF BOLTING IS
				4 -	-	-	-	-	-	-	-	-	-	REMOVED.

STEAM GENERATOR NO. 21

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	CIRCUMFERENTIAL WELDS (FIG NO A-5)													
008600	STM-21-01	B-B	UT	1	-	-	C	-	-	-	-	-	-	
	LOWER HEAD TO TUBE SHEET	B2.40		2	-	-	-	C	-	-	-	X	-	
	CONT. L1			3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**MP-20-5-CSCL-47-DCC**
	NOZZLE INSIDE RADIUS SECTIONS (FIG NO A-6)													
008700	STM-21-I-IRS	B-D	UT	1	-	-	C	-	-	-	-	-	-	
	INLET NOZZLE INSIDE	B3.140		2	-	-	-	C	-	-	-	-	-	
	RADIUSSECTION			3	X	-	-	-	-	-	-	-	-	
	CONT. L1			4	-	-	-	-	-	-	-	-	-	**IR-CSCL-24-DCC**
008800	STM-21-O-IRS	B-D	UT	1	-	-	C	-	-	-	-	-	-	
	OUTLET NOZZLE INSIDE RADIUS	B3.140		2	-	-	-	C	-	-	-	-	-	
	SECTION			3	X	-	-	-	-	-	-	-	-	
	CONT. L1			4	-	-	-	-	-	-	-	-	-	**IR-CSCL-24-DCC**
	NOZZLE TO ELBOW AND ELBOW TO NOZZLE WELDS (FIG NO A-6)													
008900	STM-21-02	B-F	PT	1	-	-	C	-	-	-	-	-	-	FULL VOLUMETRIC UT EXAMINATION
	ELBOW TO INLET NOZZLE	B5.70	UT	2	-	-	-	C	-	-	-	-	-	REQUIRED DUE TO NRC
	CONT. L1			3	X	-	-	-	-	-	-	-	-	COMMITMENT.
				4	-	-	-	-	-	-	-	-	-	**CSS/CCS-MOCKUP-36-DCC**
009000	STM-21-03	B-F	PT	1	-	-	C	-	-	-	-	-	-	FULL VOLUMETRIC UT EXAMINATION
	OUTLET NOZZLE TO ELBOW	B5.70	UT	2	-	-	-	C	-	-	-	-	-	REQUIRED DUE TO NRC
	CONT. L1			3	X	-	-	-	-	-	-	-	-	COMMITMENT.
				4	-	-	-	-	-	-	-	-	-	**CSS/CCS-MOCKUP-36-DCC**
	PRESSURE RETAINING BOLTING (2" AND LESS) (FIG NO A-6)													
009420	STM-21-OMB-1 THROUGH 16	B-G-2	VT-1	1	C	-	-	C	-	-	-	-	-	PERFORM MT IN ACCORDANCE WITH
	OUTLET MANWAY BOLTING	B7.30	MT	2	C	-	-	-	-	-	-	-	-	I.E. BULLETIN 82-02 IF BOLTING
				3	X	-	-	-	-	-	-	-	-	IS REMOVED.
				4	-	-	-	-	-	-	-	-	-	

STEAM GENERATOR NO. 21

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	PRESSURE RETAINING BOLTING (2" AND LESS) (FIG NO A-6)														
009460	STM-21-IMB-1 THROUGH 16	B-G-2	VT-1	1	C	-	-	-	C	-	-	-	-	-	PERFORM MT IN ACCORDANCE WITH
	INLET MANWAY BOLTING	B7.30	MT	2	C	-	-	-	-	-	-	-	-	-	I.E. BULLETIN 82-02 IF BOLTING
				3	X	-	-	-	-	-	-	-	-	-	IS REMOVED.
				4	-	-	-	-	-	-	-	-	-	-	

STEAM GENERATOR NO. 22

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	CIRCUMFERENTIAL WELDS (FIG NO A-6)														
009500	STM-22-01	B-B	UT	1	-	C	-	-	-	-	-	-	-	-	
	LOWER HEAD TO TUBE SHEET	B2.40		2	-	-	-	C	-	-	-	-	X	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**MP-20-5-CSCL-47-DCC**
	NOZZLE INSIDE RADIUS SECTIONS (FIG NO A-6)														
009600	STM-22-I-IRS	B-D	UT	1	C	-	-	-	-	-	-	-	-	-	
	INLET NOZZLE INSIDE	B3.140		2	-	-	-	C	-	-	-	-	-	-	
	RADIUSSECTION			3	-	-	-	X	-	-	-	-	-	-	
	CONT. L2			4	-	-	-	-	-	-	-	-	-	-	**IR-CSCL-24-DCC**
009700	STM-22-O-IRS	B-D	UT	1	C	-	-	-	-	-	-	-	-	-	
	OUTLET NOZZLE INSIDE RADIUS	B3.140		2	-	-	-	C	-	-	-	-	-	-	
	SECTION			3	-	-	-	X	-	-	-	-	-	-	
	CONT. L2			4	-	-	-	-	-	-	-	-	-	-	**IR-CSCL-24-DCC**
	NOZZLE TO ELBOW AND ELBOW TO NOZZLE WELDS (FIG NO A-6)														
009800	STM-22-02	B-F	PT	1	C	-	-	-	-	-	-	-	-	-	FULL VOLUMETRIC UT EXAMINATION
	ELBOW TO INLET NOZZLE	B5.70	UT	2	-	-	-	P	C	-	-	-	-	-	REQUIRED DUE TO NRC
	CONT. L2			3	-	-	-	X	-	-	-	-	-	-	COMMITMENT.
				4	-	-	-	-	-	-	-	-	-	-	**CSS/CCS-MOCKUP-36-DCC**
009900	STM-22-03	B-F	PT	1	C	-	-	-	-	-	-	-	-	-	FULL VOLUMETRIC UT EXAMINATION
	OUTLET NOZZLE TO ELBOW	B5.70	UT	2	-	-	-	P	C	-	-	-	-	-	REQUIRED DUE TO NRC
	CONT. L2			3	-	-	-	X	-	-	-	-	-	-	COMMITMENT.
				4	-	-	-	-	-	-	-	-	-	-	**CSS/CCS-MOCKUP-36-DCC**
	PRESSURE RETAINING BOLTING (2" AND LESS) (FIG NO A-6)														
010320	STM-22-OMB-1 THROUGH 16	B-G-2	VT-1	1	-	-	-	C	C	-	-	-	-	-	PERFORM MT IN ACCORDANCE WITH
	OUTLET MANWAY BOLTING	B7.30	MT	2	C	-	-	-	-	-	-	-	-	-	I.E. BULLETIN 82-02 IF BOLTING
				3	-	-	-	X	-	-	-	-	-	-	IS REMOVED.
				4	-	-	-	-	-	-	-	-	-	-	

STEAM GENERATOR NO. 22

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				-	-	-	O	U	T	A G E	-	-	-	

PRESSURE RETAINING BOLTING (2" AND LESS) (FIG NO A-6)

010360	STM-22-IMB-1 THROUGH 16	B-G-2	VT-1	1	-	-	-	C	C	-	-	-	-	-	PERFORM MT IN ACCORDANCE WITH
	INLET MANWAY BOLTING	B7.30	MT	2	C	-	-	-	-	-	-	-	-	-	I.E. BULLETIN 82-02 IF BOLTING
				3	-	-	-	-	X	-	-	-	-	-	IS REMOVED.
				4	-	-	-	-	-	-	-	-	-	-	

STEAM GENERATOR NO. 23

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	CIRCUMFERENTIAL WELDS (FIG NO A-6)															
010400	STM-23-01	B-B	UT	1	-	-	-	-	-	-	-	C	-	-		
	LOWER HEAD TO TUBE SHEET	B2.40		2	-	-	-	C	-	-	-	-	X	-		
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-		**MP-20-5-CSCL-47-DCC**
	NOZZLE INSIDE RADIUS SECTIONS (FIG NO A-6)															
010500	STM-23-I-IRS	B-D	UT	1	-	-	-	-	-	-	-	C	-	-		
	INLET NOZZLE INSIDE,	B3.140		2	-	-	-	C	-	-	-	-	-	-		
	RADIUSSECTION			3	-	-	-	X	-	-	-	-	-	-		
	CONT. L3			4	-	-	-	-	-	-	-	-	-	-		**IR-CSCL-24-DCC**
010600	STM-23-O-IRS	B-D	UT	1	-	-	-	-	-	-	-	C	-	-		
	OUTLET NOZZLE INSIDE RADIUS	B3.140		2	-	-	-	C	-	-	-	-	-	-		
	SECTION			3	-	-	-	X	-	-	-	-	-	-		
	CONT. L3			4	-	-	-	-	-	-	-	-	-	-		**IR-CSCL-24-DCC**
	NOZZLE TO ELBOW AND ELBOW TO NOZZLE WELDS (FIG NO A-6)															
010700	STM-23-02	B-F	PT	1	-	-	-	-	-	-	-	C	-	-		FULL VOLUMETRIC UT EXAMINATION
	ELBOW TO INLET NOZZLE	B5.70	UT	2	-	-	-	P	C	-	-	-	-	-		REQUIRED DUE TO NRC
	CONT. L3			3	-	-	-	X	-	-	-	-	-	-		COMMITMENT.
				4	-	-	-	-	-	-	-	-	-	-		**CSS/CCS-MOCKUP-36-DCC**
010800	STM-23-03	B-F	PT	1	-	-	-	-	-	-	-	C	-	-		FULL VOLUMETRIC UT EXAMINATION
	OUTLET NOZZLE TO ELBOW	B5.70	UT	2	-	-	-	P	C	-	-	-	-	-		REQUIRED DUE TO NRC
	CONT. L3			3	-	-	-	X	-	-	-	-	-	-		COMMITMENT.
				4	-	-	-	-	-	-	-	-	-	-		**CSS/CCS-MOCKUP-36-DCC**
	PRESSURE RETAINING BOLTING (2" AND LESS) (FIG NO A-6)															
011220	STM-23-OMB-1 THROUGH 16	B-G-2	VT-1	1	-	-	-	C	C	-	-	-	-	-		PERFORM MT IN ACCORDANCE WITH
	OUTLET MANWAY BOLTING	B7.30	MT	2	C	-	-	-	-	-	-	-	-	-		I.E. BULLETIN 82-02 IF BOLTING
				3	-	-	-	X	-	-	-	-	-	-		IS REMOVED.
				4	-	-	-	-	-	-	-	-	-	-		

STEAM GENERATOR NO. 23

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	FIRST PERIOD 2	3	OUTAGE 1	SECOND PERIOD 2	3	OUTAGE 4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	PRESSURE RETAINING BOLTING (2" AND LESS) (FIG NO A-6)													
011260	STM-23-IMB-1 THROUGH 16	B-G-2	VT-1	1	-	-	-	C	C	-	-	-	-	PERFORM MT IN ACCORDANCE WITH
	INLET MANWAY BOLTING	B7.30	MT	2	C	-	-	-	-	-	-	-	-	I.E. BULLETIN 82-02 IF BOLTING
				3	-	-	-	X	-	-	-	-	-	IS REMOVED.
				4	-	-	-	-	-	-	-	-	-	

STEAM GENERATOR NO. 24

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	OUTAGE 1	OUTAGE 2	OUTAGE 3	OUTAGE 4	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	CIRCUMFERENTIAL WELDS (FIG NO A-6)													
011300	STM-24-01	B-B	UT	1	-	-	-	-	-	-	C	-	-	
	LOWER HEAD TO TUBE SHEET	B2.40		2	-	-	-	-	-	-	C	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**MP-20-F-CSCL-47-DCC**
	NOZZLE INSIDE RADIUS SECTIONS (FIG NO A-6)													
011400	STM-24-I-IRS	B-D	UT	1	-	-	-	-	-	-	C	-	-	
	INLET NOZZLE INSIDE	B3.140		2	-	-	-	-	-	-	-	X	-	
	RADIUSSECTION			3	-	-	-	-	-	-	-	X	-	
	CONT. L4			4	-	-	-	-	-	-	-	-	-	**IR-CSCL-24-DCC**
011500	STM-24-O-IRS	B-D	UT	1	-	-	-	-	-	-	C	-	-	
	OUTLET NOZZLE INSIDE RADIUS	B3.140		2	-	-	-	-	-	-	-	X	-	
	SECTION			3	-	-	-	-	-	-	-	X	-	
	CONT. L4			4	-	-	-	-	-	-	-	-	-	**IR-CSCL-24-DCC**
	NOZZLE TO ELBOW AND ELBOW TO NOZZLE WELDS (FIG NO A-6)													
011600	STM-24-02	B-F	PT	1	-	-	-	-	-	-	C	-	-	FULL VOLUMETRIC UT EXAMINATION
	ELBOW TO INLET NOZZLE	B5.70	UT	2	-	-	-	-	-	-	-	X	-	REQUIRED DUE TO NRC
	CONT. L4			3	-	-	-	-	-	-	-	X	-	COMMITMENT.
				4	-	-	-	-	-	-	-	-	-	**CSS/CCS-MOCKUP-36-DCC**
011700	STM-24-03	B-F	PT	1	-	-	-	-	-	-	C	-	-	FULL VOLUMETRIC UT EXAMINATION
	OUTLET NOZZLE TO ELBOW	B5.70	UT	2	-	-	-	-	-	-	-	X	-	REQUIRED DUE TO NRC
	CONT. L4			3	-	-	-	-	-	-	-	X	-	COMMITMENT.
				4	-	-	-	-	-	-	-	-	-	**CSS/CCS-MOCKUP-36-DCC**
	PRESSURE RETAINING BOLTING (2" AND LESS) (FIG NO A-6)													
012120	STM-24-OMB-1 THROUGH 16	B-G-2	VT-1	1	-	-	-	-	C	-	C	-	-	PERFORM MT IN ACCORDANCE WITH
	OUTLET MANWAY BOLTING	B7.30	MT	2	C	-	-	-	-	-	-	-	-	I.E. BULLETIN 82-02 IF BOLTING
				3	-	-	-	-	-	-	X	-	-	IS REMOVED.
				4	-	-	-	-	-	-	-	-	-	

STEAM GENERATOR NO. 24

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - -			O U T A G E				- - - - - -			
	PRESSURE RETAINING BOLTING (2" AND LESS) (FIG NO A-6)													
012160	STH-24-IMB-1 THROUGH 16	B-G-2	VT-1	1 -	-	-	-	C	-	-	C	-	-	PERFORM MT IN ACCORDANCE WITH
	INLET MANWAY BOLTING	B7.30	MT	2 C	-	-	-	-	-	-	-	-	-	I.E. BULLETIN 82-02 IF BOLTING
				3 -	-	-	-	-	-	-	X	-	-	IS REMOVED.
				4 -	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-17 (FIG NO A-7)													
013900	2-RC-17-01	B-J	PT	1 -	C	-	-	-	-	-	-	-	-	
	SAFE-END TO PIPE	B9.11	AUT	2 -	-	-	-	-	-	-	-	-	-	
	SNDBX L1HL			3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	**9-DCC/46-DCC**
014000	2-RC-17-01N	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	SCHEDULED PER CONDITION REPORT
	6-IN. NOZZLE (SET-ON BRANCH	B9.31	UT	2 -	-	-	-	-	-	-	-	X	-	95-0781.
	CONNECTION)			3 X	-	-	-	-	-	-	-	-	-	
	CONT. L1			4 -	-	-	-	-	-	-	-	-	-	**BC-6/27.5-29-SS-42-DCC**
014100	2-RC-17-02	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
014200	2-RC-17-02N	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	2-1/2-IN. NOZZLE (BRANCH	B9.32		2 -	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3 -	-	-	-	-	-	-	-	-	-	
	CONT. L1			4 -	-	-	-	-	-	-	-	-	-	
014300	2-RC-17-13	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	BRANCH CONNECTION TO	B9.21		2 -	-	-	-	-	-	-	-	-	-	
	TEMPERATURE ELEMENT			3 -	-	-	-	-	-	-	-	-	-	
	CONT. L1			4 -	-	-	-	-	-	-	-	-	-	
014400	2-RC-17-03	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT. L1			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
	LINE 2-RC-17 (FIG NO A-8)													
014700	2-RC-17-04	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	LBOW TO PIPE	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT. L1			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1 2 3	SECOND PERIOD 1 2 3 4 (OUTAGE)	THIRD PERIOD 1 2 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-17 (FIG NO A-8)							
014750	2-RC-17-05	B-J	PT	1	- - -	- - - -	- - -	
	PIPE TO ELBOW	B9.11	UT	2	- - -	- - - -	- - -	
	CONT. L1			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	**37-CCSS-X-3.0-9-DCC**
014760	2-RC-17-05-LD-I	B-J	PT	1	- - -	- - - -	- - -	
	LONGITUDINAL SEAM	B9.12	UT	2	- - -	- - - -	- - -	
	CONT. L1			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	**37-CCSS-X-3.0-9-DCC**
014770	2-RC-17-05-LD-O	B-J	PT	1	- - -	- - - -	- - -	
	LONGITUDINAL SEAM	B9.12	UT	2	- - -	- - - -	- - -	
	CONT. L1			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	**37-CCSS-X-3.0-9-DCC**
014780	2-RC-17-06-LU-I	B-J	PT	1	- - -	- - - -	- - -	
	LONGITUDINAL SEAM	B9.12	UT	2	- - -	- - - -	- - -	
	CONT. L1			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	**37-CCSS-X-3.0-9-DCC**
014790	2-RC-17-06-LU-O	B-J	PT	1	- - -	- - - -	- - -	
	LONGITUDINAL SEAM	B9.12	UT	2	- - -	- - - -	- - -	
	CONT. L1			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	**37-CCSS-X-3.0-9-DCC**
014800	2-RC-17-06	B-J	PT	1	- - -	- - - -	- - -	
	ELBOW TO PIPE	B9.11	UT	2	- - -	- - - -	- - -	
	CONT. L1			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	**37-CCSS-X-3.0-9-DCC**
014900	2-RC-17-03N	B-J	PT	1	C - -	- - - -	- - -	
	3-IN. NOZZLE (BRANCH	B9.32		2	- - -	- - - -	- - -	
	CONNECTION)			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RC-17 (FIG NO A-8)													
015000	2-RC-17-04N	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	2-IN. NOZZLE (BRANCH	B9.32		2 -	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3 -	-	-	-	-	-	-	-	-	-	
	CONT. L1			4 -	-	-	-	-	-	-	-	-	-	
015100	2-RC-17-07	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT. L1			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
015120	2-RC-17-07-LD-I	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT. L1			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
015140	2-RC-17-07-LD-O	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT. L1			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
015160	2-RC-17-08-LU-I	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT. L1			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
015180	2-RC-17-08-LU-O	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT. L1			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
015200	2-RC-17-08	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PUMP	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT. L1			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-17 (FIG NO A-9)													
015300	2-RC-17-09	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PUMP TO PIPE	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT. L1			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
015400	2-RC-17-05N	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	2-IN. NOZZLE (BRANCH	B9.32		2 -	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3 -	-	-	-	-	-	-	-	-	-	
	CONT. L1			4 -	-	-	-	-	-	-	-	-	-	
015500	2-RC-17-06N	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	3-IN. NOZZLE (BRANCH	B9.32		2 -	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3 -	-	-	-	-	-	-	-	-	-	
	CONT. L1			4 -	-	-	-	-	-	-	-	-	-	
015600	2-RC-17-07N	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	2-1/2-IN. NOZZLE (BRANCH	B9.32		2 -	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3 -	-	-	-	-	-	-	-	-	-	
	CONT. L1			4 -	-	-	-	-	-	-	-	-	-	
015700	2-RC-17-14	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	BRANCH CONNECTION TO	B9.21		2 -	-	-	-	-	-	-	-	-	-	
	TEMPERATURE ELEMENT			3 -	-	-	-	-	-	-	-	-	-	
	CONT. L1			4 -	-	-	-	-	-	-	-	-	-	
015800	2-RC-17-08N	B-J	PT	1 C	-	-	-	C	-	-	-	-	-	SCHEDULED PER CONDITION REPORT
	10-IN. NOZZLE (SET-ON BRANCH	B9.31	UT	2 -	-	-	C	-	-	-	-	X	-	95-0781.
	CONNECTION)			3 -	-	-	X	-	-	-	-	-	-	
	CONT. L1			4 -	-	-	-	-	-	-	-	-	-	**BC-10/27.5-SS-43-DCC**
015900	2-RC-17-09N	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	1-1/2-IN. NOZZLE (BRANCH	B9.32		2 -	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3 -	-	-	-	-	-	-	-	-	-	
	CONT. L1			4 -	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-17 (FIG NO A-9)													
016000	2-RC-17-10	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT. L1			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
016100	2-RC-17-11	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT.L1			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
016200	2-RC-17-12	B-J	PT	1 -	-	-	-	-	-	-	C	-	-	
	ELBOW TO SAFE-END	B9.11	UT	2 -	-	-	-	-	-	-	-	X	-	
	SNDBX L1CL			3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	**9-DCC/46-DCC**
	LINE 2-RC-18 (FIG NO A-10)													
016500	2-RC-18-01	B-J	PT	1 -	C	-	-	-	-	-	-	-	-	
	SAFE-END TO PIPE	B9.11	AUT	2 -	-	-	-	-	-	-	-	-	-	
	SNDBX L2HL			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**9-DCC/46-DCC**
016600	2-RC-18-01N	B-J	PT	1 -	-	-	C	-	-	-	-	-	-	
	6-IN. NOZZLE (SET-ON BRANCH	B9.31	UT	2 -	-	-	-	C	-	-	-	-	-	
	CONNECTION)			3 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			4 -	-	-	-	-	-	-	-	-	-	**BC-6/27.5-29-SS-42-DCC**
016700	2-RC-18-02	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
016800	2-RC-18-02N	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	2-1/2-IN. NOZZLE (BRANCH	B9.32		2 -	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			4 -	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-18 (FIG NO A-10)													
016900	2-RC-18-13	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	BRANCH CONNECTION TO	B9.21		2 C	-	-	-	-	-	-	-	-	-	
	TEMPERATURE ELEMENT			3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
017000	2-RC-18-03N	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	SCHEDULED PER CONDITION REPORT
	14-IN. NOZZLE (SET-ON BRANCH	B9.31	UT	2 -	-	-	-	-	-	-	-	X	-	95-0781.
	CONNECTION)			3 -	-	-	-	X	-	-	-	-	-	
	CONT. L2			4 -	-	-	-	-	-	-	-	-	-	**BC-14/29-SS-44-DCC**
017100	2-RC-18-03	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
	LINE 2-RC-18 (FIG NO A-11)													
017400	2-RC-18-04	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
017500	2-RC-18-05	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
017520	2-RC-18-05-LD-I	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
017540	2-RC-18-05-LD-O	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-18 (FIG NO A-11)													
017560	2-RC-18-06-LU-I	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2	-	-	-	-	-	-	C	-	-	
	CONT. L2			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
017580	2-RC-18-06-LU-O	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2	-	-	-	-	-	-	C	-	-	
	CONT. L2			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
017600	2-RC-18-06	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	C	-	-	
	CONT. L2			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
017700	2-RC-18-04N	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	3-IN. NOZZLE (BRANCH	B9.32		2	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3	-	-	-	-	-	-	-	-	-	
	CONT. L2			4	-	-	-	-	-	-	-	-	-	
017800	2-RC-18-05N	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	2-IN. NOZZLE (BRANCH	B9.32		2	-	-	-	-	-	-	C	-	-	
	CONNECTION)			3	-	-	-	-	-	-	X	-	-	
	CONT. L2			4	-	-	-	-	-	-	-	-	-	
017900	2-RC-18-07	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
017920	2-RC-18-07-LD-I	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-18 (FIG NO A-11)													
017940	2-RC-18-07-LD-O	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
017960	2-RC-18-08-LU-I	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
017980	2-RC-18-08-LU-O	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
018000	2-RC-18-08	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PUMP	B9.11	UT	2 -	-	-	-	-	-	-	C	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
	LINE 2-RC-18 (FIG NO A-12)													
018100	2-RC-18-09	B-J	PT	1 -	-	-	C	-	-	-	-	-	-	
	PUMP TO PIPE	B9.11	UT	2 -	-	-	-	-	-	-	C	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
018200	2-RC-18-06N	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	2-IN. NOZZLE (BRANCH	B9.32		2 -	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			4 -	-	-	-	-	-	-	-	-	-	
018300	2-RC-18-07N	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	2-1/2-IN. NOZZLE (BRANCH	B9.32		2 -	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			4 -	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-18 (FIG NO A-12)														
018400	2-RC-18-14	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	BRANCH CONNECTION TO	B9.21		2	-	-	-	-	-	-	-	-	-	-	
	TEMPERATURE ELEMENT			3	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			4	-	-	-	-	-	-	-	-	-	-	
018500	2-RC-18-08N	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	10-IN. NOZZLE (SET-ON BRANCH	B9.31	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			4	-	-	-	-	-	-	-	-	-	-	**BC-10/27.5-SS-43-DCC**
018600	2-RC-18-09N	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	1-1/2-IN. NOZZLE (BRANCH	B9.32		2	-	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			4	-	-	-	-	-	-	-	-	-	-	
018700	2-RC-18-10	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
018800	2-RC-18-11	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
018900	2-RC-18-12	B-J	PT	1	-	-	-	-	-	-	-	C	-	-	
	ELBOW TO SAFE-END	B9.11	AUT	2	-	-	-	-	-	-	-	-	-	-	
	SNDBX L2CL			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**9-DCC/46-DCC**
	LINE 2-RC-19 (FIG NO A-13)														
019200	2-RC-19-01	B-J	PT	1	-	-	-	-	C	-	-	-	-	-	
	SAFE-END TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	X	-	
	SNDBX L3HL			3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	**29ID-SE-2.738-46-DCC**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-19 (FIG NO A-13)													
019300	2-RC-19-01N	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	2-1/2-IN. NOZZLE (BRANCH	B9.32		2 C	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
019400	2-RC-19-13	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	BRANCH CONNECTION TO	B9.21		2 -	-	-	-	-	-	-	-	-	-	
	TEMPERATURE ELEMENT			3 -	-	-	-	-	-	-	-	-	-	
	CONT. L3			4 -	-	-	-	-	-	-	-	-	-	
019500	2-RC-19-02N	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	6-IN. NOZZLE (SET-ON BRANCH	B9.31	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3 -	-	-	-	-	-	-	-	-	-	
	CONT. L3			4 -	-	-	-	-	-	-	-	-	-	**BC-6/27.5-29-SS-42-DCC**
019600	2-RC-19-02	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT. L3			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
019700	2-RC-19-03N	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	14-IN. NOZZLE (SET-ON BRANCH	B9.31	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3 -	-	-	-	-	-	-	-	-	-	
	CONT. L3			4 -	-	-	-	-	-	-	-	-	-	**BC-14/29-SS-44-DCC**
019800	2-RC-19-03	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT. L3			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
	LINE 2-RC-19 (FIG NO A-14)													
020100	2-RC-19-04	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT. L3			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-19 (FIG NO A-14)																
020200	2-RC-19-05	B-J	PT	1	-	-	C	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	C	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
020220	2-RC-19-05-LD-I	B-J	PT	1	-	-	C	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2	-	-	C	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
020240	2-RC-19-05-LD-O	B-J	PT	1	-	-	C	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2	-	-	C	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
020260	2-RC-19-06-LU-I	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
020280	2-RC-19-06-LU-O	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
020300	2-RC-19-06	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
020400	2-RC-19-04N	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	3-IN. NOZZLE (BRANCH	B9.32		2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			4	-	-	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-19 (FIG NO A-14)													
020500	2-RC-19-05N	B-J	PT	1	-	-	C	-	-	-	-	-	-	
	2-IN. NOZZLE (BRANCH	B9.32		2	-	-	C	-	-	-	-	-	-	
	CONNECTION)			3	-	-	X	-	-	-	-	-	-	
	CONT. L3			4	-	-	-	-	-	-	-	-	-	
020600	2-RC-19-07	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	C	-	-	
	CONT. L3			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
020620	2-RC-19-07-LD-I	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2	-	-	-	-	-	-	C	-	-	
	CONT. L3			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
020640	2-RC-19-07-LD-O	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2	-	-	-	-	-	-	C	-	-	
	CONT. L3			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
020660	2-RC-19-08-LU-I	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
020680	2-RC-19-08-LU-O	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
020700	2-RC-19-08	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PUMP	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-19 (FIG NO A-15)													
020800	2-RC-19-09	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PUMP TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
020900	2-RC-19-06N	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	2-IN. NOZZLE (BRANCH	B9.32		2	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3	-	-	-	-	-	-	-	-	-	
	CONT. L3			4	-	-	-	-	-	-	-	-	-	
021100	2-RC-19-07N	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	2-1/2-IN. NOZZLE (BRANCH	B9.32		2	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3	-	-	-	-	-	-	-	-	-	
	CONT. L3			4	-	-	-	-	-	-	-	-	-	
021150	2-RC-19-14	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	BRANCH CONNECTION TO	B9.21		2	-	-	-	-	-	-	-	-	-	
	TEMPERATURE ELEMENT			3	-	-	-	-	-	-	-	-	-	
	CONT. L3			4	-	-	-	-	-	-	-	-	-	
021200	2-RC-19-08N	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	10-IN. NOZZLE (SET-ON BRANCH	B9.31	UT	2	-	-	-	-	-	-	-	X	-	
	CONNECTION)			3	-	-	-	-	-	-	-	-	-	
	CONT. L3			4	-	-	-	-	-	-	-	-	-	**BC-10/27.5-SS-43-DCC**
021300	2-RC-19-09N	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	4-IN. NOZZLE (SET-ON BRANCH	B9.31	UT	2	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3	-	-	-	-	-	-	-	-	-	
	CONT. L3			4	-	-	-	-	-	-	-	-	-	**BC-4/27.5-SS-41-DCC**
021500	2-RC-19-10	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-19 (FIG NO A-15)																
021550	2-RC-19-10N	B-J	PT	1	-	-	-	-	-	-	C	-	-				
	1-1/2-IN. NOZZLE (BRANCH	B9.32		2	-	-	-	-	-	-	C	-	-				
	CONNECTION)			3	-	-	-	-	-	-	X	-	-				
	CONT. L3			4	-	-	-	-	-	-	-	-	-				
021600	2-RC-19-11	B-J	PT	1	-	-	-	-	-	-	-	-	-				
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-				
	CONT. L3			3	-	-	-	-	-	-	-	-	-				
				4	-	-	-	-	-	-	-	-	-				**37-CCSS-X-3.0-9-DCC**
021700	2-RC-19-12	B-J	PT	1	-	-	-	-	-	-	C	-	-				
	ELBOW TO SAFE-END	B9.11	AUT	2	-	-	-	-	-	-	-	-	-				
	SNDBX L3CL			3	-	-	-	-	-	-	-	-	-				
				4	-	-	-	-	-	-	-	-	-				**9-DCC/46-DCC**
	LINE 2-RC-20 (FIG NO A-16)																
022000	2-RC-20-01	B-J	PT	1	-	-	-	-	C	-	-	-	-				
	SAFE-END TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-				
	SNDBX L4HL			3	-	-	-	-	-	-	-	-	-				
				4	-	-	-	-	-	-	-	-	-				**9-DCC/46-DCC**
022100	2-RC-20-01N	B-J	PT	1	-	-	-	-	-	-	-	-	-				
	6-IN. NOZZLE (SET-ON BRANCH	B9.31	UT	2	-	-	-	-	-	-	-	-	-				
	CONNECTION)			3	-	-	-	-	-	-	-	-	-				
	CONT. L4			4	-	-	-	-	-	-	-	-	-				**BC-6/27.5-29-SS-42-DCC**
022400	2-RC-20-02	B-J	PT	1	-	-	-	-	-	-	-	-	-				
	PIPE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-				
	CONT. L4			3	-	-	-	-	-	-	-	-	-				
				4	-	-	-	-	-	-	-	-	-				**37-CCSS-X-3.0-9-DCC**
022450	2-RC-20-02N	B-J	PT	1	-	-	-	-	-	-	-	-	-				
	2-1/2-IN. NOZZLE (BRANCH	B9.32		2	-	-	-	-	-	-	-	-	-				
	CONNECTION)			3	-	-	-	-	-	-	-	-	-				
	CONT. L4			4	-	-	-	-	-	-	-	-	-				

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-20 (FIG NO A-16)													
022455	2-RC-20-13	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	BRANCH CONNECTION TO	B9.21		2	-	-	-	-	-	-	-	-	-	
	TEMPERATURE ELEMENT			3	-	-	-	-	-	-	-	-	-	
	CONT. L4			4	-	-	-	-	-	-	-	-	-	
022500	2-RC-20-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
	LINE 2-RC-20 (FIG NO A-17)													
022800	2-RC-20-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
022900	2-RC-20-05	B-J	PT	1	-	-	-	C	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	C	-	-	-	-	-	
	CONT. L4			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
022920	2-RC-20-05-LD-I	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2	-	-	-	C	-	-	-	-	-	
	CONT. L4			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
022940	2-RC-20-05-LD-O	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2	-	-	-	C	-	-	-	-	-	
	CONT. L4			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
022960	2-RC-20-06-LU-I	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1 (OUTAGE)	SECOND PERIOD 2 (OUTAGE)	SECOND PERIOD 3 (OUTAGE)	SECOND PERIOD 4 (OUTAGE)	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-20 (FIG NO A-17)													
022980	2-RC-20-06-LU-O	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
023000	2-RC-20-06	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
023100	2-RC-20-03N	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	3-IN. NOZZLE (BRANCH	B9.32		2	C	-	-	-	-	-	-	-	-	
	CONNECTION)			3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
023200	2-RC-20-04N	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	3-IN. NOZZLE (BRANCH	B9.32		2	C	-	-	-	-	-	-	-	-	
	CONNECTION)			3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
023300	2-RC-20-07	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
023320	2-RC-20-07-LD-I	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
023340	2-RC-20-07-LD-O	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-20 (FIG NO A-17)														
023360	2-RC-20-08-LU-I	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**37-CCS-X-3.0-9-DCC**
023380	2-RC-20-08-LU-O	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	LONGITUDINAL SEAM	B9.12	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
023400	2-RC-20-08	B-J	PT	1	-	-	-	-	-	-	-	C	-	-	
	ELBOW TO PUMP	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
	LINE 2-RC-20 (FIG NO A-18)														
023500	2-RC-20-09	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PUMP TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
023600	2-RC-20-05N	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	2-IN. NOZZLE (BRANCH	B9.32		2	-	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			4	-	-	-	-	-	-	-	-	-	-	
023700	2-RC-20-06N	B-J	PT	1	-	-	-	C	-	-	-	-	-	-	
	2-1/2-IN. NOZZLE (BRANCH	B9.32		2	-	-	-	C	-	-	-	-	-	-	
	CONNECTION)			3	-	-	-	X	-	-	-	-	-	-	
	CONT. L4			4	-	-	-	-	-	-	-	-	-	-	
023800	2-RC-20-14	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	BRANCH CONNECTION TO	B9.21		2	-	-	-	-	-	-	-	-	-	-	
	TEMPERATURE ELEMENT			3	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			4	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-20 (FIG NO A-18)													
023900	2-RC-20-07N	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	3-IN. NOZZLE (BRANCH	B9.32		2	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3	-	-	-	-	-	-	-	-	-	
	CONT. L4			4	-	-	-	-	-	-	-	-	-	
024000	2-RC-20-08N	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	10-IN. NOZZLE (SET-ON BRANCH	B9.31	UT	2	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3	-	-	-	-	-	-	-	-	-	
	CONT. L4			4	-	-	-	-	-	-	-	-	-	**BC-10/27.5-SS-43-DCC**
024100	2-RC-20-09N	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	4-IN. NOZZLE (SET-ON BRANCH	B9.31	UT	2	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3	-	-	-	-	-	-	-	-	-	
	CONT. L4			4	-	-	-	-	-	-	-	-	-	
024200	2-RC-20-10	B-J	PT	1	-	-	-	C	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2	-	-	-	C	-	-	-	-	-	
	CONT. L4			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
024300	2-RC-20-10N	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	1-1/2-IN. NOZZLE (BRANCH	B9.32		2	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3	-	-	-	-	-	-	-	-	-	
	CONT. L4			4	-	-	-	-	-	-	-	-	-	
024400	2-RC-20-11	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**37-CCSS-X-3.0-9-DCC**
024500	2-RC-20-12	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	ELBOW TO SAFE-END	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	SNDBX L4CL			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**9-DCC/46-DCC**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-21 (FIG NO A-19)																
024700	2-RC-21-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	BRANCH CONNECTION TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**
024820	2-RC-21-02	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**
024840	2-RC-21-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**
024850	2-RC-21-04	B-J	PT	1	-	-	-	C	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2	-	-	-	C	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**
024900	2-RC-21-05	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**
025000	2-RC-21-06	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**
025500	2-RC-21-07	B-F	PT	1	-	-	-	C	-	-	-	-	-	-	-	-	
	PIPE TO SAFE-END	B5.130	UT	2	-	-	-	C	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-22 (FIG NO A-20)													
025700	2-RC-22-01	B-J	PT	1	-	-	C	-	-	-	-	-	-	
	SAFE-END TO ELBOW	B9.11	UT	2	-	-	C	-	-	-	-	-	-	
	PRESS. DH			3	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
025800	2-RC-22-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
025900	2-RC-22-03	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
026000	2-RC-22-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
026100	2-RC-22-05	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
026200	2-RC-22-06	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	ELBOW TO REDUCER	B9.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
026300	2-RC-22-07	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	REDUCER TO PIPE	B9.11	UT	2	-	-	-	-	-	-	C	-	-	
	PRESS. DH			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-22 (FIG NO A-20)																
026350	2-RC-22-08	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
026400	2-RC-22-09	B-J	PT	1	-	-	-	C	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
026500	2-RC-22-10	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	X	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
026600	2-RC-22-11	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
026700	2-RC-22-12	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
026800	2-RC-22-13	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
026833	2-RC-22-01N	B-J	PT	1	-	-	-	-	-	-	-	-	-	C	-	-	
	3-IN. NOZZLE (BRANCH	B9.32		2	-	-	-	-	-	-	-	-	-	C	-	-	
	CONNECTION)			3	-	-	-	-	-	-	-	-	-	X	-	-	
	PRESS. DH			4	-	-	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD (OUTAGE 1 2 3)	SECOND PERIOD (OUTAGE 1 2 3 4)	THIRD PERIOD (OUTAGE 1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-22 (FIG NO A-20)						
026866	2-RC-22-14	B-J	PT	1 - - -	- - - -	- - -	
	PIPE TO REDUCER	B9.11	UT	2 - - -	- - - -	- - -	
	PRESS. DH			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378027 (4-SS-120-.430)**
026900	2-RC-22-15	B-J	PT	1 - - -	- - - -	- - -	
	REDUCER TO PIPE	B9.21		2 - - -	- - - -	- - -	
	PRESS. DH			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
026920	2-RC-22-16	B-J	PT	1 - - -	- - - -	- - -	
	PIPE TO PIPE	B9.21		2 - - -	- - - -	- - -	
	PRESS. DH			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
027000	2-RC-22-17	B-J	PT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	B9.21		2 - - -	- - - -	- - -	
	PRESS. DH			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
027100	2-RC-22-18	B-J	PT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	B9.21		2 - - -	- - - -	- - -	
	PRESS. DH			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
027200	2-RC-22-19	B-J	PT	1 - - -	- - - -	- - -	
	PIPE TO VALVE	B9.21		2 - - -	- - - -	- - -	
	PRESS. DH			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
027300	2-RC-22-20	B-J	PT	1 - - -	- - - -	- - -	
	VALVE TO PIPE	B9.21		2 - - -	- - - -	- - -	
	PRESS. DH			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
							OUTAGE							
	LINE 2-RC-22 (FIG NO A-20)													
027400	2-RC-22-21	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.21		2	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-23 (FIG NO A-21)													
027500	2-RC-23-01	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	TEE TO PIPE	B9.21		2	-	-	-	-	-	-	C	-	-	
	PRESS. DH			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	
027600	2-RC-23-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
027700	2-RC-23-03	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
027750	2-RC-23-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
027800	2-RC-23-05	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
027900	2-RC-23-06	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
							OUTAGE							
	LINE 2-RC-23 (FIG NO A-21)													
028000	2-RC-23-07	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.21		2	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
028100	2-RC-23-08	B-J	PT	1	-	-	-	C	-	-	-	-	-	
	VALVE TO PIPE	B9.21		2	-	-	-	C	-	-	-	-	-	
	PRESS. DH			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
028200	2-RC-23-09	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.21		2	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-24 (FIG NO A-22)													
028250	2-RC-24-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	BRANCH CONNECTION TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
028300	2-RC-24-02	B-J	PT	1	-	-	-	-	-	-	-	C	-	
	PIPE TO PIPE	B9.21		2	-	-	-	-	-	-	-	C	-	
	PRESS. DH			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	
028400	2-RC-24-03	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.21		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
028500	2-RC-24-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL ASME SEC. XI CATGY	ITEM NO	NDE METH	PLAN STATUS FIRST PERIOD 1	2	3	OUTAGE SECOND PERIOD 1	2	3	4	OUTAGE THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-24 (FIG NO A-22)														
028550	2-RC-24-05	B-J		PT	1	-	-	C	-	-	-	-	-	-	
	PIPE TO PIPE	B9.21			2	-	-	C	-	-	-	-	-	-	
	PRESS. DH				3	-	-	X	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	
028600	2-RC-24-06	B-J		PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.21			2	-	-	-	-	-	-	-	-	-	
	PRESS. DH				3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-25 (FIG NO A-23)														
028700	2-RC-25-01	B-J		PT	1	-	-	-	-	-	-	C	-	-	
	SAFE-END TO ELBOW	B9.11		UT	2	-	-	-	-	-	-	-	-	-	
	PRESS. DH				3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
028800	2-RC-25-02	B-J		PT	1	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	B9.11		UT	2	-	-	-	-	-	-	C	-	-	
	PRESS. DH				3	-	-	-	-	-	-	X	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
028900	2-RC-25-03	B-J		PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11		UT	2	-	-	-	-	-	-	-	-	-	
	PRESS. DH				3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
029000	2-RC-25-04	B-J		PT	1	C	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11		UT	2	C	-	-	-	-	-	-	-	-	
					3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
029100	2-RC-25-05	B-J		PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11		UT	2	-	-	-	-	-	-	-	-	-	
	PRESS. DH				3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-25 (FIG NO A-23)														
029200	2-RC-25-06	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
029300	2-RC-25-07	B-J	PT	1	-	-	-	C	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	C	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
029400	2-RC-25-08	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
029500	2-RC-25-08-FB	B-G-2	VT-1	1	C	-	-	-	-	-	-	-	-	-	
	FLANGE BOLTING	B7.50		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-26 (FIG NO A-24)														
029600	2-RC-26-01	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	
	SAFE-END TO ELBOW	B9.11	UT	2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
029700	2-RC-26-02	B-J	PT	1	-	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	C	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
029800	2-RC-26-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-26 (FIG NO A-24)													
029900	2-RC-26-04	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
030000	2-RC-26-05	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
030100	2-RC-26-06	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
030200	2-RC-26-07	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
030250	2-RC-26-08	B-J	PT	1 -	-	-	C	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2 -	-	-	C	-	-	-	-	-	-	
	PRESS. DH			3 -	-	-	X	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
030300	2-RC-26-09	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
030400	2-RC-26-09-FB	B-G-2	VT-1	1 -	-	-	C	-	-	-	-	-	-	
	FLANGE BOLTING	B7.50		2 -	-	-	C	-	-	-	-	-	-	
	PRESS. DH			3 -	-	-	X	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-27 (FIG NO A-25)													
030500	2-RC-27-01	B-J	PT	1	-	-	C	-	-	-	-	-	-	
	SAFE-END TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
030600	2-RC-27-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
030700	2-RC-27-03	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	C	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
030800	2-RC-27-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
030900	2-RC-27-05	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
031000	2-RC-27-06	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
031100	2-RC-27-07	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-27 (FIG NO A-25)													
031150	2-RC-27-08	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
031200	2-RC-27-09	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO FLANGE	B9.11	UT	2	-	-	-	-	-	-	C	-	-	
	PRESS. DH			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
031300	2-RC-27-09-FB	B-G-2	VT-1	1	-	-	-	-	-	-	C	-	-	
	FLANGE BOLTING	B7.50		2	-	-	-	-	-	-	C	-	-	
	PRESS. DH			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-28 (FIG NO A-26)													
031400	2-RC-28-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	BRANCH CONNECTION TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
031500	2-RC-28-02	B-J	PT	1	-	-	-	C	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	C	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
031600	2-RC-28-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
031700	2-RC-28-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	PLAN STATUS FIRST PERIOD 2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-28 (FIG NO A-26)														
031800	2-RC-28-05	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
031900	2-RC-28-06	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
032000	2-RC-28-07	B-J	PT	1	-	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	C	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
032100	2-RC-28-08	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
032500	2-RC-28-09	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
032600	2-RC-28-10	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
032700	2-RC-28-11	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-28 (FIG NO A-26)														
032800	2-RC-28-12	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
032900	2-RC-28-13	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
033000	2-RC-28-14	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
033100	2-RC-28-15	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
033200	2-RC-28-16	B-J	PT	1	-	-	-	C	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	C	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
033300	2-RC-28-17	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
033800	2-RC-28-18	B-J	PT	1	-	-	-	-	-	-	-	C	-	-	
	PIPE TO TEE	B9.11	UT	2	-	-	-	-	-	-	-	C	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-RC-28 (FIG NO A-26)														
033900	2-RC-28-19	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
034000	2-RC-28-20	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
034100	2-RC-28-21	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
034200	2-RC-28-22	B-J	UT	1	C	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.11		2	C	-	-	C	C	-	-	C	X	-	
	CONT. PRT			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
	LINE 2-RC-28 (FIG NO A-27)														
034300	2-RC-28-23	B-J	UT	1	-	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.11		2	-	-	-	C	C	-	-	C	X	-	
	CONT. PRT			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
034400	2-RC-28-24	B-J	UT	1	C	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11		2	C	-	-	C	C	-	-	C	X	-	
	CONT. PRT			3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-28 (FIG NO A-27)													
034500	2-RC-28-25	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
034600	2-RC-28-26	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
034700	2-RC-28-27	B-J	PT	1	-	-	-	C	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	C	-	-	-	-	-	
	CONT. PRT			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
034800	2-RC-28-28	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	C	-	-	
	CONT. PRT			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
034900	2-RC-28-29	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
035300	2-RC-28-30	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
035400	2-RC-28-31	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-28 (FIG NO A-27)													
035500	2-RC-28-32	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
035600	2-RC-28-33	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
036100	2-RC-28-34	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	PRESS.			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
036200	2-RC-28-35	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	PRESS.			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
036300	2-RC-28-36	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	PRESS.			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
036400	2-RC-28-37	B-J	PT	1	-	-	-	C	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	C	-	-	-	-	-	
	PRESS.			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
036500	2-RC-28-38	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	PRESS.			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-28 (FIG NO A-27)														
036600	2-RC-28-39	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	PRESS.			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
036700	2-RC-28-40	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	PRESS.			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
036800	2-RC-28-41	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	PRESS.			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
036900	2-RC-28-42	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	PRESS.			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
037000	2-RC-28-43	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	PRESS.			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
037100	2-RC-28-44	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	PRESS.			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
037200	2-RC-28-45	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	PRESS.			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-28 (FIG NO A-27)													
037300	2-RC-28-46	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	PRESS.			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
037350	2-RC-28-47	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	PRESS.			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
037400	2-RC-28-48	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
037600	2-RC-28-49	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
037700	2-RC-28-50	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
037800	2-RC-28-51	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	ELBOW TO SAFE-END	B9.11	UT	2	-	-	-	-	-	-	C	-	-	
	PRESS. DH			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
	LINE 2-RC-29 (FIG NO A-28)													
037900	2-RC-29-01	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	BRANCH CONNECTION TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	C	-	-	
	CONT. L4			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-29 (FIG NO A-28)													
038000	2-RC-29-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
038100	2-RC-29-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
038200	2-RC-29-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
038300	2-RC-29-05	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
038400	2-RC-29-06	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
038500	2-RC-29-07	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
038600	2-RC-29-08	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-29 (FIG NO A-28)													
038700	2-RC-29-09	B-J	PT	1	-	-	C	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	C	-	-	-	-	-	-	
	CONT. PRT			3	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
038800	2-RC-29-10	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
039100	2-RC-29-11	B-J	PT	1	-	-	C	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	C	-	-	-	-	-	-	
	CONT. PRT			3	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
039200	2-RC-29-12	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
039400	2-RC-29-13	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
039500	2-RC-29-14	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
039600	2-RC-29-15	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-29 (FIG NO A-28)														
039700	2-RC-29-16	B-J	PT	1	-	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	C	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
039800	2-RC-29-17	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
039900	2-RC-29-18	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
040000	2-RC-29-19	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
040100	2-RC-29-20	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
	LINE 2-RC-30 (FIG NO A-29)														
040200	2-RC-30-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
040300	2-RC-30-01N	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	
	2-IN. NOZZLE (BRANCH	B9.32		2	C	-	-	-	-	-	-	-	-	-	
	CONNECTION)			3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-30 (FIG NO A-29)													
040700	2-RC-30-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
040800	2-RC-30-03	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
040900	2-RC-30-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
041000	2-RC-30-05	B-J	PT	1	-	-	-	C	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
041050	2-RC-30-05-PB	---	UT	1	-	-	-	-	-	-	-	-	-	
	PIPE BEND	---		2	C	-	-	-	-	-	-	-	-	
	CONT. PRT			3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
041300	2-RC-30-06	B-J	UT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.11		2	C	-	-	C	C	-	-	C	X	-
	CONT. PRT			3	-	-	-	-	-	-	-	X	-	-
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
	LINE 2-RC-31 (FIG NO A-30)													
041400	2-RC-31-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-31 (FIG NO A-30)														
041500	2-RC-31-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
041600	2-RC-31-03	B-J	PT	1	-	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	B9.21		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
042100	2-RC-31-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.21		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
044200	2-RC-31-05	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
044400	2-RC-31-06	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
044500	2-RC-31-07	B-J	PT	1	-	-	-	C	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
044800	2-RC-31-08	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.21		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RC-31 (FIG NO A-30)													
044900	2-RC-31-09	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
045000	2-RC-31-10	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
045100	2-RC-31-11	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-31 (FIG NO A-31)													
045200	2-RC-31-12	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
045300	2-RC-31-13	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
045400	2-RC-31-14	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
045500	2-RC-31-15	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-31 (FIG NO A-31)														
045600	2-RC-31-16	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	B9.21		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
045700	2-RC-31-16-FB	B-G-2	VT-1	1	C	-	-	-	-	-	-	-	-	-	
	FLANGE BOLTING	B7.50		2	-	-	-	-	-	-	-	C	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
045800	2-RC-31-17	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	FLANGE TO PIPE	B9.21		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
045900	2-RC-31-18	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
046000	2-RC-31-19	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
046100	2-RC-31-20	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
046200	2-RC-31-21	B-J	PT	1	-	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-31 (FIG NO A-31)													
046600	2-RC-31-22	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	B9.21		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
046700	2-RC-31-23	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
046800	2-RC-31-24	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	B9.21		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
046900	2-RC-31-25	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
047000	2-RC-31-26	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO BRANCH CONNECTION	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-32 (FIG NO A-32)													
047100	2-RC-32-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
047200	2-RC-32-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-32 (FIG NO A-32)													
047300	2-RC-32-03	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
047700	2-RC-32-04	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.21		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
047800	2-RC-32-05	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.21		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
048000	2-RC-32-06	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
048100	2-RC-32-07	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
048400	2-RC-32-08	B-J	PT	1 -	-	-	-	-	-	-	C	-	-	
	PIPE TO PIPE	B9.21		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
048500	2-RC-32-09	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO REDUCING TEE	B9.21		2 -	-	-	C	-	-	-	-	-	-	
	CONT. L2			3 -	-	-	X	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-32 (FIG NO A-32)													
048600	2-RC-32-10	B-J	PT	1	-	-	C	-	-	-	-	-	-	
	REDUCING TEE TO PIPE	B9.21		2	-	-	C	-	-	-	-	-	-	
	CONT. L2			3	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
048700	2-RC-32-11	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	C	-	-	-	-	-	-	
	CONT. L2			3	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-32 (FIG NO A-33)													
048800	2-RC-32-12	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	C	-	-	-	-	-	-	
	CONT. L2			3	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
048900	2-RC-32-13	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO FLANGE	B9.21		2	-	-	C	-	-	-	-	-	-	
	CONT. L2			3	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
049000	2-RC-32-13-FB	B-G-2	VT-1	1	-	-	C	-	-	-	-	-	-	
	FLANGE BOLTING	B7.50		2	-	-	C	-	-	-	-	-	-	
	CONT. L2			3	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
049100	2-RC-32-14	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	FLANGE TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
049200	2-RC-32-15	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-32 (FIG NO A-33)														
049300	2-RC-32-16	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
049600	2-RC-32-17	B-J	PT	1	-	-	-	C	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
049700	2-RC-32-18	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
049800	2-RC-32-19	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
049900	2-RC-32-20	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO,PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
050000	2-RC-32-21	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
050100	2-RC-32-22	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	B9.21		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RC-32 (FIG NO A-33)													
050200	2-RC-32-23	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
050300	2-RC-32-24	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
050600	2-RC-32-25	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO BRANCH CONNECTION	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-33 (FIG NO A-34)													
050700	2-RC-33-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
050800	2-RC-33-02	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	
050900	2-RC-33-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
051000	2-RC-33-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL ASME SEC. XI CATGY	ITEM NO	NDE METH	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-33 (FIG NO A-34)														
051100	2-RC-33-05	B-J		PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21			2	-	-	-	-	-	-	-	-	-	
	CONT. L3				3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	
051300	2-RC-33-06	B-J		PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.21			2	C	-	-	-	-	-	-	-	-	
					3	X	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	
051400	2-RC-33-07	B-J		PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21			2	-	-	-	-	-	-	-	-	-	
	CONT. L3				3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	
051500	2-RC-33-08	B-J		PT	1	-	-	-	C	-	-	-	-	-	
	ELBOW TO PIPE	B9.21			2	-	-	-	-	-	-	-	-	-	
	CONT. L3				3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	
051900	2-RC-33-09	B-J		PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.21			2	-	-	-	-	-	-	-	-	-	
	CONT. L3				3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	
052000	2-RC-33-10	B-J		PT	1	-	-	-	-	-	-	C	-	-	
	VALVE TO PIPE	B9.21			2	-	-	-	-	-	-	-	-	-	
	CONT. L3				3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	
052200	2-RC-33-11	B-J		PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21			2	-	-	-	-	-	-	-	-	-	
	CONT. L3				3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	

INSPECTION INTERVAL_ _____PLAN STATUS_____

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-33 (FIG NO A-34)													
052300	2-RC-33-12	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
052500	2-RC-33-13	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
052600	2-RC-33-14	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO REDUCING TEE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
052700	2-RC-33-15	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCING TEE TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
052800	2-RC-33-16	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-33 (FIG NO A-35)													
052900	2-RC-33-17	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
053000	2-RC-33-18	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	B9.21		2	-	-	-	C	-	-	-	-	-	
	CONT. L3			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-33 (FIG NO A-35)													
053100	2-RC-33-18-FB	B-G-2	VT-1	1	-	-	-	-	-	-	C	-	-	
	FLANGE BOLTING	B7.50		2	-	-	-	C	-	-	-	-	-	
	CONT. L3			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
053200	2-RC-33-19	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	FLANGE TO PIPE	B9.21		2	-	-	-	C	-	-	-	-	-	
	CONT. L3			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
053400	2-RC-33-20	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	C	-	-	-	-	-	
	CONT. L3			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
053500	2-RC-33-21	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	C	-	-	-	-	-	
	CONT. L3			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
053750	2-RC-33-22	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
053800	2-RC-33-23	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
053900	2-RC-33-24	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY	NDE ITEM NO	METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD (1 2 3)	SECOND PERIOD (1 2 3 4)	THIRD PERIOD (1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-33 (FIG NO A-35)							
054000	2-RC-33-25	B-J		PT	1 - - -	- - - -	- - -	
	PIPE TO VALVE	B9.21			2 - - -	- - - -	- - -	
	CONT. L3				3 - - -	- - - -	- - -	
					4 - - -	- - - -	- - -	
054100	2-RC-33-26	B-J		PT	1 - - -	- - - -	- - -	
	VALVE TO PIPE	B9.21			2 - - -	- - - -	- - -	
	CONT. L3				3 - - -	- - - -	- - -	
					4 - - -	- - - -	- - -	
054200	2-RC-33-27	B-J		PT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	B9.21			2 - - -	- - - -	- - -	
	CONT. L3				3 - - -	- - - -	- - -	
					4 - - -	- - - -	- - -	
054300	2-RC-33-28	B-J		PT	1 - - -	C - - -	- - -	
	ELBOW TO PIPE	B9.21			2 - - -	- - - -	- - -	
	CONT. L3				3 - - -	- - - -	- - -	
					4 - - -	- - - -	- - -	
054400	2-RC-33-29	B-J		PT	1 - - -	- - - -	- - -	
	PIPE TO BRANCH CONNECTION	B9.21			2 - - -	- - - -	- - -	
	CONT. L3				3 - - -	- - - -	- - -	
					4 - - -	- - - -	- - -	
	LINE 2-RC-34 (FIG NO A-36)							
054500	2-RC-34-01	B-J		PT	1 - - -	- - - -	- - -	
	REDUCER TO PIPE	B9.21			2 C - -	- - - -	- - -	
					3 X - -	- - - -	- - -	
					4 - - -	- - - -	- - -	
054600	2-RC-34-02	B-J		PT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	B9.21			2 C - -	- - - -	- - -	
					3 X - -	- - - -	- - -	
					4 - - -	- - - -	- - -	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RC-34 (FIG NO A-36)													
054700	2-RC-34-03	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	
055100	2-RC-34-04	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.21		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	
055200	2-RC-34-05	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.21		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	
055400	.2-RC-34-06	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	
055500	2-RC-34-07	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	
055700	2-RC-34-08	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO REDUCING TEE	B9.21		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L4			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
055800	2-RC-34-09	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	REDUCING TEE TO PIPE	B9.21		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L4			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-34 (FIG NO A-36)													
055900	2-RC-34-10	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-34 (FIG NO A-37)													
056000	2-RC-34-11	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
056100	2-RC-34-12	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
056200	2-RC-34-12-FB	B-G-2	VT-1	1	C	-	-	-	-	-	-	-	-	
	FLANGE BOLTING	B7.50		2	-	-	-	-	-	-	C	-	-	
	CONT. L4			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	
056300	2-RC-34-13	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	FLANGE TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
056500	2-RC-34-14	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
056600	2-RC-34-15	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-34 (FIG NO A-37)														
056700	2-RC-34-16	B-J	PT	1	-	-	C	-	-	-	-	-	-		
	PIPE TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-		
	CONT. L4			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
057000	2-RC-34-17	B-J	PT	1	-	-	-	-	-	-	C	-	-		
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-		
	CONT. L4			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
057100	2-RC-34-18	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-		
	CONT. L4			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
057200	2-RC-34-19	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	PIPE TO VALVE	B9.21		2	-	-	-	-	-	-	-	-	-		
	CONT. L4			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
057300	2-RC-34-20	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	VALVE TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-		
	CONT. L4			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
057400	2-RC-34-21	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-		
	CONT. L4			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
057500	2-RC-34-22	B-J	PT	1	C	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RC-34 (FIG NO A-37)													
057600	2-RC-34-23	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
057700	2-RC-34-24	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
057800	2-RC-34-25	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
057900	2-RC-34-26	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
058000	2-RC-34-27	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
058100	2-RC-34-28	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
058200	2-RC-34-29	B-J	PT	1	-	-	-	C	-	-	-	-	-	
	PIPE TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	X	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-34 (FIG NO A-37)																
058300	2-RC-34-30	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO BRANCH CONNECTION	B9.21		2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-512 (FIG NO A-38)																
058400	2-RC-512-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	BRANCH CONNECTION TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	X	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
058500	2-RC-512-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	X	-	
	CONT. L1			3	-	-	-	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
058600	2-RC-512-03	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	X	-	
	CONT. L1			3	-	-	-	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
058700	2-RC-512-04	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	X	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
058800	2-RC-512-05	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	X	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
058900	2-RC-512-06	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	X	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	PLAN STATUS FIRST PERIOD 2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-512 (FIG NO A-38)														
059000	2-RC-512-07	B-J	PT	1	-	-	C	-	-	-	-	-	-		
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	X	-		
	CONT. L1			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
059100	2-RC-512-08	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	X	-		
	CONT. L1			3	-	-	-	-	-	-	-	X	-		
				4	-	-	-	-	-	-	-	-	-		
059200	2-RC-512-09	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	X	-		
	CONT. L1			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
059300	2-RC-512-10	B-J	PT	1	-	-	-	-	-	-	C	-	-		
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	X	-		
	CONT. L1			3	-	-	-	-	-	-	-	X	-		
				4	-	-	-	-	-	-	-	-	-		
059400	2-RC-512-11	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	X	-		
	CONT. L1			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
059500	2-RC-512-12	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	X	-		
	CONT. L1			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
059600	2-RC-512-13	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-		
	CONT. L1			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-512 (FIG NO A-38)													
059700	2-RC-512-14	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
059800	2-RC-512-15	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
059900	2-RC-512-16	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
060000	2-RC-512-17	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
060100	2-RC-512-18	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
060200	2-RC-512-19	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO MANIFOLD	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
060300	2-RC-512-20	B-J	PT	1	-	-	-	C	-	-	-	-	-	
	MANIFOLD TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RC-512 (FIG NO A-38)													
060400	2-RC-512-21	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
060500	2-RC-512-22	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
060600	2-RC-512-23	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
060700	2-RC-512-24	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
060800	2-RC-512-25	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO TEE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
060900	2-RC-512-26	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
061000	2-RC-512-27	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD			INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-512 (FIG NO A-38)																
061100	2-RC-512-28	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-		
	PIPE TO FLANGE	B9.40		2	C	-	-	-	-	-	-	-	-	-	-		
				3	X	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
061200	2-RC-512-28-FB	B-G-2	VT-1	1	-	-	-	C	-	-	-	-	-	-	-		
	FLANGE BOLTING	B7.50		2	C	-	-	-	-	-	-	-	-	-	-		
				3	X	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
061300	2-RC-512-29	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-		
	FLANGE TO PIPE	B9.40		2	C	-	-	-	-	-	-	-	-	-	-		
				3	X	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
061400	2-RC-512-30	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	B9.40		2	C	-	-	-	-	-	-	-	-	-	-		
				3	X	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
061500	2-RC-512-31	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	B9.40		2	C	-	-	-	-	-	-	-	-	-	-		
				3	X	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
061600	2-RC-512-32	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	-		
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
061700	2-RC-512-33	B-J	PT	1	-	-	-	C	-	-	-	-	-	-	-		
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	-		
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-512 (FIG NO A-38)													
062100	2-RC-512-34	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
062200	2-RC-512-35	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
062300	2-RC-512-36	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L1			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
062400	2-RC-512-37	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
062500	2-RC-512-38	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
062600	2-RC-512-39	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
062700	2-RC-512-40	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO REDUCING TEE	B9.40		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L1			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD			INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-513 (FIG NO A-39)																
062800	2-RC-513-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	REDUCER TO ELBOW	B9.40		2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
062900	2-RC-513-02	B-J	PT	1	-	-	-	C	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
063000	2-RC-513-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO CROSS	B9.40		2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
063100	2-RC-513-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	CROSS TO REDUCER	B9.40		2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
063200	2-RC-513-05	B-J	PT	1	-	-	-	-	-	-	-	-	C	-	-	-	
	CROSS TO REDUCER	B9.40		2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
063300	2-RC-513-06	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	CROSS TO PIPE	B9.40		2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
063400	2-RC-513-07	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD	SECOND PERIOD (OUTAGE)	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-513 (FIG NO A-39)							
063500	2-RC-513-08	B-J	PT	1	C	- - - -	- - -	
	ELBOW TO PIPE	B9.40		2	-	- - - -	- - -	
				3	-	- - - -	- - -	
				4	-	- - - -	- - -	
063600	2-RC-513-09	B-J	PT	1	C	- - - -	- - -	
	PIPE TO VALVE	B9.40		2	-	- - - -	- - -	
				3	-	- - - -	- - -	
				4	-	- - - -	- - -	
063700	2-RC-513-10	B-J	PT	1	-	- - - -	- - -	
	VALVE TO PIPE	B9.40		2	-	- - - -	- - -	
	CONT. L1			3	-	- - - -	- - -	
				4	-	- - - -	- - -	
063800	2-RC-513-11	B-J	PT	1	-	- - - -	- - -	
	PIPE TO VALVE	B9.40		2	-	- - - -	- - -	
	CONT. L1			3	-	- - - -	- - -	
				4	-	- - - -	- - -	
063900	2-RC-513-12	B-J	PT	1	-	- - - -	- - -	
	VALVE TO PIPE	B9.40		2	-	- - - -	- - -	
	CONT. L1			3	-	- - - -	- - -	
				4	-	- - - -	- - -	
064000	2-RC-513-13	B-J	PT	1	C	- - - -	- - -	
	PIPE TO ELBOW	B9.40		2	-	- - - -	- - -	
				3	-	- - - -	- - -	
				4	-	- - - -	- - -	
064100	2-RC-513-14	B-J	PT	1	C	- - - -	- - -	
	ELBOW TO PIPE	B9.40		2	-	- - - -	- - -	
				3	-	- - - -	- - -	
				4	-	- - - -	- - -	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	PLAN STATUS FIRST PERIOD 1	SECOND PERIOD OUTAGE 2	SECOND PERIOD OUTAGE 3	SECOND PERIOD OUTAGE 4	THIRD PERIOD OUTAGE 1	THIRD PERIOD OUTAGE 2	THIRD PERIOD OUTAGE 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-513 (FIG NO A-39)											
064200	2-RC-513-15	B-J	PT	1	-	-	-	C	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	
064300	2-RC-513-16	B-J	PT	1	-	-	-	-	-	C	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	
064400	2-RC-513-17	B-J	PT	1	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.40		2	-	-	-	-	-	X	-	
	CONT. L1			3	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	
064500	2-RC-513-18	B-J	PT	1	C	-	-	-	-	-	-	
	TEE TO PIPE	B9.40		2	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	
064600	2-RC-513-19	B-J	PT	1	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	
064700	2-RC-513-20	B-J	PT	1	C	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	
064800	2-RC-513-21	B-J	PT	1	C	-	-	-	-	-	-	
	PIPE TO FLANGE	B9.40		2	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD (OUTAGE) 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-513 (FIG NO A-39)													
064900	2-RC-513-21-FB	B-G-2	VT-1	1	-	-	-	-	-	-	C	-	-	
	FLANGE BOLTING	B7.50		2	-	-	-	-	-	-	C	-	-	
	CONT. L1			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	
065000	2-RC-513-22	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.40		2	-	-	-	-	-	-	-	X	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
065100	2-RC-513-23	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO MANIFOLD	B9.40		2	-	-	-	-	-	-	-	X	-	
	CONT. L1			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	
065200	2-RC-513-24	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	MANIFOLD TO PIPE	B9.40		2	-	-	-	-	-	-	-	X	-	
	CONT. L1			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	
065300	2-RC-513-25	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	X	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
065400	2-RC-513-26	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	X	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
065500	2-RC-513-27	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO REDUCER	B9.21		2	-	-	-	-	-	-	-	X	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-514 (FIG NO A-40)														
065600	2-RC-514-01	B-J	PT	1	-	-	C	-	-	-	-	-	-	-	
	BRANCH CONNECTION TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
065700	2-RC-514-02	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
065800	2-RC-514-03	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
065900	2-RC-514-04	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
066000	2-RC-514-05	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
066100	2-RC-514-06	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
066200	2-RC-514-07	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-514 (FIG NO A-40)													
066300	2-RC-514-08	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
066400	2-RC-514-09	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
066500	2-RC-514-10	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
066600	2-RC-514-11	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
066700	2-RC-514-12	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
066800	2-RC-514-13	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
066900	2-RC-514-14	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RC-514 (FIG NO A-40)													
067000	2-RC-514-15	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
067100	2-RC-514-16	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.40		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
067200	2-RC-514-17	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	B9.40		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
067300	2-RC-514-18	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.40		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
067400	2-RC-514-19	B-J	PT	1 -	-	-	C	-	-	-	-	-	-	
	PIPE TO MANIFOLD	B9.40		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
067500	2-RC-514-20	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	MANIFOLD TO PIPE	B9.40		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
067600	2-RC-514-21	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3.	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-514 (FIG NO A-40)													
067700	2-RC-514-22	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
067800	2-RC-514-23	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
067900	2-RC-514-24	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	C	-	-	-	-	-	
	CONT. L2			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
068000	2-RC-514-25	B-J	PT	1	-	-	-	-	-	-	-	C	-	-
	PIPE TO ELBOW	B9.40		2	-	-	-	C	-	-	-	-	-	-
	CONT. L2			3	-	-	-	X	-	-	-	-	-	-
				4	-	-	-	-	-	-	-	-	-	-
068100	2-RC-514-26	B-J	PT	1	-	-	-	-	-	-	-	-	-	-
	ELBOW TO PIPE	B9.40		2	-	-	-	C	-	-	-	-	-	-
	CONT. L2			3	-	-	-	X	-	-	-	-	-	-
				4	-	-	-	-	-	-	-	-	-	-
068200	2-RC-514-27	B-J	PT	1	C	-	-	-	-	-	-	-	-	-
	PIPE TO FLANGE	B9.40		2	C	-	-	-	-	-	-	-	-	-
				3	X	-	-	-	-	-	-	-	-	-
				4	-	-	-	-	-	-	-	-	-	-
068300	2-RC-514-27-FB	B-G-2	VT-1	1	C	-	-	-	-	-	-	-	-	-
	FLANGE BOLTING	B7.50		2	C	-	-	-	-	-	-	-	-	-
				3	X	-	-	-	-	-	-	-	-	-
				4	-	-	-	-	-	-	-	-	-	-

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-514 (FIG NO A-40)													
068400	2-RC-514-28	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	FLANGE TO PIPE	B9.40		2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
068800	2-RC-514-29	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
068900	2-RC-514-30	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
069000	2-RC-514-31	B-J	PT	1 -	-	-	C	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
069100	2-RC-514-32	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
069200	2-RC-514-33	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
069300	2-RC-514-34	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD	SECOND PERIOD (OUTAGE)	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
				1 2 3	1 2 3 4	1 2 3	
	LINE 2-RC-514 (FIG NO A-40)						
069400	2-RC-514-35	B-J	PT	1 - - -	- - - -	C - -	
	PIPE TO REDUCING TEE	B9.40		2 C - -	- - - -	- - -	
				3 X - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
	LINE 2-RC-515 (FIG NO A-41)						
069500	2-RC-515-01	B-J	PT	1 - - -	- - - -	- - -	
	REDUCER TO ELBOW	B9.40		2 - - -	- - - -	- - -	
	CONT. L2			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
069600	2-RC-515-02	B-J	PT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	B9.40		2 - - -	- - - -	- - -	
	CONT. L2			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
069700	2-RC-515-03	B-J	PT	1 - - -	- - - -	- - -	
	PIPE TO CROSS	B9.40		2 - - -	- - - -	- - -	
	CONT. L2			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
069800	2-RC-515-04	B-J	PT	1 - - -	- - - -	- - -	
	CROSS TO REDUCER	B9.40		2 - - -	- - - -	- - -	
	CONT. L2			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
069900	2-RC-515-05	B-J	PT	1 - - -	- - - -	- - -	
	CROSS TO REDUCER	B9.40		2 - - -	- - - -	- - -	
	CONT. L2			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
070000	2-RC-515-06	B-J	PT	1 - - -	- - - -	- - -	
	CROSS TO PIPE	B9.40		2 - - -	- - - -	- - -	
	CONT. L2			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-515 (FIG NO A-41)														
070100	2-RC-515-07	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
070200	2-RC-515-08	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
070300	2-RC-515-09	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	C	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
070400	2-RC-515-10	B-J	PT	1	-	-	-	C	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	C	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
070500	2-RC-515-11	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	C	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
070600	2-RC-515-12	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	C	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
070700	2-RC-515-13	B-J	PT	1	-	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	C	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	PLAN STATUS FIRST PERIOD 2	3	OUTAGE 1	SECOND PERIOD 2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-515 (FIG NO A-41)													
070800	2-RC-515-14	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	C	-	-	-	-	-	
	CONT. L2			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
070900	2-RC-515-15	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
071000	2-RC-515-16	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
071100	2-RC-515-17	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
071200	2-RC-515-18	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
071300	2-RC-515-19	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
071400	2-RC-515-20	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD (OUTAGE) 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-515 (FIG NO A-41)													
071500	2-RC-515-21	B-J	PT	1	-	-	C	-	-	-	-	-	-	
	PIPE TO FLANGE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
071600	2-RC-515-21-FB	B-G-2	VT-1	1	-	-	C	-	-	-	-	-	-	
	FLANGE BOLTING	B7.50		2	-	-	C	-	-	-	-	-	-	
	CONT. L2			3	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
071700	2-RC-515-22	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
071800	2-RC-515-23	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO MANIFOLD	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
071900	2-RC-515-24	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	MANIFOLD TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
072000	2-RC-515-25	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
072100	2-RC-515-26	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RC-515 (FIG NO A-41)													
072200	2-RC-515-27	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO REDUCER	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-516 (FIG NO A-42)													
072300	2-RC-516-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	BRANCH CONNECTION TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
072400	2-RC-516-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
072500	2-RC-516-03	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
072600	2-RC-516-04	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
072700	2-RC-516-05	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
072800	2-RC-516-06	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL ASME SEC. XI CATGY ITEM NO	NDE METH	PLAN STATUS FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-516 (FIG NO A-42)														
072900	2-RC-516-07	B-J	PT	1	-	-	C	-	-	-	-	-	-		
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-		
	CONT. L3			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
073000	2-RC-516-08	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-		
	CONT. L3			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
073100	2-RC-516-09	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-		
	CONT. L3			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
073200	2-RC-516-10	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-		
	CONT. L3			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
073300	2-RC-516-11	B-J	PT	1	-	-	-	-	-	-	C	-	-		
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-		
	CONT. L3			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
073400	2-RC-516-12	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-		
	CONT. L3			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
073500	2-RC-516-13	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-		
	CONT. L3			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-RC-516 (FIG NO A-42)														
073600	2-RC-516-14	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
073700	2-RC-516-15	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
073800	2-RC-516-16	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.40		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
073900	2-RC-516-17	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	B9.40		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
074000	2-RC-516-18	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.40		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
074100	2-RC-516-19	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO MANIFOLD	B9.40		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
074200	2-RC-516-20	B-J	PT	1	-	-	-	C	-	-	-	-	-	-	
	MANIFOLD TO PIPE	B9.40		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RC-516 (FIG NO A-42)													
074300	2-RC-516-21	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
074400	2-RC-516-22	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
074500	2-RC-516-23	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
074600	2-RC-516-24	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
074700	2-RC-516-25	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
074800	2-RC-516-26	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
074900	2-RC-516-27	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-516 (FIG NO A-42)													
075000	2-RC-516-28	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
075100	2-RC-516-28-FB	B-G-2	VT-1	1	-	-	-	-	-	-	C	-	-	
	FLANGE BOLTING	B7.50		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
075200	2-RC-516-29	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	FLANGE TO PIPE	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
075600	2-RC-516-30	B-J	PT	1	-	-	-	C	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
075700	2-RC-516-31	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
075800	2-RC-516-32	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
075900	2-RC-516-33	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-516 (FIG NO A-42)																
076000	2-RC-516-34	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
076100	2-RC-516-35	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
076200	2-RC-516-36	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.21		2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-517 (FIG NO A-43)																
076300	2-RC-517-01	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	
	REDUCER TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
076400	2-RC-517-02	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
076500	2-RC-517-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	C	-	-	
	PIPE TO TEE	B9.40		2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
076600	2-RC-517-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	B9.40		2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
					1 2 3	1 2 3 4 (OUTAGE)	1 2 3	
	LINE 2-RC-517 (FIG NO A-43)							
076700	2-RC-517-05	B-J	PT	1	- - -	- - - -	- - -	
	TEE TO PIPE	B9.40		2	- - -	- - - -	- - -	
	CONT. L3			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
076800	2-RC-517-06	B-J	PT	1	C - -	- - - -	- - -	
	PIPE TO TEE	B9.40		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
076900	2-RC-517-07	B-J	PT	1	- - -	- - - -	- - -	
	TEE TO REDUCER	B9.40		2	- - -	- - - -	- - -	
	CONT. L3			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
077000	2-RC-517-08	B-J	PT	1	- - -	- - - -	- - -	
	TEE TO PIPE	B9.40		2	- - -	- - - -	- - -	
	CONT. L3			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
077100	2-RC-517-09	B-J	PT	1	- - -	C - - -	- - -	
	PIPE TO ELBOW	B9.40		2	- - -	- - - -	- - -	
	CONT. L3			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
077200	2-RC-517-10	B-J	PT	1	- - -	- - - -	- - -	
	ELBOW TO PIPE	B9.40		2	- - -	- - - -	- - -	
	CONT. L3			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
077300	2-RC-517-11	B-J	PT	1	- - -	- - - -	- - -	
	PIPE TO ELBOW	B9.40		2	- - -	- - - -	- - -	
	CONT. L3			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-517 (FIG NO A-43)																
077400	2-RC-517-12	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
077500	2-RC-517-13	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
077600	2-RC-517-14	B-J	PT	1	-	-	-	-	-	-	-	-	-	C	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
077700	2-RC-517-15	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	C	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
077800	2-RC-517-16	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	C	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
077900	2-RC-517-17	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	C	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
078000	2-RC-517-18	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	C	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD	SECOND PERIOD (OUTAGE)	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-517 (FIG NO A-43)							
078100	2-RC-517-19	B-J	PT	1	- - -	- - - -	- - -	
	PIPE TO TEE	B9.40		2	- - -	C - - -	- - -	
	CONT. L3			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
078200	2-RC-517-20	B-J	PT	1	C - -	- - - -	- - -	
	TEE TO PIPE	B9.40		2	- - -	C - - -	- - -	
	CONT. L3			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
078300	2-RC-517-21	B-J	PT	1	- - -	C - - -	- - -	
	PIPE TO VALVE	B9.40		2	- - -	C - - -	- - -	
	CONT. L3			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
078400	2-RC-517-22	B-J	PT	1	- - -	- - - -	- - -	
	VALVE TO PIPE	B9.40		2	- - -	C - - -	- - -	
	CONT. L3			3	- - -	X - - -	- - -	
				4	- - -	- - - -	- - -	
078500	2-RC-517-23	B-J	PT	1	- - -	- - - -	C - -	
	PIPE TO FLANGE	B9.40		2	- - -	C - - -	- - -	
	CONT. L3			3	- - -	X - - -	- - -	
				4	- - -	- - - -	- - -	
078600	2-RC-517-23-FB	B-G-2	VT-1	1	C - -	- - - -	- - -	
	FLANGE BOLTING	B7.50		2	- - -	C - - -	- - -	
	CONT. L3			3	- - -	X - - -	- - -	
				4	- - -	- - - -	- - -	
078700	2-RC-517-24	B-J	PT	1	C - -	- - - -	- - -	
	TEE TO PIPE	B9.40		2	- - -	C - - -	- - -	
	CONT. L3			3	- - -	X - - -	- - -	
				4	- - -	- - - -	- - -	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD			INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-517 (FIG NO A-43)																
078800	2-RC-517-25	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO MANIFOLD	B9.40		2	-	-	-	C	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
078900	2-RC-517-26	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	MANIFOLD TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
079000	2-RC-517-27	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
079100	2-RC-517-28	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
079200	2-RC-517-29	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO REDUCER	B9.21		2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-518 (FIG NO A-44)																
079300	2-RC-518-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	BRANCH CONNECTION TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
079400	2-RC-518-02	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	OUTAGE 1	OUTAGE 2	OUTAGE 3	OUTAGE 4	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-518 (FIG NO A-44)													
079500	2-RC-518-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
079600	2-RC-518-04	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
079700	2-RC-518-05	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
079800	2-RC-518-06	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
079900	2-RC-518-07	B-J	PT	1	-	-	-	C	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
080000	2-RC-518-08	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
080100	2-RC-518-09	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-518 (FIG NO A-44)																
080200	2-RC-518-10	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO COUPLING	B9.40		2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
080300	2-RC-518-11	B-J	PT	1	-	-	-	-	-	-	-	-	-	C	-	-	
	COUPLING TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
080400	2-RC-518-12	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
080500	2-RC-518-13	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
080600	2-RC-518-14	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
080700	2-RC-518-15	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	X	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
080800	2-RC-518-16	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	X	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-518 (FIG NO A-44)													
080900	2-RC-518-17	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	X	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
081000	2-RC-518-18	B-J	PT	1	-	-	-	C	-	-	-	-	-	
	PIPE TO TEE	B9.40		2	-	-	-	-	-	-	-	X	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
081100	2-RC-518-19	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	B9.40		2	-	-	-	-	-	-	-	X	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
081200	2-RC-518-20	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.40		2	-	-	-	-	-	-	-	X	-	
	CONT. L4			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	
081300	2-RC-518-21	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO MANIFOLD	B9.40		2	-	-	-	-	-	-	-	X	-	
	CONT. L4			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	
081400	2-RC-518-22	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	MANIFOLD TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
081500	2-RC-518-23	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-518 (FIG NO A-44)																
081600	2-RC-518-24	B-J	PT	1	-	-	-	-	-	-	-	C	-	-			
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-			
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-			
				4	-	-	-	-	-	-	-	-	-	-			
081700	2-RC-518-25	B-J	PT	1	-	-	-	-	-	-	-	-	-	-			
	PIPE TO TEE	B9.40		2	-	-	-	-	-	-	-	-	X	-			
	CONT. L4			3	-	-	-	-	-	-	-	-	X	-			
				4	-	-	-	-	-	-	-	-	-	-			
081800	2-RC-518-26	B-J	PT	1	-	-	-	-	-	-	-	-	-	-			
	TEE TO REDUCER	B9.40		2	-	-	-	-	-	-	-	-	X	-			
	CONT. L4			3	-	-	-	-	-	-	-	-	X	-			
				4	-	-	-	-	-	-	-	-	-	-			
081900	2-RC-518-27	B-J	PT	1	C	-	-	-	-	-	-	-	-	-			
	TEE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	X	-			
	CONT. L4			3	-	-	-	-	-	-	-	-	X	-			
				4	-	-	-	-	-	-	-	-	-	-			
082000	2-RC-518-28	B-J	PT	1	C	-	-	-	-	-	-	-	-	-			
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	X	-			
	CONT. L4			3	-	-	-	-	-	-	-	-	X	-			
				4	-	-	-	-	-	-	-	-	-	-			
082100	2-RC-518-29	B-J	PT	1	C	-	-	-	-	-	-	-	-	-			
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	X	-			
	CONT. L4			3	-	-	-	-	-	-	-	-	X	-			
				4	-	-	-	-	-	-	-	-	-	-			
082200	2-RC-518-30	B-J	PT	1	-	-	-	C	-	-	-	-	-	-			
	PIPE TO FLANGE	B9.40		2	-	-	-	-	-	-	-	-	X	-			
	CONT. L4			3	-	-	-	-	-	-	-	-	X	-			
				4	-	-	-	-	-	-	-	-	-	-			

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
				PLAN STATUS			OUTAGE							
	LINE 2-RC-518 (FIG NO A-44)													
082300	2-RC-518-30-FB	B-G-2	VT-1	1	-	-	C	-	-	-	-	-	-	
	FLANGE BOLTING	B7.50		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
082400	2-RC-518-31	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	FLANGE TO PIPE	B9.40		2	-	-	-	-	-	-	-	X	-	
	CONT. L4			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	
082500	2-RC-518-32	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
082600	2-RC-518-33	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
082700	2-RC-518-34	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
082800	2-RC-518-35	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
082900	2-RC-518-36	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RC-518 (FIG NO A-44)													
083000	2-RC-518-37	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
083100	2-RC-518-38	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO REDUCING TEE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-519 (FIG NO A-45)													
083200	2-RC-519-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
083300	2-RC-519-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
083400	2-RC-519-03	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO CROSS	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
083500	2-RC-519-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	CROSS TO REDUCER	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
083600	2-RC-519-05	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	CROSS TO REDUCER	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-519 (FIG NO A-45)													
083700	2-RC-519-06	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	CROSS TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
083800	2-RC-519-07	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
083900	2-RC-519-08	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
084000	2-RC-519-09	B-J	PT	1	-	-	-	C	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
084100	2-RC-519-10	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
084200	2-RC-519-11	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
084300	2-RC-519-12	B-J	PT	1	-	-	-	C	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-519 (FIG NO A-45)														
084400	2-RC-519-13	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
084500	2-RC-519-14	B-J	PT	1	-	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
084600	2-RC-519-15	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
084700	2-RC-519-16	B-J	PT	1	-	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
084800	2-RC-519-17	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.40		2	-	-	-	-	-	-	-	-	X	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	
084900	2-RC-519-18	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	X	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	
085000	2-RC-519-19	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	X	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD (OUTAGE) 1	SECOND PERIOD (OUTAGE) 2	SECOND PERIOD (OUTAGE) 3	SECOND PERIOD (OUTAGE) 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-519 (FIG NO A-45)													
085100	2-RC-519-20	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	X	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
085200	2-RC-519-21	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	B9.40		2	-	-	-	-	-	-	-	X	-	
	CONT. L4			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	
085300	2-RC-519-21-FB	B-G-2	VT-1	1	-	-	-	-	-	-	C	-	-	
	FLANGE BOLTING	B7.50		2	-	-	-	-	-	-	C	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	
085400	2-RC-519-22	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.40		2	-	-	-	-	-	-	-	X	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
085500	2-RC-519-23	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO MANIFOLD	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
085600	2-RC-519-24	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	MANIFOLD TO PIPE	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
085700	2-RC-519-25	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD (1 2 3)	SECOND PERIOD (1 2 3 4)	THIRD PERIOD (1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - - OUTAGE - - - - - -			
	LINE 2-RC-519 (FIG NO A-45)						
085800	2-RC-519-26	B-J	PT	1 - - -	C - - -	- - -	
	ELBOW TO PIPE	B9.40		2 C - -	- - - -	- - -	
				3 X - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
085900	2-RC-519-27	B-J	PT	1 - - -	C - - -	- - -	
	PIPE TO REDUCER	B9.21		2 C - -	- - - -	- - -	
				3 X - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
	LINE 2-RC-525 (FIG NO A-46)						
086000	2-RC-525-01	B-J	PT	1 - - -	- - - -	- - -	
	REDUCER TO TEE	B9.40		2 - - -	- - - -	- - -	
	CONT. PRT			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
086100	2-RC-525-02	B-J	PT	1 - - -	- - - -	- - -	
	TEE TO REDUCER	B9.40		2 - - -	- - - -	- - -	
	CONT. PRT			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
086200	2-RC-525-03	B-J	PT	1 - - -	- - - -	C - -	
	TEE TO PIPE	B9.40		2 - - -	- - - -	C - -	
	CONT. PRT			3 - - -	- - - -	X - -	
				4 - - -	- - - -	- - -	
086700	2-RC-525-04	B-J	PT	1 C - -	- - - -	- - -	
	PIPE TO ELBOW	B9.40		2 C - -	- - - -	- - -	
				3 X - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
086800	2-RC-525-05	B-J	PT	1 C - -	- - - -	- - -	
	ELBOW TO PIPE	B9.40		2 C - -	- - - -	- - -	
				3 X - -	- - - -	- - -	
				4 - - -	- - - -	- - -	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-525 (FIG NO A-46)														
086900	2-RC-525-06	B-J	PT	1	-	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	C	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
087000	2-RC-525-07	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
087100	2-RC-525-08	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
087200	2-RC-525-09	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
087300	2-RC-525-10	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
087400	2-RC-525-11	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
087500	2-RC-525-12	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	
	PIPE TO COUPLING	B9.40		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-525 (FIG NO A-46)														
087600	2-RC-525-13	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	COUPLING TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
087700	2-RC-525-14	B-J	PT	1	-	-	-	C	-	-	-	-	-	-	
	BRANCH CONNECTION TO PIPE	B9.40		2	-	-	-	C	-	-	-	-	-	-	
	CONT. PRT			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-56 (FIG NO A-47)													
087800	2-SI-56-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
087900	2-SI-56-02	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
088000	2-SI-56-02-PL 1 AND 2	B-K-1	PT	1	C	-	-	-	C	-	-	-	-	
	PIPE LUG	B10.10		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
088100	2-SI-56-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	C	-	-	-	-	-	
	ANNULUS			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
088200	2-SI-56-04	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	WELD INACCESSIBLE FOR
	PIPE TO COLLAR	B10.10		2	-	-	-	-	-	-	-	-	-	EXAMINATION DUE TO COLLAR
	CONT. L1			3	-	-	-	-	-	-	-	-	-	CONFIGURATION.
				4	-	-	-	-	-	-	-	-	-	
088250	2-SI-56-04FB	B-G-2	PT	1	-	-	-	-	-	-	-	-	-	
	FLANGE BOLTING	B7.50		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
088400	2-SI-56-05	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	
	COLLAR TO PIPE	B10.10		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-56 (FIG NO A-47)														
088500	2-SI-56-06	B-J	PT	1	-	-	C	-	-	-	-	-	-		
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-		
	CONT. L1			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**3378030 (10-SS-140-1.0)**
088600	2-SI-56-07	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-		
	CONT. L1			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**3378030 (10-SS-140-1.0)**
088700	2-SI-56-08	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-		
	CONT. L1			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**3378030 (10-SS-140-1.0)**
088800	2-SI-56-09	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-		
	CONT. L1			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**3378030 (10-SS-140-1.0)**
088900	2-SI-56-10	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-		
	CONT. L1			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**3378030 (10-SS-140-1.0)**
089000	2-SI-56-11	B-J	PT	1	-	-	-	-	-	-	C	-	-		
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	C	-	-		
	CONT. L1			3	-	-	-	-	-	-	X	-	-		
				4	-	-	-	-	-	-	-	-	-		**3378030 (10-SS-140-1.0)**
089100	2-SI-56-12	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-		
	CONT. L1			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**3378030 (10-SS-140-1.0)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-56 (FIG NO A-47)													
089200	2-SI-56-13	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
089300	2-SI-56-14	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
089400	2-SI-56-15	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
089500	2-SI-56-16	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
089600	2-SI-56-17	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
089700	2-SI-56-18	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO TEE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
089750	2-SI-56-19	B-J	PT	1	-	-	-	C	-	-	-	-	-	
	TEE TO PIPE	B9.11	UT	2	-	-	-	C	-	-	-	-	-	
	CONT. L1			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-56 (FIG NO A-47)														
089800	2-SI-56-20	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
089900	2-SI-56-21	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
090000	2-SI-56-22	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO BRANCH CONNECTION	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
	LINE 2-SI-78 (FIG NO A-47)														
090100	2-SI-78-01	B-J	PT	1	-	-	-	-	-	-	-	C	-	-	
	VALVE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	C	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
090200	2-SI-78-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
090300	2-SI-78-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
090400	2-SI-78-04	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	PLAN STATUS FIRST PERIOD 2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-78 (FIG NO A-47)														
090600	2-SI-78-05	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
090700	2-SI-78-06	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
090800	2-SI-78-07	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
090850	2-SI-78-08	B-J	PT	1	-	-	-	C	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2	-	-	-	C	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
090900	2-SI-78-09	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO REDUCER	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
	LINE 2-SI-57 (FIG NO A-48)														
091000	2-SI-57-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
091050	2-SI-57-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.11	UT	2	-	-	-	-	-	-	-	C	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS — FIRST PERIOD (OUTAGE 1 2 3)	SECOND PERIOD (OUTAGE 1 2 3 4)	THIRD PERIOD (OUTAGE 1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-57 (FIG NO A-48)						
091100	2-SI-57-03	B-J	PT	1 - - -	- - - -	- - -	
	TEE TO ELBOW	B9.11	UT	2 - - -	- - - -	- - -	
	ANNULUS			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378030 (10-SS-140-1.0)**
091300	2-SI-57-04	B-J	PT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	B9.11	UT	2 - - -	- - - -	- - -	
	ANNULUS			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378030 (10-SS-140-1.0)**
091400	2-SI-57-05	B-J	PT	1 - - -	- - - -	C - -	
	PIPE TO ELBOW	B9.11	UT	2 - - -	- - - -	- - -	
	ANNULUS			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378030 (10-SS-140-1.0)**
091500	2-SI-57-06	B-J	PT	1 - - -	- - - -	C - -	
	ELBOW TO PIPE	B9.11	UT	2 - - -	- - - -	C - -	
	ANNULUS			3 - - -	- - - -	X - -	
				4 - - -	- - - -	- - -	**3378030 (10-SS-140-1.0)**
091600	2-SI-57-07	B-K-1	PT	1 - - -	- - - -	- - -	WELD INACCESSIBLE FOR
	PIPE TO COLLAR	B10.10		2 - - -	- - - -	- - -	EXAMINATION DUE TO COLLAR
	CONT. L2			3 - - -	- - - -	- - -	CONFIGURATION.
				4 - - -	- - - -	- - -	
091650	2-SI-57-07FB	B-G-2	PT	1 - - -	- - - -	- - -	
	FLANGE BOLTING	B7.50		2 - - -	- - - -	- - -	
	CONT. L2			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
091800	2-SI-57-08	B-K-1	PT	1 - - -	- - - -	- - -	
	COLLAR TO PIPE	B10.10		2 - - -	- - - -	- - -	
	CONT. L2			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-57 (FIG NO A-48)													
091900	2-SI-57-09	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
092000	2-SI-57-10	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
092100	2-SI-57-11	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
092200	2-SI-57-12	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
092300	2-SI-57-13	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
092400	2-SI-57-14	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
092500	2-SI-57-15	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-57 (FIG NO A-48)														
092600	2-SI-57-16	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
092700	2-SI-57-17	B-J	PT	1	-	-	-	C	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	C	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
092800	2-SI-57-18	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
092900	2-SI-57-19	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
093000	2-SI-57-20	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	REDUCER TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
093100	2-SI-57-21	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO TEE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
093200	2-SI-57-22	B-J	PT	1	-	-	-	-	-	-	-	C	-	-	
	TEE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	C	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-57 (FIG NO A-48)													
093300	2-SI-57-23	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.11	UT	2	-	-	-	-	-	-	C	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
093400	2-SI-57-24	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
093500	2-SI-57-25	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	ELBOW TO BRANCH CONNECTION	B9.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
	LINE 2-SI-76 (FIG NO A-48)													
093600	2-SI-76-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
093700	2-SI-76-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
094000	2-SI-76-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
094100	2-SI-76-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-76 (FIG NO A-48)																
094300	2-SI-76-05	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
094400	2-SI-76-06	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO REDUCER	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
	LINE 2-SI-58 (FIG NO A-49)																
094500	2-SI-58-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
094600	2-SI-58-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
094700	2-SI-58-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	TEE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
094800	2-SI-58-03-PL 1 AND 2	B-K-1	PT	1	-	-	-	C	-	-	-	-	-	-	-	-	
	PIPE LUG	B10.10		2	-	-	-	C	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
094900	2-SI-58-04	B-J	PT	1	-	-	-	C	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	C	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-58 (FIG NO A-49)													
095100	2-SI-58-05	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	WELD INACCESSIBLE FOR
	PIPE TO COLLAR	B10.10		2	-	-	-	-	-	-	-	-	-	EXAMINATION DUE TO COLLAR
	CONT. L3			3	-	-	-	-	-	-	-	-	-	CONFIGURATION.
				4	-	-	-	-	-	-	-	-	-	
095300	2-SI-58-06	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	
	COLLAR TO PIPE	B10.10		2	-	-	-	-	-	-	-	X	-	
	CONT. L3			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	
095400	2-SI-58-07	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
095500	2-SI-58-08	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	C	-	-	
	CONT. L3			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
095600	2-SI-58-09	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
095700	2-SI-58-10	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
095800	2-SI-58-11	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-58 (FIG NO A-49)														
095900	2-SI-58-12	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
096000	2-SI-58-13	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
096100	2-SI-58-14	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
096200	2-SI-58-15	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
096300	2-SI-58-16	B-J	PT	1	-	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	C	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
096400	2-SI-58-17	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
096500	2-SI-58-18	B-J	PT	1	-	-	-	C	-	-	-	-	-	-	
	REDUCER TO ELBOW	B9.11	UT	2	-	-	-	C	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD (OUTAGE 1 2 3)	SECOND PERIOD (OUTAGE 1 2 3 4)	THIRD PERIOD (OUTAGE 1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-58 (FIG NO A-49)						
096600	2-SI-58-19	B-J	PT	1 - - -	- - - -	- - -	
	ELBOW TO TEE	B9.11	UT	2 - - -	- - - -	- - -	
	CONT. L3			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378030 (10-SS-140-1.0)**
096700	2-SI-58-20	B-J	PT	1 - - -	- - - -	- - -	
	TEE TO PIPE	B9.11	UT	2 - - -	- - - -	- - -	
	CONT. L3			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378030 (10-SS-140-1.0)**
096800	2-SI-58-21	B-J	PT	1 - - -	- - - -	- - -	
	PIPE TO VALVE	B9.11	UT	2 - - -	- - - -	- - -	
	CONT. L3			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378030 (10-SS-140-1.0)**
096900	2-SI-58-22	B-J	PT	1 - - -	- - - -	C - -	
	VALVE TO ELBOW	B9.11	UT	2 - - -	- - - -	- - -	
	CONT. L3			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378030 (10-SS-140-1.0)**
097000	2-SI-58-23	B-J	PT	1 - - -	- - - -	C - -	
	ELBOW TO BRANCH CONNECTION	B9.11	UT	2 - - -	- - - -	- - -	
	CONT. L3			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378030 (10-SS-140-1.0)**
	LINE 2-SI-77 (FIG NO A-49)						
097100	2-SI-77-01	B-J	PT	1 - - -	- - - -	- - -	
	VALVE TO ELBOW	B9.11	UT	2 - - -	- - - -	- - -	
	CONT. L3			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378028 (6-SS-160-.71)**
097200	2-SI-77-02	B-J	PT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	B9.11	UT	2 - - -	- - - -	- - -	
	CONT. L3			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378028 (6-SS-160-.71)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-SI-77 (FIG NO A-49)														
097300	2-SI-77-03	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
097400	2-SI-77-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
097600	2-SI-77-05	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
097700	2-SI-77-06	B-J	PT	1	-	-	-	C	-	-	-	-	-	-	
	PIPE TO REDUCER	B9.11	UT	2	-	-	-	C	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
	LINE 2-SI-59 (FIG NO A-50)														
097800	2-SI-59-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
097900	2-SI-59-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
098000	2-SI-59-02-PL 1 AND 2	B-K-1	PT	1	-	-	-	-	-	-	-	C	-	-	
	PIPE LUG	B10.10		2	-	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-59 (FIG NO A-50)													
098100	2-SI-59-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
098200	2-SI-59-04	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	WELD INACCESSIBLE FOR
	PIPE TO COLLAR	B10.10		2	-	-	-	-	-	-	-	-	-	EXAMINATION DUE TO COLLAR
	CONT. L4			3	-	-	-	-	-	-	-	-	-	CONFIGURATION.
				4	-	-	-	-	-	-	-	-	-	
098250	2-SI-59-04FB	B-G-2	VT-1	1	-	-	-	-	-	-	-	-	-	
	FLANGE BOLTING	B7.50		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
098400	2-SI-59-05	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	
	COLLAR TO PIPE	B10.10		2	-	-	-	-	-	-	C	-	-	
	CONT. L4			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	
098500	2-SI-59-06	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
098600	2-SI-59-07	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
098700	2-SI-59-08	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-59 (FIG NO A-50)														
098800	2-SI-59-09	B-J	PT	1	-	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	C	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
098900	2-SI-59-10	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
099000	2-SI-59-11	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
099100	2-SI-59-12	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
099200	2-SI-59-13	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
099300	2-SI-59-14	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
099400	2-SI-59-15	B-J	PT	1	-	-	-	C	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	C	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-59 (FIG NO A-50)													
099500	2-SI-59-16	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
099600	2-SI-59-17	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
099700	2-SI-59-18	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	C	-	-	
	CONT. L4			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
099800	2-SI-59-19	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
099900	2-SI-59-20	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO REDUCER	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
100000	2-SI-59-21	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO TEE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
100100	2-SI-59-22	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL ASME SEC. XI CATGY ITEM NO	NDE METH	PLAN STATUS FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-59 (FIG NO A-50)														
100200	2-SI-59-23	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
100300	2-SI-59-24	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
100400	2-SI-59-25	B-J	PT	1	-	-	-	C	-	-	-	-	-	-	
	ELBOW TO BRANCH CONNECTION	B9.11	UT	2	-	-	-	C	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
	LINE 2-SI-60 (FIG NO A-51)														
100500	2-SI-60-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
100600	2-SI-60-02	B-J	PT	1	-	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
100700	2-SI-60-02-PL 1 THROUGH 4	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE LUG	B10.10		2	-	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
101200	2-SI-60-02-PL 5 THROUGH 8	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE LUG	B10.10		2	-	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
							OUTAGE							
	LINE 2-SI-60 (FIG NO A-51)													
101600	2-SI-60-03	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
101700	2-SI-60-04	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
101800	2-SI-60-05	B-J	PT	1 -	-	-	C	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2 -	-	-	C	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	X	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
101900	2-SI-60-06	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2 -	-	-	-	-	-	-	C	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
102000	2-SI-60-07	B-J	PT	1 -	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	B9.11	UT	2 -	-	-	-	-	-	-	C	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
102100	2-SI-60-08	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO TEE	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
102200	2-SI-60-09	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-60 (FIG NO A-51)													
102300	2-SI-60-10	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	B9.11	UT	2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
102400	2-SI-60-11	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
102500	2-SI-60-12	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
102600	2-SI-60-13	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
102700	2-SI-60-14	B-J	PT	1 -	-	-	C	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2 -	-	-	C	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	X	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
	LINE 2-SI-60 (FIG NO A-52)													
102800	2-SI-60-15	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
102900	2-SI-60-16	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-60 (FIG NO A-52)													
102950	2-SI-60-17	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	C	-	-	
	ANNULUS			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
103000	2-SI-60-18	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	WELD INACCESSIBLE FOR
	PIPE TO COLLAR	B10.10		2	-	-	-	-	-	-	-	-	-	EXAMINATION DUE TO COLLAR
	CONT. L4			3	-	-	-	-	-	-	-	-	-	CONFIGURATION.
				4	-	-	-	-	-	-	-	-	-	
103020	2-SI-60-18FB	B-B-2	VT-1	1	-	-	-	-	-	-	-	-	-	
	FLANGE BOLTING	B7.50		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
103200	2-SI-60-19	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	
	COLLAR TO PIPE	B10.10		2	-	-	-	-	-	-	C	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
103233	2-SI-60-20	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
103266	2-SI-60-21	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
103300	2-SI-60-22	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-60 (FIG NO A-52)														
103400	2-SI-60-23	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
103500	2-SI-60-24	B-J	PT	1	-	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
103600	2-SI-60-25	B-J	PT	1	-	-	-	C	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	C	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
103700	2-SI-60-26	B-J	PT	1	-	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	C	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
103800	2-SI-60-27	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
103900	2-SI-60-28	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
104000	2-SI-60-29	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	C	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-60 (FIG NO A-52)													
104100	2-SI-60-30	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT. L4			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
104200	2-SI-60-31	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	CONT. L4			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
104300	2-SI-60-32	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	ELBOW TO BRANCH CONNECTION	B9.11	UT	2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
	LINE 2-SI-61 (FIG NO A-53)													
104400	2-SI-61-01	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
104500	2-SI-61-02	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
104600	2-SI-61-03	B-K-1	PT	1 -	-	-	-	-	-	-	-	-	-	WELD INACCESSIBLE FOR
	PIPE TO COLLAR	B10.10		2 -	-	-	-	-	-	-	-	-	-	EXAMINATION DUE TO COLLAR
	CONT. L1			3 -	-	-	-	-	-	-	-	-	-	CONFIGURATION.
				4 -	-	-	-	-	-	-	-	-	-	
104650	2-SI-61-03FB	B-G-2	VT-1	1 -	-	-	-	-	-	-	-	-	-	
	FLANGE BOLTING	B7.50		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-61 (FIG NO A-53)													
104800	2-SI-61-04	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	
	COLLAR TO PIPE	B10.10		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
104900	2-SI-61-05	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	C	-	-	
	CONT. L1			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
105000	2-SI-61-06	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
105100	2-SI-61-07	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
105200	2-SI-61-08	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	C	-	-	
	CONT. L1			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
105300	2-SI-61-09	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
105400	2-SI-61-10	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1 (OUTAGE)	SECOND PERIOD 2 (OUTAGE)	SECOND PERIOD 3 (OUTAGE)	SECOND PERIOD 4 (OUTAGE)	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-61 (FIG NO A-53)													
105500	2-SI-61-11	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
105600	2-SI-61-12	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	C	-	-	
	CONT. L1			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
105700	2-SI-61-13	B-J	PT	1	-	-	-	C	-	-	-	-	-	
	PIPE TO VALVE	B9.11	UT	2	-	-	-	C	-	-	-	-	-	
	CONT. L1			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
105800	2-SI-61-14	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
105900	2-SI-61-15	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO BRANCH CONNECTION	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
	LINE 2-SI-62 (FIG NO A-54)													
106000	2-SI-62-01	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	VALVE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
106100	2-SI-62-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-62 (FIG NO A-54)														
106200	2-SI-62-02-PL 1 THROUGH 4	B-K-1	PT	1	-	-	-	-	-	-	C	-	-		
	PIPE LUG	B10.10		2	-	-	-	-	-	-	C	-	-		
	ANNULUS			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
106700	2-SI-62-02-PL 5 THROUGH 8	B-K-1	PT	1	-	-	-	-	-	-	-	-	-		
	PIPE LUG	B10.10		2	-	-	-	-	-	-	C	-	-		
	ANNULUS			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
107100	2-SI-62-03	B-J	PT	1	C	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	B9.11	UT	2	C	-	-	-	-	-	-	-	-		
				3	X	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**3378029 (8-SS-140-.81)**
107200	2-SI-62-04	B-J	PT	1	-	-	-	C	-	-	-	-	-		
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	C	-	-	-	-	-		
	ANNULUS			3	-	-	-	X	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**3378029 (8-SS-140-.81)**
107300	2-SI-62-05	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	C	-	-		
	ANNULUS			3	-	-	-	-	-	-	X	-	-		
				4	-	-	-	-	-	-	-	-	-		**3378029 (8-SS-140-.81)**
107400	2-SI-62-06	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	ELBOW TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-		
	ANNULUS			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**3378029 (8-SS-140-.81)**
107500	2-SI-62-07	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-		
	ANNULUS			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**3378029 (8-SS-140-.81)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD OUTAGE 1	SECOND PERIOD OUTAGE 2	SECOND PERIOD OUTAGE 3	SECOND PERIOD OUTAGE 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-62 (FIG NO A-54)													
107700	2-SI-62-08	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
107800	2-SI-62-09	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO TEE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
107900	2-SI-62-10	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
108000	2-SI-62-11	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
108100	2-SI-62-12	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	C	-	-	
	ANNULUS			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
108200	2-SI-62-13	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
108300	2-SI-62-14	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-62 (FIG NO A-54)													
108400	2-SI-62-15	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
	LINE 2-SI-62 (FIG NO A-55)													
108500	2-SI-62-16	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
108600	2-SI-62-17	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
108700	2-SI-62-18	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	WELD INACCESSIBLE FOR
	PIPE TO COLLAR	B10.10		2	-	-	-	-	-	-	-	-	-	EXAMINATION DUE TO COLLAR
	CONT. L3			3	-	-	-	-	-	-	-	-	-	CONFIGURATION.
				4	-	-	-	-	-	-	-	-	-	
108750	2-SI-62-18FB	B-G-2	VT-1	1	-	-	-	-	-	-	-	-	-	
	FLANGE BOLTING	B7.50		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
108900	2-SI-62-19	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	
	COLLAR TO PIPE	B10.10		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
109000	2-SI-62-20	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL ASME SEC. XI CATGY ITEM NO	NDE METH	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-62 (FIG NO A-55)													
109100	2-SI-62-21	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
109200	2-SI-62-22	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
109300	2-SI-62-23	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
109400	2-SI-62-24	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
109500	2-SI-62-25	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
109600	2-SI-62-26	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
109700	2-SI-62-27	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-62 (FIG NO A-55)														
109800	2-SI-62-28	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
109900	2-SI-62-29	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
110000	2-SI-62-30	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
110100	2-SI-62-31	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
110200	2-SI-62-32	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO BRANCH CONNECTION	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
	LINE 2-SI-63 (FIG NO A-56)														
110300	2-SI-63-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
110400	2-SI-63-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-63 (FIG NO A-56)													
110500	2-SI-63-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
110600	2-SI-63-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
110700	2-SI-63-05	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	WELD INACCESSIBLE FOR
	PIPE TO COLLAR	B10.10		2	-	-	-	-	-	-	-	-	-	EXAMINATION DUE TO COLLAR
	CONT. L2			3	-	-	-	-	-	-	-	-	-	CONFIGURATION.
				4	-	-	-	-	-	-	-	-	-	
110750	2-SI-63-05FB	B-G-2	VT-1	1	-	-	-	-	-	-	-	-	-	
	FLANGE BOLTING	B7.50		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
110900	2-SI-63-06	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	
	COLLAR TO PIPE	B10.10		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
111000	2-SI-63-07	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
111100	2-SI-63-08	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	C	-	-	
	CONT. L2			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-63 (FIG NO A-56)														
111200	2-SI-63-09	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
111300	2-SI-63-10	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
111400	2-SI-63-11	B-J	PT	1	-	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
111500	2-SI-63-12	B-J	PT	1	-	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
111600	2-SI-63-13	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	C	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
111700	2-SI-63-14	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
111800	2-SI-63-15	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-63 (FIG NO A-56)													
111900	2-SI-63-16	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
112000	2-SI-63-17	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO VALVE	B9.11	UT	2	-	-	-	-	-	-	C	-	-	
	CONT. L2			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
112100	2-SI-63-18	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
112200	2-SI-63-19	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO BRANCH CONNECTION	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
	LINE 2-SI-66 (FIG NO A-57)													
112201	2-SI-66-01F	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PENETRATION #44 TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112202	2-SI-66-02S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112203	2-SI-66-03S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-66 (FIG NO A-57)														
112204	2-SI-66-04S	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.21		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
112205	2-SI-66-05S	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	B9.21		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
112206	2-SI-66-06S	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	B9.21		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
112207	2-SI-66-07S	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
112208	2-SI-66-08S	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
112209	2-SI-66-09S	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
112210	2-SI-66-10S	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-66 (FIG NO A-57)													
112211	2-SI-66-11S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112212	2-SI-66-12S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112213	2-SI-66-13S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112214	2-SI-66-14F	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112215	2-SI-66-15S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO BEND	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112216	2-SI-66-16F	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	BEND TO BEND	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	
112217	2-SI-66-17S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	BEND TO REDUCER	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-67 (FIG NO A-58)														
112218	2-SI-67-01F	B-J	PT	1 -	-	-	-	-	-	-	-	-	-		
	REDUCER TO PIPE	B9.21		2 -	-	-	-	-	-	-	-	-	-		
				3 -	X	-	-	-	-	-	-	-	-		
				4 -	-	-	-	-	-	-	-	-	-		
112219	2-SI-67-02S	B-J	PT	1 -	-	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	B9.21		2 -	-	-	-	-	-	-	-	-	-		
				3 -	X	-	-	-	-	-	-	-	-		
				4 -	-	-	-	-	-	-	-	-	-		
112220	2-SI-67-03S	B-J	PT	1 -	-	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	B9.21		2 -	-	-	-	-	-	-	-	-	-		
				3 -	-	-	-	-	-	-	-	-	-		
				4 -	-	-	-	-	-	-	-	-	-		
112221	2-SI-67-04S	B-J	PT	1 -	-	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	B9.21		2 -	-	-	-	-	-	-	-	-	-		
				3 -	-	-	-	-	-	-	-	-	-		
				4 -	-	-	-	-	-	-	-	-	-		
112222	2-SI-67-05S	B-J	PT	1 -	-	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	B9.21		2 -	-	-	-	-	-	-	-	-	-		
				3 -	-	-	-	-	-	-	-	-	-		
				4 -	-	-	-	-	-	-	-	-	-		
112223	2-SI-67-06S	B-J	PT	1 -	-	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	B9.21		2 -	-	-	-	-	-	-	-	-	-		
				3 -	-	-	-	-	-	-	-	-	-		
				4 -	-	-	-	-	-	-	-	-	-		
112224	2-SI-67-07S	B-J	PT	1 -	-	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	B9.21		2 -	-	-	-	-	-	-	-	-	-		
				3 -	-	-	-	-	-	-	-	-	-		
				4 -	-	-	-	-	-	-	-	-	-		

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-67 (FIG NO A-58)													
112225	2-SI-67-08S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112226	2-SI-67-09S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112227	2-SI-67-10F	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO BEND	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112228	2-SI-67-11S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	BEND TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-67 (FIG NO A-59)													
112229	2-SI-67-12F	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112230	2-SI-67-13S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112231	2-SI-67-14S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-67 (FIG NO A-59)													
112232	2-SI-67-15S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112233	2-SI-67-16S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112234	2-SI-67-17S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112235	2-SI-67-18F	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112236	2-SI-67-19S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112237	2-SI-67-20S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112238	2-SI-67-21S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-67 (FIG NO A-59)													
112239	2-SI-67-22S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112240	2-SI-67-23S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112241	2-SI-67-24S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112242	2-SI-67-25S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112243	2-SI-67-26S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112244	2-SI-67-27S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112245	2-SI-67-28S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1 (OUTAGE)	SECOND PERIOD 2 (OUTAGE)	SECOND PERIOD 3 (OUTAGE)	SECOND PERIOD 4 (OUTAGE)	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-67 (FIG NO A-59)													
112246	2-SI-67-29S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO REDUCER	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-73 (FIG NO A-60)													
112268	2-SI-73-17S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO REDUCER	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	
112269	2-SI-73-18S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO TEE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	
112270	2-SI-73-24F	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO REDUCER	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112271	2-SI-73-25F	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	REDUDER TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112272	2-SI-73-26S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO TEE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112273	2-SI-73-27F	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-SI-73 (FIG NO A-60)														
112274	2-SI-73-28S	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
112275	2-SI-73-29S	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	
112276	2-SI-73-30F	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO PENETRATION #44	B9.21		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-566 (FIG NO A-61)														
112277	2-SI-566-25F	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
112278	2-SI-566-26F	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
112279	2-SI-566-27S	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
112280	2-SI-566-28S	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-566 (FIG NO A-61)													
112281	2-SI-566-29S	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
112282	2-SI-566-30S	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
112283	2-SI-566-31S	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
112284	2-SI-566-32S	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.21		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
112285	2-SI-566-33S	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.21		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
112286	2-SI-566-34S	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.21		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
112287	2-SI-566-35S	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.21		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-566 (FIG NO A-61)													
112288	2-SI-566-36S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112289	2-SI-566-37S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112290	2-SI-566-38S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112291	2-SI-566-39S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112292	2-SI-566-40S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112293	2-SI-566-41S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112294	2-SI-566-42S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-566 (FIG NO A-61)													
112295	2-SI-566-43F	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112296	2-SI-566-44F	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112297	2-SI-566-45S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO BEND	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112298	2-SI-566-46F	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	BEND TO VALVE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-566 (FIG NO A-62)													
112300	2-SI-566-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112400	2-SI-566-02	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112500	2-SI-566-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-566 (FIG NO A-62)													
112600	2-SI-566-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112700	2-SI-566-05	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
112900	2-SI-566-06	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
113000	2-SI-566-07	B-J	PT	1	-	-	-	C	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	C	-	-	-	-	-	
	ANNULUS			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
113100	2-SI-566-08	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
113200	2-SI-566-09	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
113300	2-SI-566-10	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-566 (FIG NO A-62)														
113400	2-SI-566-11	B-J	PT	1	-	-	-	-	-	-	C	-	-		
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	C	-	-		
	ANNULUS			3	-	-	-	-	-	-	X	-	-		
				4	-	-	-	-	-	-	-	-	-		
113500	2-SI-566-12	B-K-1	PT	1	-	-	-	-	-	-	-	-	-		WELD INACCESSIBLE FOR
	PIPE TO COLLAR	B10.10		2	-	-	-	-	-	-	-	-	-		EXAMINATION DUE TO COLLAR
	CONT. L1			3	-	-	-	-	-	-	-	-	-		CONFIGURATION.
				4	-	-	-	-	-	-	-	-	-		
113550	2-SI-566-12FB	B-G-2	VT-1	1	-	-	-	-	-	-	-	-	-		
	FLANGE BOLTING	B7.50		2	-	-	-	-	-	-	-	-	-		
	CONT. L1			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
113700	2-SI-566-13	B-K-1	PT	1	-	-	-	-	-	-	-	-	-		100% UT NOT FEASIBLE DUE TO
	COLLAR TO PIPE	B10.10		2	-	-	-	C	-	-	-	-	-		WELD CONFIGURATION.
	CONT. L1			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
113800	2-SI-566-14	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	PIPE TO COUPLING	B9.40		2	-	-	-	-	-	-	-	-	-		
	CONT. L1			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
113900	2-SI-566-15	B-J	PT	1	-	-	-	-	-	-	C	-	-		
	COUPLING TO PIPE	B9.40		2	-	-	-	-	-	-	C	-	-		
	CONT. L1			3	-	-	-	-	-	-	X	-	-		
				4	-	-	-	-	-	-	-	-	-		
114100	2-SI-566-16	B-J	PT	1	-	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-		
	CONT. L1			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-566 (FIG NO A-62)													
114200	2-SI-566-17	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
114300	2-SI-566-18	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
114400	2-SI-566-19	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
114600	2-SI-566-20	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
114700	2-SI-566-21	B-J	PT	1	-	-	-	C	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	C	-	-	-	-	-	
	CONT. L1			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
114800	2-SI-566-22	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
114900	2-SI-566-23	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-566 (FIG NO A-62)													
115000	2-SI-566-24	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO BRANCH CONNECTION	B9.40		2	-	-	-	-	-	-	C	-	-	
	CONT. L1			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-567 (FIG NO A-63)													
115003	2-SI-567-33F	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
115006	2-SI-567-34S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
115009	2-SI-567-35F	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
115012	2-SI-567-36S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
115015	2-SI-567-37S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
115018	2-SI-567-38S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE)	FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-567 (FIG NO A-63)														
115021	2-SI-567-39S	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
115024	2-SI-567-40F	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
115027	2-SI-567-41S	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO BEND	B9.40		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
115030	2-SI-567-42F	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	BEND TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
115033	2-SI-567-43S	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
115036	2-SI-567-44S	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
115039	2-SI-567-45S	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-567 (FIG NO A-63)													
115042	2-SI-567-46S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
115045	2-SI-567-47S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
115048	2-SI-567-48S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
115051	2-SI-567-49S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO BEND	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
115054	2-SI-567-50F	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	BEND TO BEND	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
115057	2-SI-567-51F	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	BEND TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
115060	2-SI-567-52S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL ASME SEC. XI CATGY ITEM NO	NDE METH	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-567 (FIG NO A-63)													
115063	2-SI-567-53S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
115066	2-SI-567-54S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
115069	2-SI-567-55S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
115072	2-SI-567-56F	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-567 (FIG NO A-64)													
115075	2-SI-567-57F	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
115078	2-SI-567-58S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
115081	2-SI-567-59S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-567 (FIG NO A-64)													
115084	2-SI-567-60S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
115087	2-SI-567-61S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
115090	2-SI-567-62S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
115093	2-SI-567-63F	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-567 (FIG NO A-65)													
115100	2-SI-567-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
115300	2-SI-567-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
115400	2-SI-567-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-567 (FIG NO A-65)													
115500	2-SI-567-04	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
115600	2-SI-567-05	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2 -	-	-	-	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
115700	2-SI-567-06	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2 -	-	-	-	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
115800	2-SI-567-07	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2 -	-	-	-	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
115900	2-SI-567-08	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2 -	-	-	-	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
116000	2-SI-567-09	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2 -	-	-	-	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
116200	2-SI-567-10	B-J	PT	1 -	-	-	C	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2 -	-	-	C	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	X	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-567 (FIG NO A-65)														
116300	2-SI-567-11	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
116400	2-SI-567-12	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
116500	2-SI-567-13	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
116600	2-SI-567-14	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	-	WELD INACCESSIBLE FOR
	PIPE TO COLLAR	B10.10		2	-	-	-	-	-	-	-	-	-	-	EXAMINATION DUE TO COLLAR
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	CONFIGURATION.
				4	-	-	-	-	-	-	-	-	-	-	
116800	2-SI-567-15	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	-	100% UT NOT FEASIBLE DUE TO
	COLLAR TO PIPE	B10.10		2	-	-	-	-	-	-	-	-	-	-	WELD CONFIGURATION.
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
116900	2-SI-567-16	B-J	PT	1	-	-	-	-	-	-	-	C	-	-	
	PIPE TO COUPLING	B9.40		2	-	-	-	-	-	-	-	C	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
117000	2-SI-567-17	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	COUPLING TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1 2 3	SECOND PERIOD 1 2 3 4	THIRD PERIOD 1 2 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-567 (FIG NO A-65)							
117100	2-SI-567-18	B-J	PT	1	- - -	- - - -	- - -	
	PIPE TO ELBOW	B9.40		2	- - -	- - - -	- - -	
	CONT. L4			3	- - -	- - - -	X - -	
				4	- - -	- - - -	- - -	
117200	2-SI-567-19	B-J	PT	1	- - -	- - - -	- - -	
	ELBOW TO PIPE	B9.40		2	- - -	- - - -	- - -	
	CONT. L4			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
117300	2-SI-567-20	B-J	PT	1	- - -	- - - -	- - -	
	PIPE TO ELBOW	B9.40		2	- - -	- - - -	- - -	
	CONT. L4			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
117400	2-SI-567-21	B-J	PT	1	- - -	- - - -	- - -	
	ELBOW TO PIPE	B9.40		2	- - -	- - - -	- - -	
	CONT. L4			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
117500	2-SI-567-22	B-J	PT	1	- - -	- - - -	- - -	
	PIPE TO ELBOW	B9.40		2	- - -	- - - -	- - -	
	CONT. L4			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
117600	2-SI-567-23	B-J	PT	1	- - -	- - - -	C - -	
	ELBOW TO PIPE	B9.40		2	- - -	- - - -	C - -	
	CONT. L4			3	- - -	- - - -	X - -	
				4	- - -	- - - -	- - -	
117800	2-SI-567-24	B-J	PT	1	- - -	- - - -	- - -	
	PIPE TO ELBOW	B9.40		2	- - -	- - - -	- - -	
	CONT. L4			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-567 (FIG NO A-65)													
117900	2-SI-567-25	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
118000	2-SI-567-26	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
118100	2-SI-567-27	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
118300	2-SI-567-28	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
118400	2-SI-567-29	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
118500	2-SI-567-30	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
118600	2-SI-567-31	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD (OUTAGE 1 2 3)	SECOND PERIOD (OUTAGE 1 2 3 4)	THIRD PERIOD (OUTAGE 1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-567 (FIG NO A-65)						
118700	2-SI-567-32	B-J	PT	1 - - -	- - - -	- - -	
	PIPE TO BRANCH CONNECTION	B9.40		2 - - -	- - - -	- - -	
	CONT. L4			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
	LINE 2-SI-568 (FIG NO A-66)						
118730	2-SI-568-33F	B-J	PT	1 - - -	- - - -	- - -	
	TEE TO PIPE	B9.40		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
118735	2-SI-568-34S	B-J	PT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	B9.40		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
118740	2-SI-568-35S	B-J	PT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	B9.40		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
118745	2-SI-568-36S	B-J	PT	1 - - -	- - - -	- - -	
	PIPE TO TEE	B9.40		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
118750	2-SI-568-37S	B-J	PT	1 - - -	- - - -	- - -	
	TEE TO PIPE	B9.40		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
118755	2-SI-568-38S	B-J	PT	1 - - -	- - - -	- - -	
	PIPE TO TEE	B9.40		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD (OUTAGE 1 2 3)	SECOND PERIOD (OUTAGE 1 2 3 4)	THIRD PERIOD (OUTAGE 1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-568 (FIG NO A-66)						
118760	2-SI-568-39S	B-J	PT	1 - - -	- - - -	- - -	
	TEE TO PIPE	B9.40		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
118765	2-SI-568-40S	B-J	PT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	B9.40		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
118770	2-SI-568-41S	B-J	PT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	B9.40		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
118775	2-SI-568-42S	B-J	PT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	B9.40		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
118780	2-SI-568-43S	B-J	PT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	B9.40		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
118785	2-SI-568-44S	B-J	PT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	B9.40		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
118790	2-SI-568-45S	B-J	PT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	B9.40		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-568 (FIG NO A-66)													
118795	2-SI-568-46F	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-568 (FIG NO A-67)													
118800	2-SI-568-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
119000	2-SI-568-02	B-J	PT	1	-	-	-	C	-	-	-	-	-	-
	PIPE TO VALVE	B9.40		2	-	-	-	C	-	-	-	-	-	-
	ANNULUS			3	-	-	-	X	-	-	-	-	-	-
				4	-	-	-	-	-	-	-	-	-	-
119100	2-SI-568-03	B-J	PT	1	-	-	-	C	-	-	-	-	-	-
	VALVE TO PIPE	B9.40		2	-	-	-	C	-	-	-	-	-	-
	ANNULUS			3	-	-	-	X	-	-	-	-	-	-
				4	-	-	-	-	-	-	-	-	-	-
119200	2-SI-568-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	-
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-
	ANNULUS			3	-	-	-	X	-	-	-	-	-	-
				4	-	-	-	-	-	-	-	-	-	-
119300	2-SI-568-05	B-J	PT	1	-	-	-	-	-	-	-	C	-	-
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	C	-	-
	ANNULUS			3	-	-	-	-	-	-	-	X	-	-
				4	-	-	-	-	-	-	-	-	-	-
119400	2-SI-568-06	B-J	PT	1	-	-	-	-	-	-	-	-	-	-
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-
	ANNULUS			3	-	-	-	-	-	-	-	-	-	-
				4	-	-	-	-	-	-	-	-	-	-

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD			INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-568 (FIG NO A-67)																
119500	2-SI-568-07	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	-		
	ANNULUS			3	-	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
119600	2-SI-568-08	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	-		
	ANNULUS			3	-	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
119700	2-SI-568-09	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	-		
	ANNULUS			3	-	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
120000	2-SI-568-10	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
120100	2-SI-568-11	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	B9.40		2	C	-	-	-	-	-	-	-	-	-	-		
				3	X	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
120200	2-SI-568-12	B-J	PT	1	-	-	-	-	-	-	-	-	C	-	-		
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	C	-	-		
	ANNULUS			3	-	-	-	-	-	-	-	-	X	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
120300	2-SI-568-13	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	-		
	ANNULUS			3	-	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-568 (FIG NO A-67)													
120400	2-SI-568-14	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	WELD INACCESSIBLE FOR
	PIPE TO COLLAR	B10.10		2	-	-	-	-	-	-	-	-	-	EXAMINATION DUE TO COLLAR
	CONT. L2			3	-	-	-	-	-	-	-	-	-	CONFIGURATION.
				4	-	-	-	-	-	-	-	-	-	
120600	2-SI-568-15	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	100% UT NOT FEASIBLE DUE TO
	COLLAR TO PIPE	B10.10		2	-	-	-	-	-	-	-	-	-	WELD CONFIGURATION.
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
120700	2-SI-568-16	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
120800	2-SI-568-17	B-J	PT	1	-	-	-	C	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	C	-	-	-	-	-	
	CONT. L2			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
120900	2-SI-568-18	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
121000	2-SI-568-19	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
121100	2-SI-568-20	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	C	-	-	
	CONT. L2			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-568 (FIG NO A-67)													
121200	2-SI-568-21	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
121300	2-SI-568-22	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
121400	2-SI-568-23	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
121800	2-SI-568-24	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
121900	2-SI-568-25	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
122000	2-SI-568-26	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
122100	2-SI-568-27	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - -			O U T A G E				- - - - - -			
	LINE 2-SI-568 (FIG NO A-67)													
122200	2-SI-568-28	B-J	PT	1 -	-	-	-	-	-	-	C	-	-	
	PIPE TO VALVE	B9.40		2 -	-	-	-	-	-	-	C	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
122300	2-SI-568-29	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
122400	2-SI-568-30	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
122500	2-SI-568-31	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
122600	2-SI-568-32	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	PIPE TO BRANCH CONNECTION	B9.40		2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-569 (FIG NO A-68)													
122605	2-SI-569-37F	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	REDUCER TO BEND	B9.40		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
122610	2-SI-569-38F	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	BEND TO BEND	B9.40		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-569 (FIG NO A-68)													
122615	2-SI-569-39S	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	BEND TO ELBOW	B9.40		2 -	-	-	-	-	-	-	-	-	-	
				3 -	X	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
122620	2-SI-569-40S	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2 -	-	-	-	-	-	-	-	-	-	
				3 -	X	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
122625	2-SI-569-41S	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2 -	-	-	-	-	-	-	-	-	-	
				3 -	X	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
122630	2-SI-569-42S	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
122635	2-SI-569-43S	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
122640	2-SI-569-44S	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
122645	2-SI-569-45S	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-569 (FIG NO A-68)													
122650	2-SI-569-46S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
122655	2-SI-569-47S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
122660	2-SI-569-48S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
122665	2-SI-569-49S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
122670	2-SI-569-50S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
122675	2-SI-569-51S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
122680	2-SI-569-52S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-569 (FIG NO A-68)													
122685	2-SI-569-53S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
122687	2-SI-569-54S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
122690	2-SI-569-55F	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
122693	2-SI-569-56S	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO BEND	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
122695	2-SI-569-57F	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	BEND TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-569 (FIG NO A-69)													
122700	2-SI-569-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
122800	2-SI-569-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-569 (FIG NO A-69)													
122900	2-SI-569-03	B-J	PT	1	-	-	C	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	C	-	-	-	-	-	-	
	ANNULUS			3	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
123000	2-SI-569-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
123100	2-SI-569-05	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
123300	2-SI-569-06	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
123400	2-SI-569-07	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
123500	2-SI-569-08	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	
123600	2-SI-569-09	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD			INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-569 (FIG NO A-69)																
123700	2-SI-569-10	B-J	PT	1	-	-	-	-	-	-	C	-	-				
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	C	-	-				
	ANNULUS			3	-	-	-	-	-	-	X	-	-				
				4	-	-	-	-	-	-	-	-	-				
123800	2-SI-569-11	B-J	PT	1	-	-	-	-	-	-	-	-	-				
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-				
	ANNULUS			3	-	-	-	-	-	-	X	-	-				
				4	-	-	-	-	-	-	-	-	-				
123900	2-SI-569-12	B-K-1	PT	1	-	-	-	-	-	-	-	-	-				WELD INACCESSIBLE FOR
	PIPE TO COLLAR	B10.10		2	-	-	-	-	-	-	-	-	-				EXAMINAION DUE TO COLLAR
	CONT. L3			3	-	-	-	-	-	-	-	-	-				CONFIGURATION.
				4	-	-	-	-	-	-	-	-	-				
124100	2-SI-569-13	B-K-1	PT	1	-	-	-	C	-	-	-	-	-				100% UT NOT FEASIBLE DUE TO
	COLLAR TO PIPE	B10.10		2	-	-	-	C	-	-	-	-	-				WELD CONFIGURATION.
	CONT. L3			3	-	-	-	-	-	-	-	-	-				
				4	-	-	-	-	-	-	-	-	-				
124200	2-SI-569-14	B-J	PT	1	-	-	-	-	-	-	-	-	-				
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-				
	CONT. L3			3	-	-	-	-	-	-	-	-	-				
				4	-	-	-	-	-	-	-	-	-				
124300	2-SI-569-15	B-J	PT	1	-	-	-	-	-	-	-	-	-				
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-				
	CONT. L3			3	-	-	-	-	-	-	-	-	-				
				4	-	-	-	-	-	-	-	-	-				
124400	2-SI-569-16	B-J	PT	1	-	-	-	C	-	-	-	-	-				
	PIPE TO ELBOW	B9.40		2	-	-	-	C	-	-	-	-	-				
	CONT. L3			3	-	-	-	X	-	-	-	-	-				
				4	-	-	-	-	-	-	-	-	-				

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-569 (FIG NO A-69)													
124500	2-SI-569-17	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
124600	2-SI-569-18	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L3			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
124700	2-SI-569-19	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L3			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
125100	2-SI-569-20	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L3			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
125200	2-SI-569-21	B-J	PT	1 -	-	-	C	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2 -	-	-	C	-	-	-	-	-	-	
	CONT. L3			3 -	-	-	X	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
125300	2-SI-569-22	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L3			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
125400	2-SI-569-23	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L3			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-569 (FIG NO A-69)														
125600	2-SI-569-24	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
125700	2-SI-569-25	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	C	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
125800	2-SI-569-26	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
125900	2-SI-569-27	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
126100	2-SI-569-28	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
126200	2-SI-569-29	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
126300	2-SI-569-30	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-569 (FIG NO A-69)													
126400	2-SI-569-31	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	C	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
126600	2-SI-569-32	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
126700	2-SI-569-33	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
126800	2-SI-569-34	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
126900	2-SI-569-35	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	C	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
127000	2-SI-569-36	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO BRANCH CONNECTION	B9.40		2	-	-	-	-	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-119 (FIG NO A-70)													
128300	2-CS-119-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	BRANCH CONNECTION TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
128400	2-CS-119-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
128500	2-CS-119-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
128600	2-CS-119-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO REDUCER	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
128700	2-CS-119-05	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
128800	2-CS-119-06	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.21		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
128900	2-CS-119-07	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD (OUTAGE) 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-119 (FIG NO A-70)													
129200	2-CS-119-08	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.21		2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
129300	2-CS-119-09	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.21		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L4			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
129400	2-CS-119-10	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L4			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
129500	2-CS-119-11	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L4			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
129600	2-CS-119-12	B-J	PT	1 -	-	-	-	-	-	-	C	-	-	
	PIPE TO PIPE	B9.21		2 -	-	-	-	-	-	-	-	X	-	
	CONT. L4			3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	
129700	2-CS-119-13	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L4			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-CS-119 (FIG NO A-71)													
129800	2-CS-119-14	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2 -	-	-	-	-	-	-	-	-	-	
	CONT. L4			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD			INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-119 (FIG NO A-71)																
129900	2-CS-119-15	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	-	-		
	PIPE TO PIPE	B9.21		2 C	-	-	-	-	-	-	-	-	-	-	-		
				3 X	-	-	-	-	-	-	-	-	-	-	-		
				4 -	-	-	-	-	-	-	-	-	-	-	-		
130400	2-CS-119-16	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	B9.21		2 -	-	-	-	-	-	-	-	-	-	-	-		
	CONT. PRT			3 -	-	-	-	-	-	-	-	-	-	-	-		
				4 -	-	-	-	-	-	-	-	-	-	-	-		
130500	2-CS-119-17	B-J	PT	1 -	-	-	C	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	B9.21		2 -	-	-	C	-	-	-	-	-	-	-	-		
	CONT. PRT			3 -	-	-	X	-	-	-	-	-	-	-	-		
				4 -	-	-	-	-	-	-	-	-	-	-	-		
130600	2-CS-119-18	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	B9.21		2 -	-	-	-	-	-	-	-	-	-	-	-		
	CONT. PRT			3 -	-	-	-	-	-	-	-	-	-	-	-		
				4 -	-	-	-	-	-	-	-	-	-	-	-		
130700	2-CS-119-19	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	-	-		
	ELBOW TO ELBOW	B9.21		2 -	-	-	-	-	-	-	-	-	-	-	-		
	CONT. PRT			3 -	-	-	-	-	-	-	-	-	-	-	-		
				4 -	-	-	-	-	-	-	-	-	-	-	-		
130800	2-CS-119-20	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	B9.21		2 -	-	-	-	-	-	-	-	-	-	-	-		
	CONT. PRT			3 -	-	-	-	-	-	-	-	-	-	-	-		
				4 -	-	-	-	-	-	-	-	-	-	-	-		
130900	2-CS-119-21	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	-	-		
	PIPE TO REDUCER	B9.21		2 -	-	-	-	-	-	-	-	-	-	-	-		
	CONT. PRT			3 -	-	-	-	-	-	-	-	-	-	-	-		
				4 -	-	-	-	-	-	-	-	-	-	-	-		

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD (OUTAGE 1 2 3)	SECOND PERIOD (OUTAGE 1 2 3 4)	THIRD PERIOD (OUTAGE 1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-119 (FIG NO A-71)						
131000	2-CS-119-22	B-J	PT	1 - - -	- - - -	- - -	
	REDUCER TO VALVE	B9.40		2 - - -	- - - -	- - -	
	CONT. PRT			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
131100	2-CS-119-23	B-J	PT	1 - - -	- - - -	- - -	
	VALVE TO REDUCER	B9.40		2 - - -	- - - -	- - -	
	CONT. PRT			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
131200	2-CS-119-24	B-J	PT	1 - - -	- - - -	C - -	
	REDUCER TO PIPE	B9.21		2 - - -	- - - -	C - -	
	CONT. PRT			3 - - -	- - - -	X - -	
				4 - - -	- - - -	- - -	
131600	2-CS-119-25	B-J	PT	1 - - -	- - - -	- - -	
	PIPE TO VALVE	B9.21		2 - - -	- - - -	- - -	
	CONT. PRT			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
	LINE 2-CS-120 (FIG NO A-72)						
134000	2-CS-120-01	B-J	PT	1 - - -	- - - -	- - -	
	VALVE TO PIPE	B9.21		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
134100	2-CS-120-02	B-J	PT	1 - - -	- - - -	- - -	
	PIPE TO VALVE	B9.21		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
134200	2-CS-120-03	B-J	PT	1 - - -	- - - -	C - -	
	VALVE TO PIPE	B9.21		2 - - -	- - - -	C - -	
	CONT. L1			3 - - -	- - - -	X - -	
				4 - - -	- - - -	- - -	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1 (OUTAGE)	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-120 (FIG NO A-72)													
135000	2-CS-120-04	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
135100	2-CS-120-05	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
135400	2-CS-120-06	B-J	PT	1 C	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
135500	2-CS-120-07	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
135600	2-CS-120-08	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
135700	2-CS-120-09	B-J	PT	1 -	-	-	C	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2 -	-	-	C	-	-	-	-	-	-	
	CONT. L1			3 -	-	-	X	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
135800	2-CS-120-10	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
							OUTAGE							
	LINE 2-CS-120 (FIG NO A-72)													
135900	2-CS-120-11	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
136100	2-CS-120-12	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	C	-	-	
	CONT. L1			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	
136200	2-CS-120-13	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO BRANCH CONNECTION	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-CS-121 (FIG NO A-73)													
136300	2-CS-121-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
136400	2-CS-121-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
136500	2-CS-121-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
136600	2-CS-121-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CS-121 (FIG NO A-73)													
136700	2-CS-121-05	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	B9.21		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
136800	2-CS-121-06	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
136900	2-CS-121-07	B-J	PT	1 -	-	-	C	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.21		2 -	-	-	C	-	-	-	-	-	-	
	CONT. L4			3 -	-	-	X	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
137000	2-CS-121-08	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	B9.21		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
137100	2-CS-121-09	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.21		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
137200	2-CS-121-10	B-J	PT	1 -	-	-	-	-	-	-	C	-	-	
	PIPE TO BRANCH CONNECTION	B9.21		2 -	-	-	-	-	-	-	-	X	-	
	CONT. L4			3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-CS-687 (FIG NO A-74)													
137300	2-CS-687-01	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1 2 3	SECOND PERIOD 1 2 3 4 (OUTAGE)	THIRD PERIOD 1 2 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-687 (FIG NO A-74)						
137400	2-CS-687-02	B-J	PT	1 - - -	C - - -	- - -	
	PIPE TO ELBOW	B9.40		2 - - -	C - - -	- - -	
	REGEN HXRM			3 - - -	X - - -	- - -	
				4 - - -	- - - -	- - -	
137500	2-CS-687-03	B-J	PT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	B9.40		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
137600	2-CS-687-04	B-J	PT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	B9.40		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
137700	2-CS-687-05	B-J	PT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	B9.40		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
137800	2-CS-687-06	B-J	PT	1 - - -	C - - -	- - -	
	PIPE TO ELBOW	B9.40		2 - - -	C - - -	- - -	
	REGEN HXRM			3 - - -	X - - -	- - -	
				4 - - -	- - - -	- - -	
137900	2-CS-687-07	B-J	PT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	B9.40		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
138000	2-CS-687-08	B-J	PT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	B9.40		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-687 (FIG NO A-74)													
138100	2-CS-687-09	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	C	-	-	
	CONT. L4			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	
138400	2-CS-687-10	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
138500	2-CS-687-11	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
138600	2-CS-687-12	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
138700	2-CS-687-13	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
138800	2-CS-687-14	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
138900	2-CS-687-15	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CS-687 (FIG NO A-74)													
139000	2-CS-687-16	B-J	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO REDUCER	B9.21		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

RESIDUAL HEAT REMOVAL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-31 (FIG NO A-75)														
148000	2-RH-31-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.11	UT	2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
148100	2-RH-31-02	B-J	PT	1	C	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
148200	2-RH-31-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
148300	2-RH-31-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
	LINE 2-RH-32 (FIG NO A-76)														
148400	2-RH-32-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
148500	2-RH-32-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
148600	2-RH-32-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**

RESIDUAL HEAT REMOVAL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
							OUTAGE							
	LINE 2-RH-32 (FIG NO A-76)													
148700	2-RH-32-04	B-J	PT	1	-	-	C	-	-	-	-	-	-	
	PIPE TO TEE	B9.11	UT	2	-	-	C	-	-	-	-	-	-	
	ANNULUS			3	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
	LINE 2-RH-33 (FIG NO A-77)													
148800	2-RH-33-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	BRANCH CONNECTION TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**
148900	2-RH-33-02	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	C	-	-	
	CONT. L2			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**
149000	2-RH-33-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**
149100	2-RH-33-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**
149200	2-RH-33-05	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**
149250	2-RH-33-05-PL 1 AND 2	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE LUG	B10.10		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

RESIDUAL HEAT REMOVAL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-33 (FIG NO A-77)													
149300	2-RH-33-06	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**
149400	2-RH-33-07	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	C	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**
149500	2-RH-33-08	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**
149600	2-RH-33-09	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**
149700	2-RH-33-10	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**
149800	2-RH-33-11	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**
149850	2-RH-33-12	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**

RESIDUAL HEAT REMOVAL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-33 (FIG NO A-77)													
149900	2-RH-33-13	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**
150000	2-RH-33-14	B-J	PT	1	-	-	-	C	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	C	-	-	-	-	-	
	CONT. L2			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**
150100	2-RH-33-15	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO COLLAR	B10.10		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
150300	2-RH-33-16	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	WELD INACCESSIBLE FOR
	COLLAR TO PIPE	B10.10		2	-	-	-	-	-	-	-	-	-	EXAMINATION DUE TO COLLAR
				3	-	-	-	-	-	-	-	-	-	CONFIGURATION.
				4	-	-	-	-	-	-	-	-	-	
150400	2-RH-33-17	B-J	PT	1	-	-	-	-	-	-	-	C	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	C	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**
150466	2-RH-33-17-PL	B-K-1	PT	1	-	-	-	-	-	-	-	C	-	
	PIPE LUG	B10.10		2	-	-	-	-	-	-	-	C	-	
	ANNULUS			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	
150500	2-RH-33-18	B-J	PT	1	-	-	-	-	-	-	-	C	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	C	-	
	ANNULUS			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**

RESIDUAL HEAT REMOVAL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-33 (FIG NO A-77)													
150600	2-RH-33-19	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**
150700	2-RH-33-20	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**
150800	2-RH-33-21	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO VALVE	B9.11	UT	2	-	-	-	-	-	-	C	-	-	
	ANNULUS			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378032 (14-SS-160-1.40)**

WASTE DISPOSAL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-WD-820 (FIG NO A-78)													
150900	2-WD-820-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	BRANCH CONNECTION TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
151000	2-WD-820-02	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
151100	2-WD-820-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
151200	2-WD-820-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-WD-821 (FIG NO A-79)													
151300	2-WD-821-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	BRANCH CONNECTION TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
151400	2-WD-821-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
151500	2-WD-821-03	B-J	PT	1	-	-	-	C	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	C	-	-	-	-	-	
	CONT. L2			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

WASTE DISPOSAL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-WD-821 (FIG NO A-79)													
151600	2-WD-821-04	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-WD-822 (FIG NO A-80)													
151700	2-WD-822-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	BRANCH CONNECTION TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
151800	2-WD-822-02	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
151900	2-WD-822-03	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
152000	2-WD-822-04	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	C	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
152100	2-WD-822-05	B-J	PT	1	C	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
152200	2-WD-822-06	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

WASTE DISPOSAL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-WD-822 (FIG NO A-80)													
152300	2-WD-822-07	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	TEE TO REDUCER	B9.40		2	-	-	-	-	-	-	C	-	-	
	CONT. L3			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	
152400	2-WD-822-08	B-J	PT	1	-	-	-	C	-	-	-	-	-	
	TEE TO PIPE	B9.40		2	-	-	-	C	-	-	-	-	-	
	CONT. L3			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
152500	2-WD-822-09	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-WD-823 (FIG NO A-81)													
152600	2-WD-823-01	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
152700	2-WD-823-02	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
152800	2-WD-823-03	B-J	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	B9.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
152900	2-WD-823-04	B-J	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO VALVE	B9.40		2	-	-	-	-	-	-	C	-	-	
	CONT. L4			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT PUMP NO. 21

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	PRESSURE RETAINING BOLTING (GREATER THAN 2") (FIG NO A-82)																
153000	PUMP BOLTS, 1 THROUGH 24	B-G-1	UT	1 C	-	-	-	-	-	-	-	-	-	-	-	-	
		B6.180		2 C	-	-	-	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	-	-	-	**3378042 (PUMP STUD)**
153075	PUMP BOLTS (12 - 2" BOLTS) LOWER SEAL HOUSING BOLTS	B-G-2	VT-1	1 -	-	-	-	-	-	-	-	-	-	-	-	-	EXAMINED WHEN REMOVED.
		B7.50		2 -	-	-	-	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	-	-	-	
	SUPPORT COMPONENT																
153100	SUPPORT LUG NO. 1	B-K-1	PT	1 -	-	-	-	-	-	-	-	-	-	-	-	-	UT OF WELD NOT FEASIBLE DUE TO
		B10.20		2 -	-	-	-	-	-	-	-	-	-	-	-	-	ATTENUATIVE PROPERTIES OF PUMP
				3 -	-	-	-	-	-	-	-	-	-	-	-	-	CASING MATERIAL.
				4 -	-	-	-	-	-	-	-	-	-	-	-	-	
153200	SUPPORT LUG NO. 2	B-K-1	PT	1 -	-	-	-	-	-	-	-	-	-	-	-	-	UT OF WELD NOT FEASIBLE DUE TO
		B10.20		2 -	-	-	-	-	-	-	-	-	-	-	-	-	ATTENUATIVE PROPERTIES OF PUMP
				3 -	-	-	-	-	-	-	-	-	-	-	-	-	CASING MATERIAL.
				4 -	-	-	-	-	-	-	-	-	-	-	-	-	
153300	SUPPORT LUG NO. 3	B-K-1	PT	1 C	-	-	-	-	-	-	-	-	-	-	-	-	UT OF WELD NOT FEASIBLE DUE TO
		B10.20		2 -	-	-	-	-	-	-	-	-	-	-	-	-	ATTENUATIVE PROPERTIES OF PUMP
				3 -	-	-	-	-	-	-	-	-	-	-	-	-	CASING MATERIAL.
				4 -	-	-	-	-	-	-	-	-	-	-	-	-	
	CIRCUMFERENTIAL WELDS																
153400	PUMP CASING WELD	B-L-1	VT-1	1 -	-	-	-	-	-	-	-	-	-	-	-	-	EXAMINATION TO BE PERFORMED IN
		B12.10		2 -	-	-	-	-	-	-	-	-	-	-	-	-	ACCORDANCE WITH CC-N-481.
				3 -	-	-	-	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT PUMP NO. 21

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - - OUTAGE - - - - - -										
	PUMP INTERNALS													
153450	PUMP CASING INTERNAL SURFACE	B-L-2	VT-3	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION TO BE PERFORMED IN
		B12.20		2 -	-	-	-	-	-	-	-	-	-	ACCORDANCE WITH CC-N-481.
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
153460	PUMP FLANGE SURFACE	B-G-1	VT-1	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION TO BE PERFORMED IN
		B6.190		2 -	-	-	-	-	-	-	-	-	-	ACCORDANCE WITH CC-N-481.
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	PUMP FLYWHEEL													
153500	FLYWHEEL	--	UT	1 -	-	-	-	C	-	-	-	-	-	
	(IN PLACE)	RG1.14		2 -	-	-	C	-	-	-	C	-	-	
	CONT. L1			3 -	-	-	X	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**RC FLYWHEEL-CS-31-DCC**
153600	FLYWHEEL	--	PT	1 C	-	-	-	-	-	-	-	-	-	PT OF BORE AND MT OF ALL
	(WHEN REMOVED)	RG1.14	MT	2 C	-	-	-	-	-	-	-	-	-	REMAINING ACCESSIBLE SURFACES.
			UT	3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**RC FLYWHEEL-CS-31-DCC**

REACTOR COOLANT PUMP NO. 22

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	FIRST PERIOD 1 2 3	SECOND PERIOD 1 2 3 4	THIRD PERIOD 1 2 3	INSTRUCTIONS **CALIBRATION BLOCK**
	PRESSURE RETAINING BOLTING (GREATER THAN 2") (FIG NO A-82)							
153700	PUMP BOLTS, 1 THROUGH 24	B-G-1	UT	1	- - -	C C - -	- - -	
		B6.180		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	**3378042 (PUMP STUD)**
153730	PUMP BOLTS (12 - 2" BOLTS)	B-G-2	VT-1	1	- - -	- - - -	- - -	EXAMINED WHEN REMOVED.
	LOWER SEAL HOUSING BOLTS	B7.50		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SUPPORT COMPONENT							
153750	SUPPORT LUG NO. 1	B-K-1	PT	1	- - -	- - - -	- - -	UT OF WELD NOT FEASIBLE DUE TO
		B10.20		2	- - -	- - - -	C - -	ATTENUATIVE PROPERTIES OF PUMP
	CONT. L2			3	- - -	- - - -	X - -	CASING MATERIAL.
				4	- - -	- - - -	- - -	
153800	SUPPORT LUG NO. 2	B-K-1	PT	1	- - -	C - - -	- - -	UT OF WELD NOT FEASIBLE DUE TO
		B10.20		2	- - -	- - - -	C - -	ATTENUATIVE PROPERTIES OF PUMP
	CONT. L2			3	- - -	- - - -	X - -	CASING MATERIAL.
				4	- - -	- - - -	- - -	
153850	SUPPORT LUG NO. 3	B-K-1	PT	1	- - -	- - - -	- - -	UT OF WELD NOT FEASIBLE DUE TO
		B10.20		2	- - -	- - - -	C - -	ATTENUATIVE PROPERTIES OF PUMP
	CONT. L2			3	- - -	- - - -	X - -	CASING MATERIAL.
				4	- - -	- - - -	- - -	
	CIRCUMFERENTIAL WELDS							
154050	PUMP CASING WELD	B-L-1	VT-1	1	- - -	- - - -	- - -	EXAMINATION TO BE PERFORMED IN
		B12.10		2	- - -	- - - -	C - -	ACCORDANCE WITH CC-N-481.
	CONT. L2			3	- - -	- - - -	X - -	
				4	- - -	- - - -	- - -	

REACTOR COOLANT PUMP NO. 22

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	PUMP INTERNALS													
154100	PUMP CASING INTERNAL SURFACE	B-L-2	VT-3	1	-	-	-	-	-	-	-	-	-	EXAMINATION TO BE PERFORMED IN
		B12.20		2	-	-	-	-	-	-	-	-	-	ACCORDANCE WITH CC-N-481.
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
154110	PUMP FLANGE SURFACE	B-G-1	VT-1	1	-	-	-	-	-	-	-	-	-	EXAMINATION TO BE PERFORMED IN
		B6.190		2	-	-	-	-	-	-	-	-	-	ACCORDANCE WITH CC-N-481.
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	PUMP FLYWHEEL													
154150	FLYWHEEL	--	UT	1	-	-	-	-	C	-	-	-	-	
	(IN PLACE)	RG1.14		2	C	-	-	-	-	-	-	C	-	
	CONT. L2			3	X	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	**RC FLYWHEEL-CS-31-DCC**
154200	FLYWHEEL	--	PT	1	C	-	-	-	-	-	-	-	-	PT OF BORE AND MT OF ALL
	(WHEN REMOVED)	RG1.14	MT	2	-	-	-	C	-	-	-	-	-	REMAINING ACCESSIBLE SURFACES.
	CONT.		UT	3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**RC FLYWHEEL-CS-31-DCC**

REACTOR COOLANT PUMP NO. 23

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL ASME SEC. XI CATGY ITEM NO	NDE METH	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	PRESSURE RETAINING BOLTING (GREATER THAN 2") (FIG NO A-82)													
154400	PUMP BOLTS, 1 THROUGH 24	B-G-1	UT	1	-	-	-	-	-	-	C	-	-	
		B6.180		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378042 (PUMP STUD)**
154430	PUMP BOLTS (12 - 2" BOLTS) LOWER SEAL HOUSING BOLTS	B-G-2	VT-1	1	-	-	-	-	-	-	-	-	-	EXAMINED WHEN REMOVED.
		B7.50		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SUPPORT COMPONENT													
154450	SUPPORT LUG NO. 1	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	UT OF WELD NOT FEASIBLE DUE TO
		B10.20		2	-	-	-	-	-	-	-	-	-	ATTENUATIVE PROPERTIES OF PUMP
				3	-	-	-	-	-	-	-	-	-	CASING MATERIAL.
				4	-	-	-	-	-	-	-	-	-	
154500	SUPPORT LUG NO. 2	B-K-1	PT	1	-	-	-	-	-	-	-	-	-	UT OF WELD NOT FEASIBLE DUE TO
		B10.20		2	-	-	-	-	-	-	-	-	-	ATTENUATIVE PROPERTIES OF PUMP
				3	-	-	-	-	-	-	-	-	-	CASING MATERIAL.
				4	-	-	-	-	-	-	-	-	-	
154550	SUPPORT LUG NO. 3	B-K-1	PT	1	-	-	-	-	-	-	C	-	-	UT OF WELD NOT FEASIBLE DUE TO
		B10.20		2	-	-	-	-	-	-	-	-	-	ATTENUATIVE PROPERTIES OF PUMP
				3	-	-	-	-	-	-	-	-	-	CASING MATERIAL.
				4	-	-	-	-	-	-	-	-	-	
	CIRCUMFERENTIAL WELDS													
154750	PUMP CASING WELD	B-L-1	RT	1	-	-	-	-	-	-	-	-	-	EXAMINATION TO BE PEFORMED IN
		B12.10		2	-	-	-	-	-	-	-	-	-	ACCORDANCE WITH CC-N-481.
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT PUMP NO. 23

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	PUMP INTERNALS													
154800	PUMP CASING INTERNAL SURFACE	B-L-2	VT-3	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION TO BE PEFORMED IN
		B12.20		2 -	-	-	-	-	-	-	-	-	-	ACCORDANCE WITH CC-N-481.
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
154810	PUMP FLANGE SURFACE	B-G-1	VT-1	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION TO BE PEFORMED IN
		B6.190		2 -	-	-	-	-	-	-	-	-	-	ACCORDANCE WITH CC-N-481.
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	PUMP FLYWHEEL													
154850	FLYWHEEL	--	UT	1 -	-	-	-	C	-	-	-	-	-	
	(IN PLACE)	RG1.14		2 C	-	-	-	-	-	-	C	-	-	
	CONT. L3			3 X	-	-	-	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**RC FLYWHEEL-CS-31-DCC**
154900	FLYWHEEL	--	PT	1 -	C	-	-	-	-	-	-	-	-	PT OF BORE AND MT OF ALL
	(WHEN REMOVED)	RG1.14	MT	2 -	-	-	C	-	-	-	-	-	-	REMAINING ACCESSIBLE SURFACES.
	CONT.		UT	3 -	-	-	X	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**RC FLYWHEEL-CS-31-DCC**

REACTOR COOLANT PUMP NO. 24

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	PRESSURE RETAINING BOLTING (GREATER THAN 2") (FIG NO A-82)													
155100	PUMP BOLTS, 1 THROUGH 24	B-G-1	UT	1 -	-	-	-	-	-	-	C	-	-	
		B6.180		2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378042 (PUMP STUD)**
155130	PUMP BOLTS (12 - 2" BOLTS) LOWER SEAL HOUSING BOLTS	B-G-2	VT-1	1 -	-	-	-	-	-	-	-	-	-	EXAMINED WHEN REMOVED.
		B7.50		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	SUPPORT COMPONENT													
155150	SUPPORT LUG NO. 1	B-K-1	PT	1 -	-	-	-	-	-	-	-	-	-	UT OF WELD NOT FEASIBLE DUE TO
		B10.20		2 -	-	-	-	-	-	-	-	-	-	ATTENUATIVE PROPERTIES OF PUMP
				3 -	-	-	-	-	-	-	-	-	-	CASING MATERIAL.
				4 -	-	-	-	-	-	-	-	-	-	
155200	SUPPORT LUG NO. 2	B-K-1	PT	1 -	-	-	-	-	-	-	-	-	-	UT OF WELD NOT FEASIBLE DUE TO
		B10.20		2 -	-	-	-	-	-	-	-	-	-	ATTENUATIVE PROPERTIES OF PUMP
				3 -	-	-	-	-	-	-	-	-	-	CASING MATERIAL.
				4 -	-	-	-	-	-	-	-	-	-	
155250	SUPPORT LUG NO. 3	B-K-1	PT	1 -	-	-	-	-	-	-	-	-	-	UT OF WELD NOT FEASIBLE DUE TO
		B10.20		2 -	-	-	-	-	-	-	-	-	-	ATTENUATIVE PROPERTIES OF PUMP
				3 -	-	-	-	-	-	-	-	-	-	CASING MATERIAL.
				4 -	-	-	-	-	-	-	-	-	-	
	CIRCUMFERENTIAL WELDS													
155450	PUMP CASING WELD	B-L-1	RT	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION TO BE PEFORMED IN
		B12.10		2 -	-	-	-	-	-	-	-	-	-	ACCORDANCE WITH CC-N-481.
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT PUMP NO. 24

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	PUMP INTERNALS													
155500	PUMP CASING INTERNAL SURFACE	B-L-2	VT-3	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION TO BE PEFORMED IN
		B12.20		2 -	-	-	-	-	-	-	-	-	-	ACCORDANCE WITH CC-N-481.
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
155510	PUMP FLANGE SURFACE	B-G-1	VT-1	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION TO BE PEFORMED IN
		B6.190		2 -	-	-	-	-	-	-	-	-	-	ACCORDANCE WITH CC-N-481.
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	PUMP FLYWHEEL													
155550	FLYWHEEL	--	UT	1 -	-	-	-	C	-	-	-	-	-	
	(IN PLACE)	RG1.14		2 -	-	-	C	-	-	-	-	X	-	
	CONT. L4			3 -	-	-	X	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	**RC FLYWHEEL-CS-31-DCC**
155600	FLYWHEEL	--	PT	1 -	C	-	-	-	-	-	-	-	-	PT OF BORE AND MT OF ALL
	(WHEN REMOVED)	RG1.14	MT	2 C	-	-	-	-	-	-	-	-	-	REMAINING ACCESSIBLE SURFACES.
			UT	3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**RC FLYWHEEL-CS-31-DCC**

VALVE PRESSURE RETAINING BOLTING (2" AND LESS)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-RC-25 (FIG NO A-23)														
220000	SV-45C	B-G-2	VT-1	1	-	C	C	-	C	-	-	-	-	-	
	FLANGE BOLTING	B7.70		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-26 (FIG NO A-24)														
220100	SV-45B	B-G-2	VT-1	1	-	-	-	C	C	-	-	-	-	-	
	FLANGE BOLTING	B7.70		2	-	-	-	C	-	-	-	-	-	-	
	PRESS. DH			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-27 (FIG NO A-25)														
220200	SV-45A	B-G-2	VT-1	1	-	-	-	-	C	-	-	C	-	-	
	FLANGE BOLTING	B7.70		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-56 (FIG NO A-47)														
220250	SI-161-L1	B-G-2	VT-1	1	-	C	-	-	-	-	-	-	-	-	
	FLANGE BOLTING	B7.70		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
220300	SI-166-1	B-G-2	VT-1	1	-	C	C	-	-	-	-	-	-	-	
	FLANGE BOLTING	B7.70		2	-	-	-	C	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
220500	SI-170-L1	B-G-2	VT-1	1	-	-	-	-	-	-	-	C	-	-	
	FLANGE BOLTING	B7.70		2	-	-	-	C	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

VALVE PRESSURE RETAINING BOLTING (2" AND LESS)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
						OUTAGE		
					1 2 3	1 2 3 4	1 2 3	
	LINE 2-SI-57 (FIG NO A-48)							
220550	SI-161-L2	B-G-2	VT-1	1	- - -	- C - -	- - -	
	FLANGE BOLTING	B7.70		2	- - -	C - - -	- - -	
	CONT. L2			3	- - -	X - - -	- - -	
				4	- - -	- - - -	- - -	
220600	SI-166-2	B-G-2	VT-1	1	- C C	- - - -	- - -	
	FLANGE BOLTING	B7.70		2	- - -	- - - -	C - -	
	CONT. L2			3	- - -	- - - -	X - -	
				4	- - -	- - - -	- - -	
220700	SI-170-L2	B-G-2	VT-1	1	- - -	- C - -	- - -	
	FLANGE BOLTING	B7.70		2	- - -	- - - -	- X -	
	CONT. L2			3	- - -	- - - -	- X -	
				4	- - -	- - - -	- - -	
	LINE 2-SI-58 (FIG NO A-49)							
220750	SI-161-L3	B-G-2	VT-1	1	- - -	- - - -	- - -	
	FLANGE BOLTING	B7.70		2	- - -	C - - -	- - -	
	CONT. L3			3	- X -	- - - -	- - -	
				4	- - -	- - - -	- - -	
220800	SI-166-3	B-G-2	VT-1	1	- - -	- - - -	C - -	
	FLANGE BOLTING	B7.70		2	- - -	C - - -	- - -	
	ANNULUS			3	- X -	- - - -	- - -	
				4	- - -	- - - -	- - -	
220900	SI-170-L3	B-G-2	VT-1	1	- C C	- - - -	- - -	
	FLANGE BOLTING	B7.70		2	- - -	C - - -	- - -	
	CONT. L3			3	- - -	X - - -	- - -	
				4	- - -	- - - -	- - -	
	LINE 2-SI-59 (FIG NO A-50)							
221000	SI-161-L4	B-G-2	VT-1	1	- - -	- C - -	- - -	
	FLANGE BOLTING	B7.70		2	- - -	- C - -	- - -	
	CONT. L4			3	- - -	- X - -	- - -	
				4	- - -	- - - -	- - -	

VALVE PRESSURE RETAINING BOLTING (2" AND LESS)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-59 (FIG NO A-50)															
221100	SI-166-4	B-G-2	VT-1	1	-	-	-	-	-	-	-	-	C	-	-	
	FLANGE BOLTING	B7.70		2	-	-	-	-	-	-	-	-	C	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	
221200	SI-170-L4	B-G-2	VT-1	1	-	C	-	C	-	-	-	-	-	-	-	
	FLANGE BOLTING	B7.70		2	-	-	-	-	-	-	-	-	-	X	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-60 (FIG NO A-51)															
221400	IMO-315	B-G-2	VT-1	1	-	-	-	-	-	-	-	-	C	-	-	
	FLANGE BOLTING	B7.70		2	C	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-60 (FIG NO A-52)															
221450	SI-158-L4	B-G-2	VT-1	1	-	-	-	-	C	-	-	-	-	-	-	
	FLANGE BOLTING	B7.70		2	-	-	-	C	-	-	-	-	-	-	-	
	CONT. L4			3	-	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-61 (FIG NO A-53)															
221500	SI-158-L1	B-G-2	VT-1	1	-	C	C	-	-	-	-	-	-	-	-	
	FLANGE BOLTING	B7.70		2	-	-	-	C	-	-	-	-	-	-	-	
	CONT. L1			3	-	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-62 (FIG NO A-54)															
221550	IMO-325	B-G-2	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	
	FLANGE BOLTING	B7.70		2	-	-	-	C	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	X	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	

VALVE PRESSURE RETAINING BOLTING (2" AND LESS)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-SI-62 (FIG NO A-54)														
221600	SI-158-L3	B-G-2	VT-1	1	-	-	-	-	C	-	-	-	-	-	
	FLANGE BOLTING	B7.70		2	-	-	-	-	-	-	-	C	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-63 (FIG NO A-56)														
221800	SI-158-L2	B-G-2	VT-1	1	-	C	C	-	-	-	-	-	-	-	
	FLANGE BOLTING	B7.70		2	-	-	-	-	-	-	-	-	X	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RH-31 (FIG NO A-75)														
222200	RH-134	B-G-2	VT-1	1	-	-	-	C	-	-	-	-	-	-	
	FLANGE BOLTING	B7.70		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RH-32 (FIG NO A-76)														
222300	RH-133	B-G-2	VT-1	1	-	-	-	-	-	-	-	C	-	-	
	FLANGE BOLTING	B7.70		2	-	-	-	C	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RH-33 (FIG NO A-77)														
222400	IMO-128	B-G-2	VT-1	1	-	C	C	-	-	-	-	-	-	-	
	FLANGE BOLTING	B7.70		2	-	-	-	C	-	-	-	-	-	-	
	CONT. L2			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
222500	ICM-129	B-G-2	VT-1	1	-	-	-	C	-	-	-	-	-	-	
	FLANGE BOLTING	B7.70		2	-	-	-	-	C	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

CROSBY SAFETY VALVES (6" NOMINAL)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1 2 3	SECOND PERIOD OUTAGE 1 2 3 4	THIRD PERIOD 1 2 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-25 (FIG NO A-23)							
224000	SV-45C	B-M-2	VT-3	1	- - -	- - - -	- - -	ONE CROSBY SAFETY VALVE TO BE
	VALVE BODY INTERNAL SURFACE	B12.50		2	- - -	- - - -	- - -	EXAMINED BY I&M PERSONNEL
				3	- - -	- - - -	- - -	DURING THE INTERVAL. THE
				4	- - -	- - - -	- - -	CHOICE DEPENDS ON MAINTENANCE REQUIREMENTS.
	LINE 2-RC-26 (FIG NO A-24)							
224100	SV-45B	B-M-2	VT-3	1	- - -	- - - -	- - -	
	VALVE BODY INTERNAL SURFACE	B12.50		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	LINE 2-RC-27 (FIG NO A-25)							
224200	SV-45A	B-M-2	VT-3	1	- - -	- - - -	- - -	
	VALVE BODY INTERNAL SURFACE	B12.50		2	C - -	- - - -	- - -	
				3	X - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

ALOYCO SWING CHECK VALVES (6" NOMINAL)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
					1 2 3	1 2 3 4	1 2 3	
	LINE 2-SI-56 (FIG NO A-47)							
224700	SI-161-L1	B-M-2	VT-3	1	- - -	- - - -	- - -	ONE 6" ALOYCO SWING CHECK
	VALVE BODY INTERNAL SURFACE	B12.50		2	- - -	- - - -	- - -	VALVE TO BE EXAMINED BY I&M
				3	- - -	- - - -	- - -	PERSONNEL DURING THE INTERVAL.
				4	- - -	- - - -	- - -	THE CHOICE DEPENDS ON
								MAINTENANCE REQUIREMENTS.
	LINE 2-SI-57 (FIG NO A-48)							
224800	SI-161-L2	B-M-2	VT-3	1	- - -	- - - -	- - -	
	VALVE BODY INTERNAL SURFACE	B12.50		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	LINE 2-SI-58 (FIG NO A-49)							
224900	SI-161-L3	B-M-2	VT-3	1	- - -	- - - -	- - -	
	VALVE BODY INTERNAL SURFACE	B12.50		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	LINE 2-SI-59 (FIG NO A-50)							
225000	SI-161-L4	B-M-2	VT-3	1	- - -	- - - -	- - -	
	VALVE BODY INTERNAL SURFACE	B12.50		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	LINE 2-SI-60 (FIG NO A-52)							
225050	SI-158-L4	B-M-2	VT-3	1	- - -	- - - -	- - -	
	VALVE BODY INTERNAL SURFACE	B12.50		2	C - -	C - - -	- - -	
	CONT. L4			3	- - -	X - - -	- - -	
				4	- - -	- - - -	- - -	

ALOYCO SWING CHECK VALVES (6" NOMINAL)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-62 (FIG NO A-55)														
225100	SI-158-L3	B-M-2	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	VALVE BODY INTERNAL SURFACE	B12.50		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-63 (FIG NO A-56)														
225150	SI-158-L2	B-M-2	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	VALVE BODY INTERNAL SURFACE	B12.50		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-61 (FIG NO A-53)														
225200	SI-158-L1	B-M-2	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	VALVE BODY INTERNAL SURFACE	B12.50		2	C	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

WALWORTH MOTOR-OPERATED GATE VALVES (8" NOMINAL)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-60 (FIG NO A-51)													
225300	SI-IMO-315	B-M-2	VT-3	1	-	-	-	-	-	-	-	-	-	ONE WALWORTH GATE VALVE TO BE
	VALVE BODY INTERNAL SURFACE	B12.50		2	-	-	-	-	-	-	-	X	-	EXAMINED BY I&M PERSONNEL
	ANNULUS			3	-	-	-	-	-	-	-	X	-	DURING THE INTERVAL. THE
				4	-	-	-	-	-	-	-	-	-	CHOICE DEPENDS ON MAINTENANCE REQUIREMENTS.
	LINE 2-SI-62 (FIG NO A-54)													
225400	SI-IMO-325	B-M-2	VT-3	1	-	-	-	-	-	-	-	-	-	
	VALVE BODY INTERNAL SURFACE	B12.50		2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

DARLING SWING CHECK VALVES (10" NOMINAL)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD			INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-56 (FIG NO A-47)																
225700	SI-166-1	B-M-2	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	ONE 10" DARLING SWING CHECK
	VALVE BODY INTERNAL SURFACE	B12.50		2	C	-	-	-	-	-	-	-	-	-	-	-	VALVE TO BE EXAMINED BY I&M
				3	X	-	-	-	-	-	-	-	-	-	-	-	PERSONNEL DURING THE INTERVAL.
				4	-	-	-	-	-	-	-	-	-	-	-	-	THE CHOICE DEPENDS ON
																	MAINTENANCE REQUIREMENTS.
225750	SI-170-L1	B-M-2	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	VALVE BODY INTERNAL SURFACE	B12.50		2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-57 (FIG NO A-48)																
225800	SI-166-2	B-M-2	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	VALVE BODY INTERNAL SURFACE	B12.50		2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
225850	SI-170-L2	B-M-2	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	VALVE BODY INTERNAL SURFACE	B12.50		2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-58 (FIG NO A-49)																
225900	SI-166-3	B-M-2	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	VALVE BODY INTERNAL SURFACE	B12.50		2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
225950	SI-170-L3	B-M-2	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	VALVE BODY INTERNAL SURFACE	B12.50		2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	

DARLING SWING CHECK VALVES (10" NOMINAL)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-SI-59 (FIG NO A-50)														
226000	SI-166-4	B-M-2	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	VALVE BODY INTERNAL SURFACE	B12.50		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
226050	SI-170-L4	B-M-2	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	VALVE BODY INTERNAL SURFACE	B12.50		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

DARLING SWING CHECK VALVES (8" NOMINAL)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD			INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-31 (FIG NO A-75)																
226200	RH-134	B-M-2	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	ONE 8" DARLING SWING CHECK
	VALVE BODY INTERNAL SURFACE	B12.50		2	C	-	-	-	-	-	-	-	-	-	-	-	VALVE TO BE EXAMINED BY I&M
				3	X	-	-	-	-	-	-	-	-	-	-	-	PERSONNEL DURING THE INTERVAL.
				4	-	-	-	-	-	-	-	-	-	-	-	-	THE CHOICE DEPENDS ON
																	MAINTENANCE REQUIREMENTS.
	LINE 2-RH-32 (FIG NO A-76)																
226300	RH-133	B-M-2	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	VALVE BODY INTERNAL SURFACE	B12.50		2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	

COPES VULCAN MOTOR-OPERATED GATE VALVES (14"NOMINA

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	FIRST PERIOD 2	3	OUTAGE 1	SECOND PERIOD 2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-33 (FIG NO A-77)													
226400	RH-IMO-128	B-M-2	VT-3	1	-	-	-	-	-	-	-	-	-	ONE COPES VULCAN GATE VALVE TO
	VALVE BODY INTERNAL SURFACE	B12.50		2	C	-	-	-	-	-	-	-	-	BE EXAMINED BY I&M PERSONNEL
				3	-	-	-	X	-	-	-	-	-	DURING THE INTERVAL. THE
				4	-	-	-	-	-	-	-	-	-	CHOICE DEPENDS ON MAINTENANCE REQUIREMENTS.
226500	RH-ICM-129	B-M-2	VT-3	1	-	-	-	-	-	-	-	-	-	
	VALVE BODY INTERNAL SURFACE	B12.50		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

STEAM GENERATOR NO. 21 (FIGURE B-1)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1 (OUTAGE)	SECOND PERIOD 2 (OUTAGE)	SECOND PERIOD 3 (OUTAGE)	SECOND PERIOD 4 (OUTAGE)	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	CIRCUMFERENTIAL WELDS													
300000	STM-21-04	C-A	UT	1	-	-	C	-	-	-	-	-	-	
	TUBE SHEET TO STUB BARREL	C1.30		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**PL-3.0-CS-22-DCC**
300010	STM-21-05	C-A	UT	1	-	-	-	-	-	-	-	-	-	
	STUB BARREL TO SHELL	C1.10		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**PL-3.0-CS-22-DCC**
300020	STM-21-06	C-A	SEE	1	-	-	-	-	-	-	-	-	-	NO EXAMINATION REQUIRED FOR
	SHELL TO SHELL	C1.10	INST	2	-	-	-	-	-	-	-	-	-	WELDS WITH IDENTICAL SHELL
				3	-	-	-	-	-	-	-	-	-	COURSE THICKNESSES AND WITH NO
				4	-	-	-	-	-	-	-	-	-	GROSS STRUCTURAL DISCONTINUITY. **PL-3.0-CS-22-DCC**
300030	STM-21-07	C-A	SEE	1	-	-	-	-	-	-	-	-	-	
	SHELL TO TRANSITION CONE	C1.10	INST	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**PL-3.0-CS-22-DCC**
300040	STM-21-08	C-A	SEE	1	-	-	-	-	-	-	-	-	-	
	TRANSITION CONE TO SHELL	C1.10	INST	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**PL-3.0-CS-22-DCC**
300050	STM-21-09	C-A	SEE	1	-	-	-	-	-	-	-	-	-	NO EXAMINATION REQUIRED FOR
	SHELL TO SHELL	C1.10	INST	2	-	-	-	-	-	-	-	-	-	WELDS WITH IDENTICAL SHELL
				3	-	-	-	-	-	-	-	-	-	COURSE THICKNESSES AND WITH NO
				4	-	-	-	-	-	-	-	-	-	GROSS STRUCTURAL DISCONTINUITY. **PL-3.0-CS-22-DCC**

STEAM GENERATOR NO. 21 (FIGURE B-1)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	CIRCUMFERENTIAL WELDS														
300060	STM-21-10	C-A	UT	1	-	-	-	-	-	-	-	-	-	-	
	SHELL TO HEAD	C1.20		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**CAL. BLK. TO BE DETERMINED**
	NOZZLE TO SHELL AND SHELL TO NOZZLE WELDS														
300070	STM-21-FWN	C-B	MT	1	-	-	-	-	-	-	-	-	-	-	
	NOZZLE TO SHELL	C2.21	UT	2	-	-	-	-	C	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**PL-3.0-CS-22-DCC**
300080	STM-21-MSN	C-B	MT	1	-	-	-	C	-	-	-	-	-	-	
	SHELL TO NOZZLE	C2.21	UT	2	-	-	-	C	-	-	-	-	-	-	
	CONT. L1			3	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**PL-3.0-CS-22-DCC**
	INSIDE RADIUS SECTIONS														
300090	STM-21-FWN-IRS	C-B	UT	1	-	-	-	-	-	-	-	-	-	-	
		C2.22		2	-	-	-	C	-	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**IR-CS-33-DCC**
300100	STM-21-MSN-IRS	C-B	UT	1	-	-	-	-	-	-	-	-	-	-	
		C2.22		2	-	-	-	C	-	-	-	-	-	-	
	CONT. L1			3	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**IR-CS-33-DCC**

STEAM GENERATOR NO. 22 (FIGURE B-2)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1 2 3	PLAN STATUS FIRST PERIOD 1 2 3	SECOND PERIOD 1 2 3 4	THIRD PERIOD 1 2 3	INSTRUCTIONS **CALIBRATION BLOCK**
	CIRCUMFERENTIAL WELDS							
300110	STM-22-04	C-A	UT	1 - - -	- - -	- - - -	- - -	
	TUBE SHEET TO STUB BARREL	C1.30		2 - - -	- - -	- - - -	- - -	
				3 - - -	- - -	- - - -	- - -	
				4 - - -	- - -	- - - -	- - -	**PL-3.0-CS-22-DCC**
300120	STM-22-05	C-A	UT	1 - - -	- - -	- - - -	- - -	
	STUB BARREL TO SHELL	C1.10		2 - - -	- - -	- - - -	- - -	
				3 - - -	- - -	- - - -	- - -	
				4 - - -	- - -	- - - -	- - -	**PL-3.0-CS-22-DCC**
300130	STM-22-06	C-A	SEE	1 - - -	- - -	- - - -	- - -	NO EXAMINATION REQUIRED FOR
	SHELL TO SHELL	C1.10	INST	2 - - -	- - -	- - - -	- - -	WELDS WITH IDENTICAL SHELL
				3 - - -	- - -	- - - -	- - -	COURSE THICKNESSES AND WITH NO
				4 - - -	- - -	- - - -	- - -	GROSS STRUCTURAL
								DISCONTINUITY.
								PL-3.0-CS-22-DCC
300140	STM-22-07	C-A	SEE	1 - - -	- - -	- - - -	- - -	
	SHELL TO TRANSITION CONE	C1.10	INST	2 - - -	- - -	- - - -	- - -	
				3 - - -	- - -	- - - -	- - -	
				4 - - -	- - -	- - - -	- - -	**PL-3.0-CS-22-DCC**
300150	STM-22-08	C-A	SEE	1 - - -	- - -	- - - -	- - -	
	TRANSITION CONE TO SHELL	C1.10	INST	2 - - -	- - -	- - - -	- - -	
				3 - - -	- - -	- - - -	- - -	
				4 - - -	- - -	- - - -	- - -	**PL-3.0-CS-22-DCC**
300160	STM-22-09	C-A	SEE	1 - - -	- - -	- - - -	- - -	NO EXAMINATION REQUIRED FOR
	SHELL TO SHELL	C1.10	INST	2 - - -	- - -	- - - -	- - -	WELDS WITH IDENTICAL SHELL
				3 - - -	- - -	- - - -	- - -	COURSE THICKNESSES AND WITH NO
				4 - - -	- - -	- - - -	- - -	GROSS STRUCTURAL
								DISCONTINUITY.
								PL-3.0-CS-22-DCC

STEAM GENERATOR NO. 22 (FIGURE B-2)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	CIRCUMFERENTIAL WELDS													
300170	STM-22-10	C-A	UT	1	-	-	-	-	-	-	-	-	-	
	SHELL TO HEAD	C1.20		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**CAL. BLK. TO BE DETERMINED**
	NOZZLE TO SHELL AND SHELL TO NOZZLE WELDS													
300180	STM-22-FWN	C-B	MT	1	-	-	-	-	-	-	-	-	-	
	NOZZLE TO SHELL	C2.21	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**PL-3.0-CS-22-DCC**
300190	STM-22-MSN	C-B	MT	1	-	-	-	-	-	-	-	-	-	
	SHELL TO NOZZLE	C2.21	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**PL-3.0-CS-22-DCC**
	INSIDE RADIUS SECTIONS													
300200	STM-22-FWN-IRS	C-B	UT	1	-	-	-	-	-	-	-	-	-	
		C2.22		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**IR-CS-33-DCC**
300210	STM-22-MSN-IRS	C-B	UT	1	-	-	-	-	-	-	-	-	-	
		C2.22		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**IR-CS-33-DCC**

STEAM GENERATOR NO. 23 (FIGURE B-3)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	CIRCUMFERENTIAL WELDS													
300220	STM-23-04	C-A	UT	1	-	-	-	-	-	-	-	-	-	
	TUBE SHEET TO STUB BARREL	C1.30		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**PL-3.0-CS-22-DCC**
300230	STM-23-05	C-A	UT	1	-	-	-	-	-	-	-	-	-	
	STUB BARREL TO SHELL	C1.10		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**PL-3.0-CS-22-DCC**
300240	STM-23-06	C-A	SEE	1	-	-	-	-	-	-	-	-	-	NO EXAMINATION REQUIRED FOR
	SHELL TO SHELL	C1.10	INST	2	-	-	-	-	-	-	-	-	-	WELDS WITH IDENTICAL SHELL
				3	-	-	-	-	-	-	-	-	-	COURSE THICKNESSES AND WITH NO
				4	-	-	-	-	-	-	-	-	-	GROSS STRUCTURAL
														DISCONTINUITY.
														PL-3.0-CS-22-DCC
300250	STM-23-07	C-A	SEE	1	-	-	-	-	-	-	-	-	-	
	SHELL TO TRANSITION CONE	C1.10	INST	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**PL-3.0-CS-22-DCC**
300260	STM-23-08	C-A	SEE	1	-	-	-	C	-	-	-	-	-	
	TRANSITION CONE TO SHELL	C1.10	INST	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**PL-3.0-CS-22-DCC**
300270	STM-23-09	C-A	SEE	1	-	-	-	-	-	-	-	-	-	NO EXAMINATION REQUIRED FOR
	SHELL TO SHELL	C1.10	INST	2	-	-	-	-	-	-	-	-	-	WELDS WITH IDENTICAL SHELL
				3	-	-	-	-	-	-	-	-	-	COURSE THICKNESSES AND WITH NO
				4	-	-	-	-	-	-	-	-	-	GROSS STRUCTURAL
														DISCONTINUITY.
														PL-3.0-CS-22-DCC

STEAM GENERATOR NO. 23 (FIGURE B-3)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY / ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1 2 3	SECOND PERIOD 1 2 3 4	THIRD PERIOD 1 2 3	INSTRUCTIONS **CALIBRATION BLOCK**
	CIRCUMFERENTIAL WELDS						
300280	STM-23-10	C-A	UT	1 - - -	- - - -	- - -	
	SHELL TO HEAD	C1.20		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**CAL. BLK. TO BE DETERMINED**
	NOZZLE TO SHELL AND SHELL TO NOZZLE WELDS						
300290	STM-23-FWN	C-B	MT	1 - - -	- - - -	- - -	
	NOZZLE TO SHELL	C2.21	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**PL-3.0-CS-22-DCC**
300300	STM-23-MSN	C-B	MT	1 - - -	- - - -	- - -	
	SHELL TO NOZZLE	C2.21	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**PL-3.0-CS-22-DCC**
	INSIDE RADIUS SECTIONS						
300310	STM-23-FWN-IRS	C-B	UT	1 - - -	- - - -	- - -	
		C2.22		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**IR-CS-33-DCC**
300320	STM-23-MSN-IRS	C-B	UT	1 - - -	- - - -	- - -	
		C2.22		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**IR-CS-33-DCC**

STEAM GENERATOR NO. 24 (FIGURE B-4)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD			SECOND PERIOD				THIRD PERIOD			INSTRUCTIONS **CALIBRATION BLOCK**
								OUTAGE							
					1	2	3	1	2	3	4	1	2	3	
	CIRCUMFERENTIAL WELDS														
300330	STM-24-04	C-A	UT	1	-	-	-	-	-	-	-	-	-	-	
	TUBE SHEET TO STUB BARREL	C1.30		2	-	-	-	-	C	-	-	-	-	-	
	CONT. L4			3	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**PL-3.0-CS-22-DCC**
300340	STM-24-05	C-A	UT	1	-	-	-	-	-	-	-	-	-	-	
	STUB BARREL TO SHELL	C1.10		2	-	-	-	-	-	-	-	C	-	-	
	CONT. L4			3	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**PL-3.0-CS-22-DCC**
300350	STM-24-06	C-A	SEE	1	-	-	-	-	-	-	-	-	-	-	NO EXAMINATION REQUIRED FOR
	SHELL TO SHELL	C1.10	INST	2	-	-	-	-	-	-	-	-	-	-	WELDS WITH IDENTICAL SHELL
				3	-	-	-	-	-	-	-	-	-	-	COURSE THICKNESSES AND WITH NO
				4	-	-	-	-	-	-	-	-	-	-	GROSS STRUCTURAL
															DISCONTINUITY.
															PL-3.0-CS-22-DCC
300360	STM-24-07	C-A	SEE	1	-	-	-	-	-	-	-	-	-	-	
	SHELL TO TRANSITION CONE	C1.10	INST	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**PL-3.0-CS-22-DCC**
300370	STM-24-08	C-A	SEE	1	-	-	-	-	-	-	-	-	-	-	
	TRANSITION CONE TO SHELL	C1.10	INST	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**PL-3.0-CS-22-DCC**
300380	STM-24-09	C-A	SEE	1	-	-	-	-	-	-	-	-	-	-	NO EXAMINATION REQUIRED FOR
	SHELL TO SHELL	C1.10	INST	2	-	-	-	-	-	-	-	-	-	-	WELDS WITH IDENTICAL SHELL
				3	-	-	-	-	-	-	-	-	-	-	COURSE THICKNESSES AND WITH NO
				4	-	-	-	-	-	-	-	-	-	-	GROSS STRUCTURAL
															DISCONTINUITY.
															PL-3.0-CS-22-DCC

STEAM GENERATOR NO. 24 (FIGURE B-4)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	CIRCUMFERENTIAL WELDS													
300390	STM-24-10	C-A	UT	1	-	-	-	-	-	-	-	-	-	
	SHELL TO HEAD	C1.20		2	-	-	-	-	-	-	-	X	-	
	CONT. L4			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	**CAL. BLK. TO BE DETERMINED**
	NOZZLE TO SHELL AND SHELL TO NOZZLE WELDS													
300400	STM-24-FWN	C-B	MT	1	-	-	-	-	-	-	-	-	-	
	NOZZLE TO SHELL	C2.21	UT	2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**PL-3.0-CS-22-DCC**
300410	STM-24-MSN	C-B	MT	1	-	-	-	-	-	-	-	-	-	
	SHELL TO NOZZLE	C2.21	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**PL-3.0-CS-22-DCC**
	INSIDE RADIUS SECTIONS													
300420	STM-24-FWN-IRS	C-B	UT	1	-	-	-	-	-	-	-	-	-	
		C2.22		2	-	-	-	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**IR-CS-33-DCC**
300430	STM-24-MSN-IRS	C-B	UT	1	-	-	-	-	-	-	-	-	-	
		C2.22		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**IR-CS-33-DCC**

REGENERATIVE HEAT EXCHANGER (FIGURE B-5)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	CIRCUMFERENTIAL WELDS													
300440	RHE-2-02	C-A	UT	1	-	-	C	-	-	-	-	-	-	
	CAP TO SHELL	C1.20		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**9.625-CCSS-X-1.0-2-DCC**
300450	RHE-2-03	C-A	UT	1	-	-	-	-	-	-	-	-	-	
	SHELL TO TUBE SHEET	C1.30		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**9.625-CCSS-X-1.0-2-DCC**
300460	RHE-2-08	C-A	UT	1	-	-	-	-	-	-	-	-	-	
	CAP TO SHELL	C1.20		2	-	-	-	C	-	-	-	-	-	
	REGEN HXRM			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**9.625-CCSS-X-1.0-2-DCC**
300470	RHE-2-09	C-A	UT	1	-	-	-	-	-	-	-	-	-	
	SHELL TO TUBE SHEET	C1.30		2	-	-	-	C	-	-	-	-	-	
	REGEN HXRM			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**9.625-CCSS-X-1.0-2-DCC**
300480	RHE-2-14	C-A	UT	1	-	-	-	-	-	-	-	-	-	
	CAP TO SHELL	C1.20		2	-	-	-	-	-	-	C	-	-	
	REGEN HXRM			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**9.625-CCSS-X-1.0-2-DCC**
300490	RHE-2-15	C-A	UT	1	-	-	-	-	-	-	-	-	-	
	SHELL TO TUBE SHEET	C1.30		2	-	-	-	-	-	-	C	-	-	
	REGEN HXRM			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**9.625-CCSS-X-1.0-2-DCC**
300500	RHE-2-17	C-A	UT	1	-	-	-	-	-	-	-	-	-	
	TUBE SHEET TO SHELL	C1.30		2	-	-	-	-	-	-	C	-	-	
	REGEN HXRM			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**9.625-CCSS-X-1.0-2-DCC**

REGENERATIVE HEAT EXCHANGER (FIGURE B-5)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	CIRCUMFERENTIAL WELDS														
300510	RHE-2-20	C-A	UT	1	-	-	-	-	-	-	-	-	-	-	
	SHELL TO CAP	C1.20		2	-	-	-	-	-	-	-	C	-	-	
	REGEN HXRM			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**9.625-CCSS-X-1.0-2-DCC**
300520	RHE-2-21	C-A	UT	1	-	-	-	C	-	-	-	-	-	-	
	TUBE SHEET TO SHELL	C1.30		2	-	-	-	-	C	-	-	-	-	-	
	REGEN HXRM			3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**9.625-CCSS-X-1.0-2-DCC**
300530	RHE-2-24	C-A	UT	1	-	-	-	-	-	-	-	-	-	-	
	SHELL TO CAP	C1.20		2	-	-	-	-	C	-	-	-	-	-	
	REGEN HXRM			3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**9.625-CCSS-X-1.0-2-DCC**
300540	RHE-2-25	C-A	UT	1	-	-	-	-	-	-	-	-	-	-	
	TUBE SHEET TO SHELL	C1.30		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**9.625-CCSS-X-1.0-2-DCC**
300550	RHE-2-28	C-A	UT	1	-	-	-	-	-	-	-	-	-	-	
	SHELL TO CAP	C1.20		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**9.625-CCSS-X-1.0-2-DCC**

CHEMICAL AND VOLUME CONTROL TANK (FIGURE B-6)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
					1 2 3	1 2 3 4	1 2 3	
	CIRCUMFERENTIAL WELDS							
300620	2-CVCT-1	C-A	UT	1	- - -	- - - -	- - -	
	UPPER HEAD TO SHELL	C1.20		2	C - -	- - - -	- - -	
				3	X - -	- - - -	- - -	
				4	- - -	- - - -	- - -	**PL-.312-SS-23-DCC**
300630	2-CVCT-2	C-A	UT	1	- - -	- - - -	- - -	
	SHELL TO LOWER HEAD	C1.20		2	- - -	C - - -	- - -	
	VCT RM			3	X - -	- - - -	- - -	
				4	- - -	- - - -	- - -	**PL-.312-SS-23R-DCC**
	INTEGRALLY WELDED VESSEL SUPPORTS							
300640	2-CVCT-2VS-1, 2, & 3	C-C	PT	1	- - -	- - - -	C - -	
		C3.10		2	C - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
300650	2-CVCT-2VS-4, 5, & 6	C-C	PT	1	- - -	- - - -	- - -	
		C3.10		2	- - -	C - - -	- - -	
	VCT RM			3	- - -	X - - -	- - -	
				4	- - -	- - - -	- - -	
300660	2-CVCT-2VS-7, 8, & 9	C-C	PT	1	- - -	- - - -	- - -	
		C3.10		2	- - -	- - - -	C - -	
	VCT RM			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
300670	2-CVCT-2VS-10, 11, & 12	C-C	PT	1	- - -	- - - -	- - -	
		C3.10		2	- - -	- - - -	- X -	
	VCT RM			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

CTS HEAT EXCHANGER EAST (FIGURE B-7)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	CIRCUMFERENTIAL WELDS														
300671	E-CTSHEX-1	C-A	UT	1	-	-	-	-	-	-	-	-	-	-	
	TUBE SHEET TO SHELL	C1.30		2	-	-	-	C	-	-	-	-	-	-	
	E CTS HXRM			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**SS-25-DCC/CS-37-DCC**
300672	E-CTSHEX-2	C-A	UT	1	-	-	-	-	-	-	-	-	-	-	
	SHELL TO FLANGE	C1.10		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**PL-.500-SS-25-DCC**
	NOZZLE TO SHELL AND SHELL TO NOZZLE WELDS														
300673	E-CTSHEX-IN	C-B	PT	1	-	-	-	-	-	-	-	-	-	-	
	NOZZLE TO SHELL	C2.11		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
300674	E-CTSHEX-OUT	C-B	PT	1	-	-	-	-	-	-	-	-	-	-	
	SHELL TO NOZZLE	C2.11		2	-	-	-	-	-	-	-	-	X	-	
	E CTS HXRM			3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	

CTS HEAT EXCHANGER WEST (FIGURE B-8)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	CIRCUMFERENTIAL WELDS													
300679	W-CTSHEX-1	C-A	UT	1	-	-	-	-	-	-	-	-	-	
	TUBE SHEET TO SHELL	C1.30		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**SS-25-DCC/CS-37-DCC**
300680	W-CTSHEX-2	C-A	UT	1	-	-	-	-	-	-	-	-	-	
	SHELL TO FLANGE	C1.10		2	-	-	-	-	-	-	C	-	-	
	W CTS HXRM			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**PL-.500-SS-25-DCC**
	NOZZLE TO SHELL AND SHELL TO NOZZLE WELDS													
300681	W-CTSHEX-IN	C-B	PT	1	-	-	-	-	-	-	-	-	-	
	NOZZLE TO SHELL	C2.11		2	-	-	-	-	-	-	C	-	-	
	W CTS HXRM			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	
300682	W-CTSHEX-OUT	C-B	PT	1	-	-	-	-	-	-	-	-	-	
	SHELL TO NOZZLE	C2.11		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

RHR HEAT EXCHANGER EAST (FIGURE B-9)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	CIRCUMFERENTIAL WELDS													
300689	E-RHRHEX-1	C-A	UT	1 -	-	-	-	-	-	-	C	-	-	
	FLANGE TO SHELL	C1.10		2 -	-	-	C	-	-	-	-	-	-	
	E RHR HXRM			3 -	X	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**PL-1.000-SS-27-DCC**
300690	E-RHRHEX-2	C-A	UT	1 -	-	-	-	-	-	-	-	-	-	
	SHELL TO HEAD	C1.20		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**PL-1.000-SS-27-DCC**
	NOZZLE TO SHELL AND SHELL TO NOZZLE WELDS													
300700	E-RHRHEX-IN	C-B	PT	1 -	-	-	-	-	-	-	-	-	-	
	NOZZLE TO SHELL	C2.21	UT	2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	X	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**PL-1.000-SS-27-DCC**
300710	E-RHRHEX-OUT	C-B	PT	1 -	-	-	-	-	-	-	-	-	-	
	SHELL TO NOZZLE	C2.21	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**PL-1.000-SS-27-DCC**
	NOZZLE INSIDE RADIUS SECTIONS													
300720	E-RHRHEX-IN-IRS	C-B	UT	1 -	-	-	-	-	-	-	-	-	-	UT NOT FEASIBLE DUE TO
	INSIDE RADIUS SECTION	C2.22		2 -	-	-	-	-	-	-	-	-	-	CONFIGURATION. RELIEF
				3 -	-	-	-	-	-	-	-	-	-	REQUESTED.
				4 -	-	-	-	-	-	-	-	-	-	
300730	E-RHRHEX-OUT-IRS	C-B	UT	1 -	-	-	-	-	-	-	-	-	-	UT NOT FEASIBLE DUE TO
	INSIDE RADIUS SECTION	C2.22		2 -	-	-	-	-	-	-	-	-	-	CONFIGURATION. RELIEF
				3 -	-	-	-	-	-	-	-	-	-	REQUESTED.
				4 -	-	-	-	-	-	-	-	-	-	

RHR HEAT EXCHANGER EAST (FIGURE B-9)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	INTEGRALLY WELDED VESSEL SUPPORTS													
300740	E-RHRHEX-1VS	C-C	PT	1 -	-	-	-	-	-	-	-	-	-	
	VESSEL SUPPORT	C3.10		2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
300750	E-RHRHEX-2VS	C-C	PT	1 -	-	-	-	-	-	-	-	-	-	
	VESSEL SUPPORT	C3.10		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

RHR HEAT EXCHANGER WEST (FIGURE B-10)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	CIRCUMFERENTIAL WELDS														
300760	W-RHRHEX-1	C-A	UT	1	-	-	-	-	-	-	-	-	-	-	
	FLANGE TO SHELL	C1.10		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**PL-1.000-SS-27-DCC**
300770	W-RHRHEX-2	C-A	UT	1	-	-	-	-	-	-	-	-	-	-	
	SHELL TO HEAD	C1.20		2	-	-	-	-	-	-	-	C	-	-	
	W RHR HXRM			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**PL-1.000-SS-27-DCC**
	NOZZLE TO SHELL AND SHELL TO NOZZLE WELDS														
300780	W-RHRHEX-IN	C-B	PT	1	-	-	-	-	-	-	-	-	-	-	
	NOZZLE TO SHELL	C2.21	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**PL-1.000-SS-27-DCC**
300790	W-RHRHEX-OUT	C-B	PT	1	-	-	-	-	-	-	-	-	-	-	
	SHELL TO NOZZLE	C2.21	UT	2	-	-	-	C	-	-	-	-	-	-	
	W RHR HXRM			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**PL-1.000-SS-27-DCC**
	NOZZLE INSIDE RADIUS SECTIONS														
300800	W-RHRHEX-IN-IRS	C-B	UT	1	-	-	-	-	-	-	-	-	-	-	UT NOT FEASIBLE DUE TO
	INSIDE RADIUS SECTION	C2.22		2	-	-	-	-	-	-	-	-	-	-	CONFIGURATION. RELIEF
				3	-	-	-	-	-	-	-	-	-	-	REQUESTED.
				4	-	-	-	-	-	-	-	-	-	-	
300810	W-RHRHEX-OUT-IRS	C-B	UT	1	-	-	-	-	-	-	-	-	-	-	UT NOT FEASIBLE DUE TO
	INSIDE RADIUS SECTION	C2.22		2	-	-	-	-	-	-	-	-	-	-	CONFIGURATION. RELIEF
				3	-	-	-	-	-	-	-	-	-	-	REQUESTED.
				4	-	-	-	-	-	-	-	-	-	-	

RHR HEAT EXCHANGER WEST (FIGURE B-10)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	INTEGRALLY WELDED VESSEL SUPPORTS													
300820	W-RHRHEX-1VS	C-C	PT	1 -	-	-	-	-	-	-	-	-	-	
	VESSEL SUPPORT	C3.10		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
300830	W-RHRHEX-2VS	C-C	PT	1 -	-	-	-	-	-	-	-	-	-	
	VESSEL SUPPORT	C3.10		2 -	-	-	C	-	-	-	-	-	-	
	W RHR HXRM			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

BORON INJECTION TANK (FIGURE B-11)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	CIRCUMFERENTIAL WELDS														
300840	2-BIT-A	C-A	UT	1	-	-	-	-	-	-	-	C	-	-	
	SHELL TO LOWER HEAD	C1.20		2	-	-	-	C	-	-	-	-	-	-	
	BIT RM			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**PL-3.0-CSCL-4-DCC**
300850	2-BIT-B	C-A	UT	1	-	-	-	-	-	-	-	-	-	-	
	SHELL TO UPPER HEAD	C1.20		2	-	-	-	-	C	-	-	-	-	-	
	BIT RM			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**PL-3.0-CSCL-4-DCC**
	NOZZLE TO SHELL AND SHELL TO NOZZLE WELDS														
300860	2-BIT-INS	C-B	MT	1	-	-	-	-	-	-	-	-	-	-	NO EXAMINATION REQUIRED PER
	INLET NOZZLE TO SHELL	C2.21	UT	2	-	-	-	-	-	-	-	-	-	-	TABLE IWC-2500, CATEGORY C-B,
				3	-	-	-	-	-	-	-	-	-	-	NOTE 2.
				4	-	-	-	-	-	-	-	-	-	-	
300870	2-BIT-ONS	C-B	MT	1	-	-	-	-	-	-	-	-	-	-	NO EXAMINATION REQUIRED PER
	OUTLET NOZZLE TO	C2.21	UT	2	-	-	-	-	-	-	-	-	-	-	TABLE IWC-2500, CATEGORY C-B,
	SHELL			3	-	-	-	-	-	-	-	-	-	-	NOTE 2.
				4	-	-	-	-	-	-	-	-	-	-	
	NOZZLE INSIDE RADIUS SECTIONS														
300880	2-BIT-INS-IRS	C-B	UT	1	-	-	-	-	-	-	-	-	-	-	NO EXAMINATION REQUIRED PER
		C2.22		2	-	-	-	-	-	-	-	-	-	-	FIGURE IWC-2500-4. DIAMETER
				3	-	-	-	-	-	-	-	-	-	-	LESS THAN 12".
				4	-	-	-	-	-	-	-	-	-	-	
300890	2-BIT-ONS-IRS	C-B	UT	1	-	-	-	-	-	-	-	-	-	-	NO EXAMINATION REQUIRED PER
		C2.22		2	-	-	-	-	-	-	-	-	-	-	FIGURE IWC-2500-4. DIAMETER
				3	-	-	-	-	-	-	-	-	-	-	LESS THAN 12".
				4	-	-	-	-	-	-	-	-	-	-	

BORON INJECTION TANK (FIGURE B-11)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	INTEGRALLY WELDED VESSEL SUPPORTS														
300900	2-BIT-VS-1	C-C	MT	1	-	-	-	-	-	-	-	C	-	-	
		C3.10		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
300910	2-BIT-VS-2	C-C	MT	1	-	-	-	-	-	-	-	-	-	-	
		C3.10		2	-	-	-	C	-	-	-	-	-	-	
	BIT RM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
300920	2-BIT-VS-3	C-C	MT	1	-	-	-	-	-	-	-	-	-	-	
		C3.10		2	-	-	-	-	-	-	-	-	X	-	
	BIT RM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
300930	2-BIT-VS-4	C-C	MT	1	-	-	-	-	-	-	-	-	-	-	
		C3.10		2	-	-	-	-	-	-	-	-	X	-	
	BIT RM			3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	OUTAGE 1	OUTAGE 2	OUTAGE 3	OUTAGE 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-7 (FIG NO 8-12)													
310010	2-SI-7-01F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**18-SS-40-.562-32-DCC**
310020	2-SI-7-02S	C-F-1	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**18-SS-40-.562-32-DCC**
310030	2-SI-7-03S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**18-SS-40-.562-32-DCC**
310039	2-SI-7-04S-LU	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	EXAMINATION TO BE PEFORMED IN
	LONG. PIPE SEAM	C5.12	UT	2	-	-	-	-	C	-	-	-	-	ACCORDANCE WITH CC-N-524.
	VESTIBULE			3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**18-SS-40-.562-32-DCC**
310040	2-SI-7-04S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	C	-	-	-	-	
	VESTIBULE			3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**18-SS-40-.562-32-DCC**
310041	2-SI-7-04S-LDO	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	EXAMINATION TO BE PEFORMED IN
	OUTER LONG. ELBOW SEAM	C5.12	UT	2	-	-	-	-	C	-	-	-	-	ACCORDANCE WITH CC-N-524.
	VESTIBULE			3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**18-SS-40-.562-32-DCC**
310042	2-SI-7-04S-LDI	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	EXAMINATION TO BE PEFORMED IN
	INNER LONG. ELBOW SEAM	C5.12	UT	2	-	-	-	-	C	-	-	-	-	ACCORDANCE WITH CC-N-524.
	VESTIBULE			3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**18-SS-40-.562-32-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-7 (FIG NO B-12)													
310050	2-SI-7-05S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**18-SS-40-.562-32-DCC**
310060	2-SI-7-06S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**18-SS-40-.562-32-DCC**
310070	2-SI-7-07S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**18-SS-40-.562-32-DCC**
310080	2-SI-7-08F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310090	2-SI-7-09S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310100	2-SI-7-10S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310110	2-SI-7-11S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-7 (FIG NO B-12)													
310120	2-SI-7-12S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310130	2-SI-7-13F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310140	2-SI-7-14S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310150	2-SI-7-15S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310160	2-SI-7-16S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	-	C	-	-	-	-	-	
	W RHR PPRM			3 -	-	-	-	X	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310170	2-SI-7-17F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310180	2-SI-7-18F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-7 (FIG NO B-12)													
310190	2-SI-7-19S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310200	2-SI-7-20F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310210	2-SI-7-21S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310220	2-SI-7-22F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310230	2-SI-7-23F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO TEE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310240	2-SI-7-24F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310250	2-SI-7-25S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO FLANGE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-7 (FIG NO B-12)													
310260	2-SI-7-26F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PUMP	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310270	2-SI-7-27F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310280	2-SI-7-28S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310290	2-SI-7-29S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310300	2-SI-7-30S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310310	2-SI-7-31F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	C	-	-	-	-	-	
	VESTIBULE			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310320	2-SI-7-32S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-7 (FIG NO B-12)													
310330	2-SI-7-33S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310340	2-SI-7-34S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	-	C	-	-	-	-	-	
	W CTS PPRM			3 -	-	-	-	X	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310360	2-SI-7-35F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310370	2-SI-7-36F	C-F-1	PT	1 -	-	-	-	-	-	-	C	-	-	
	VALVE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310380	2-SI-7-37S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310390	2-SI-7-38S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310400	2-SI-7-39F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO VALVE	C5.11	UT	2 -	-	-	C	-	-	-	-	-	-	
	W CTS PPRM			3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-7 (FIG NO B-12)													
310410	2-SI-7-40F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO VALVE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310420	2-SI-7-41S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310430	2-SI-7-42F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310440	2-SI-7-43F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PUMP	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
	LINE 2-SI-8 (FIG NO B-13)													
310450	2-SI-8-01F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**18-SS-40-.562-32-DCC**
310460	2-SI-8-02S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**18-SS-40-.562-32-DCC**
310470	2-SI-8-03S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**18-SS-40-.562-32-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	PLAN STATUS FIRST PERIOD 2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-8 (FIG NO B-13)													
310480	2-SI-8-04S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**18-SS-40-.562-32-DCC**
310490	2-SI-8-05S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**18-SS-40-.562-32-DCC**
310500	2-SI-8-06S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**18-SS-40-.562-32-DCC**
310510	2-SI-8-07F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310520	2-SI-8-08S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**18-SS-40-.562-32-DCC**
310530	2-SI-8-09S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310540	2-SI-8-11S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-8 (FIG NO B-13)														
310550	2-SI-8-12F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310560	2-SI-8-13S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310570	2-SI-8-14S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	C	-	-	
	E RHR PPRM			3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310580	2-SI-8-16S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	ACCESS RESTRICTED BY SMALL
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	BORE PIPE SUPPORT.
	E RHR PPRM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310590	2-SI-8-17F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310600	2-SI-8-18F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310610	2-SI-8-19S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - -			O U T A G E				- - - - - -			
	LINE 2-SI-8 (FIG NO B-13)													
310620	2-SI-8-20S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310630	2-SI-8-21S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310640	2-SI-8-22F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310650	2-SI-8-23F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO TEE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310660	2-SI-8-24F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310670	2-SI-8-25S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO FLANGE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310680	2-SI-8-26F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO PUMP	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-8 (FIG NO B-13)													
310690	2-SI-8-27S	C-F-1	PT	1	2	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310700	2-SI-8-28S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310710	2-SI-8-29S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310720	2-SI-8-30S	C-F-1	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310730	2-SI-8-31F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	C	-	-	-	-	-	
	VESTIBULE			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310740	2-SI-8-32S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310760	2-SI-8-33S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-8 (FIG NO B-13)													
310770	2-SI-8-34S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310780	2-SI-8-35F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310790	2-SI-8-36F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	C5.11	UT	2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310800	2-SI-8-37S	C-F-1	PT	1 -	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310810	2-SI-8-38S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310820	2-SI-8-39F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO VALVE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310830	2-SI-8-40F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO VALVE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-8 (FIG NO B-13)														
310840	2-SI-8-41S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310850	2-SI-8-42F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310860	2-SI-8-43F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO PUMP	C5.11	UT	2	-	-	-	-	C	-	-	-	-	-	
	E CTS PPRM			3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
	LINE 2-SI-9 (FIG NO B-14)														
310870	2-SI-9-01F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	PENETRATION TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310880	2-SI-9-02S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310890	2-SI-9-03S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310900	2-SI-9-04F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	C	-	-	
	VESTIBULE			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-9 (FIG NO B-14)													
310910	2-SI-9-05S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310915	2-SI-9-05S-PS 1 THRU 4 4	C-C	PT	1 -	-	-	-	-	-	-	-	-	-	BASE MATERIAL 1.5".
	PIPE LUG	C3.20		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	X	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
310920	2-SI-9-06S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310930	2-SI-9-07F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO VALVE	C5.11	UT	2 -	-	-	-	C	-	-	-	-	-	
	VESTIBULE			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310940	2-SI-9-08F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO VALVE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
	VESTIBULE			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
310950	2-SI-9-09S	C-F-1	PT	1 -	-	-	-	-	-	-	C	-	-	
	TEE TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
310960	2-SI-9-10S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-9 (FIG NO B-14)														
310970	2-SI-9-11F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	C5.11	UT	2 C	-	-	-	-	-	-	-	-	-		
				3 X	-	-	-	-	-	-	-	-	-		
				4 -	-	-	-	-	-	-	-	-	-		**14-SS-40-.438-30-DCC**
310980	2-SI-9-12S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-		
	PIPE TO TEE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-		
				3 -	-	-	-	-	-	-	-	-	-		
				4 -	-	-	-	-	-	-	-	-	-		**14-SS-40-.438-30-DCC**
310990	2-SI-9-13F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-		
	TEE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-		
				3 -	-	-	-	-	-	-	-	-	-		
				4 -	-	-	-	-	-	-	-	-	-		**14-SS-40-.438-30-DCC**
311000	2-SI-9-14F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-		
	TEE TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-		
				3 -	-	-	-	-	-	-	-	-	-		
				4 -	-	-	-	-	-	-	-	-	-		**14-SS-40-.438-30-DCC**
311010	2-SI-9-15S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	C	-	-		
	VESTIBULE			3 -	-	-	-	-	-	-	X	-	-		
				4 -	-	-	-	-	-	-	-	-	-		**14-SS-40-.438-30-DCC**
311020	2-SI-9-16S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-		
				3 -	-	-	-	-	-	-	-	-	-		
				4 -	-	-	-	-	-	-	-	-	-		**14-SS-40-.438-30-DCC**
311030	2-SI-9-17F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-		
				3 -	-	-	-	-	-	-	-	-	-		
				4 -	-	-	-	-	-	-	-	-	-		**14-SS-40-.438-30-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-9 (FIG NO B-14)																
311040	2-SI-9-18S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
311050	2-SI-9-19F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
311060	2-SI-9-20S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
311070	2-SI-9-21S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	C	-	-	-	-	-	-	-	-	
	VESTIBULE			3	-	-	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
311080	2-SI-9-22F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
311090	2-SI-9-23F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
	LINE 2-SI-56 (FIG NO B-15)																
311100	2-SI-56-01F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	NOZZLE TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-56 (FIG NO B-15)													
311110	2-SI-56-02S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
311120	2-SI-56-03S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
311130	2-SI-56-04S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
311140	2-SI-56-05S	C-F-1	SEE	1	-	-	-	-	-	-	C	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
311150	2-SI-56-06F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
311170	2-SI-56-07F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO VALVE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
311180	2-SI-56-08F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-56 (FIG NO B-15)													
311190	2-SI-56-09S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
311200	2-SI-56-10F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
	LINE 2-SI-57 (FIG NO B-16)													
311210	2-SI-57-01F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	NOZZLE TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
311220	2-SI-57-02S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
311230	2-SI-57-03S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
311240	2-SI-57-04S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
311250	2-SI-57-05S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-57 (FIG NO B-16)													
311260	2-SI-57-06F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
311280	2-SI-57-07S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
311290	2-SI-57-08F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO VALVE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
311300	2-SI-57-09F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	C5.21	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
311310	2-SI-57-10F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.21	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
	LINE 2-SI-58 (FIG NO B-17)													
311320	2-SI-58-01F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	NOZZLE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
311330	2-SI-58-02S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-58 (FIG NO B-17)													
311340	2-SI-58-03S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
311350	2-SI-58-04S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	ANNULUS			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
311360	2-SI-58-05S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
311370	2-SI-58-06F	C-F-1	SEE	1 -	-	-	-	-	-	-	C	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
311380	2-SI-58-07F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
311420	2-SI-58-08F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO VALVE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
311430	2-SI-58-09F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	C	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD OUTAGE 1	SECOND PERIOD OUTAGE 2	SECOND PERIOD OUTAGE 3	SECOND PERIOD OUTAGE 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-58 (FIG NO B-17)													
311440	2-SI-58-10S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
311450	2-SI-58-11F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.21	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
	LINE 2-SI-59 (FIG NO B-18)													
311460	2-SI-59-01F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	NOZZLE TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
311470	2-SI-59-02S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
311480	2-SI-59-03S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
311490	2-SI-59-04S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
311500	2-SI-59-05S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-59 (FIG NO B-18)													
311510	2-SI-59-06F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
311520	2-SI-59-07S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
311530	2-SI-59-08F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO VALVE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
311540	2-SI-59-09F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	C5.21	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
311560	2-SI-59-10F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.21	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378030 (10-SS-140-1.0)**
	LINE 2-SI-60 (FIG NO B-19)													
311570	2-SI-60-01F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PENETRATION TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311575	2-SI-60-36S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-60 (FIG NO B-19)													
311580	2-SI-60-02F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311590	2-SI-60-03F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	C5.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311600	2-SI-60-04S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311610	2-SI-60-05F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311630	2-SI-60-07F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311640	2-SI-60-08S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311650	2-SI-60-09S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	C	-	-	-	-	-	
	ANNULUS			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - - OUTAGE - - - - - -										
	LINE 2-SI-60 (FIG NO B-19)													
311660	2-SI-60-10S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311670	2-SI-60-11S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	C	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
	LINE 2-SI-60 (FIG NO B-20)													
311680	2-SI-60-13F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311690	2-SI-60-14S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311700	2-SI-60-15S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311710	2-SI-60-16F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	C	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	X	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311720	2-SI-60-17S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-60 (FIG NO B-20)													
311730	2-SI-60-18S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311740	2-SI-60-19F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311750	2-SI-60-20F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311760	2-SI-60-21F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311810	2-SI-60-26S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311820	2-SI-60-27S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311830	2-SI-60-28F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-60 (FIG NO B-20)													
311840	2-SI-60-29S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311850	2-SI-60-30S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311860	2-SI-60-31S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO TEE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311870	2-SI-60-32F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311880	2-SI-60-33S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.11	UT	2 -	-	-	C	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	X	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311890	2-SI-60-33S-PL 1 THROUGH 4	C-C	PT	1 -	-	-	-	-	-	-	-	-	-	BASE MATERIAL 1.0".
	PIPE LUG	C3.20		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
311900	2-SI-60-34S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-60 (FIG NO B-20)														
311920	2-SI-60-35F	C-F-1	PT	1	-	-	-	-	-	-	-	C	-	-	
	ELBOW TO VALVE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
	LINE 2-SI-62 (FIG NO B-21)														
311930	2-SI-62-01F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	PENETRATION TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311940	2-SI-62-02S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	X	-	
	U. CONT.			3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311950	2-SI-62-03F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.11	UT	2	-	-	-	-	C	-	-	-	-	-	
	U. CONT.			3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311960	2-SI-62-04F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311970	2-SI-62-05S	C-F-1	PT	1	-	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
311980	2-SI-62-06S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-62 (FIG NO B-21)													
311990	2-SI-62-07F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312010	2-SI-62-09F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	C	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	X	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312020	2-SI-62-10S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312030	2-SI-62-11S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312040	2-SI-62-12F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
	LINE 2-SI-62 (FIG NO B-22)													
312050	2-SI-62-13S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312060	2-SI-62-14S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-62 (FIG NO B-22)													
312070	2-SI-62-15F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312080	2-SI-62-16F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312120	2-SI-62-20S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312130	2-SI-62-21S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312140	2-SI-62-22F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312150	2-SI-62-23S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312160	2-SI-62-24S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	C	-	-	
	ANNULUS			3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-62 (FIG NO B-22)													
312170	2-SI-62-25S	C-F-1	PT	1	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312180	2-SI-62-26S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312190	2-SI-62-27S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312200	2-SI-62-27S-PL 1 THROUGH 4	C-C	PT	1	-	-	-	-	-	-	-	-	-	BASE MATERIAL 1.0".
	PIPE LUG	C3.20		2	-	-	-	-	-	-	C	-	-	
	ANNULUS			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	
312210	2-SI-62-28S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312220	2-SI-62-29S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312230	2-SI-62-30S	C-F-1	PT	1	3	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-62 (FIG NO B-22)													
312240	2-SI-62-30S-PL 1 THROUGH 4	C-C	PT	1	-	-	-	-	-	-	-	-	-	BASE MATERIAL 1.0".
	PIPE LUG	C3.20		2	-	-	-	C	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
312250	2-SI-62-31S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312260	2-SI-62-31S-PL 1 THROUGH 4	C-C	PT	1	-	-	-	-	-	-	-	-	-	BASE MATERIAL 1.0".
	PIPE LUG	C3.20		2	-	-	-	-	C	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
312270	2-SI-62-32F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312280	2-SI-62-33S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312290	2-SI-62-33S-PL 1 THROUGH 4	C-C	PT	1	-	-	-	-	-	-	-	-	-	BASE MATERIAL 1.0".
	PIPE LUG	C3.20		2	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
312300	2-SI-62-34F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-76 (FIG NO B-23)													
312310	2-SI-76-01F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312320	2-SI-76-02F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312330	2-SI-76-03S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312340	2-SI-76-04S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312350	2-SI-76-05S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312360	2-SI-76-06S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312370	2-SI-76-07S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-76 (FIG NO B-23)													
312380	2-SI-76-08F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312390	2-SI-76-09F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	C	-	-	-	-	-	
	CONT. L2			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312400	2-SI-76-10S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312410	2-SI-76-11F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
	LINE 2-SI-77 (FIG NO B-24)													
312420	2-SI-77-01F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312430	2-SI-77-01F-PL 1 THROUGH 4	C-C	PT	1	-	-	-	-	-	-	-	-	-	BASE MATERIAL 1.0".
	PIPE LUG	C3.20		2	-	-	-	-	C	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
312440	2-SI-77-02S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-77 (FIG NO B-24)													
312450	2-SI-77-02S-PL 1 THROUGH 4	C-C	PT	1	-	-	-	-	-	-	-	-	-	BASE MATERIAL 1.0".
	PIPE LUG	C3.20		2	-	-	-	-	-	-	-	X	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
312470	2-SI-77-03S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312480	2-SI-77-04F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312490	2-SI-77-05S	C-F-1	PT	1	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312500	2-SI-77-06S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312510	2-SI-77-07F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	C5.11	UT	2	-	-	-	C	-	-	-	-	-	
	ANNULUS			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312520	2-SI-77-08F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1 (OUTAGE)	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-77 (FIG NO B-24)													
312530	2-SI-77-09S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312540	2-SI-77-10S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312550	2-SI-77-11S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312560	2-SI-77-12F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312570	2-SI-77-13S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312580	2-SI-77-14S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312590	2-SI-77-15F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.11	UT	2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-78 (FIG NO B-25)													
312600	2-SI-78-01F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	C	-	-	
	ANNULUS			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312620	2-SI-78-03F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312630	2-SI-78-04S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312640	2-SI-78-05S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312650	2-SI-78-06S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312660	2-SI-78-07S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312670	2-SI-78-08S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-78 (FIG NO B-25)													
312680	2-SI-78-09S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312690	2-SI-78-10F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312700	2-SI-78-11F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312710	2-SI-78-12S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312720	2-SI-78-13F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
	LINE 2-SI-79 (FIG NO B-26)													
312730	2-SI-79-01S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312740	2-SI-79-02S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	PLAN STATUS FIRST PERIOD 2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
							OUTAGE							
	LINE 2-SI-79 (FIG NO B-26)													
312750	2-SI-79-02S-PL 1 THROUGH 4	C-C	PT	1	-	-	-	-	-	-	-	-	-	BASE MATERIAL 1.0".
	PIPE LUG	C3.20		2	-	-	-	C	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
312760	2-SI-79-03S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312770	2-SI-79-03S-PL 1 THROUGH 4	C-C	PT	1	-	-	-	-	-	-	-	-	-	BASE MATERIAL 1.0".
	PIPE LUG	C3.20		2	-	-	-	C	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
312780	2-SI-79-04F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312790	2-SI-79-05F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312800	2-SI-79-05F-PL 1 THROUGH 4	C-C	PT	1	-	-	-	-	-	-	-	-	-	BASE MATERIAL 1.0".
	PIPE LUG	C3.20		2	-	-	-	C	-	-	-	-	-	
	ANNULUS			3	-	X	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
312810	2-SI-79-06S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	C	-	-	-	-	-	
	ANNULUS			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-79 (FIG NO B-26)													
312820	2-SI-79-06S-PL 1 THROUGH 4	C-C	PT	1	-	-	-	-	-	-	-	-	-	BASE MATERIAL 1.0".
	PIPE LUG	C3.20		2	-	-	-	C	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
312830	2-SI-79-07S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312840	2-SI-79-08S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312850	2-SI-79-09S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
312860	2-SI-79-10S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312870	2-SI-79-11F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312880	2-SI-79-12S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
					1 2 3	1 2 3 4	1 2 3	
	LINE 2-SI-79 (FIG NO B-26)							
312890	2-SI-79-13S	C-F-1	PT	1	- - -	- - - -	C - -	
	PIPE TO ELBOW	C5.11	UT	2	- - -	- - - -	- - -	
				3	- - -	- - - -	X - -	
				4	- - -	- - - -	- - -	**3378028 (6-SS-160-.71)**
312900	2-SI-79-14S	C-F-1	PT	1	- - -	- - - -	- - -	
	ELBOW TO PIPE	C5.11	UT	2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	**3378028 (6-SS-160-.71)**
312910	2-SI-79-15S	C-F-1	PT	1	- - -	- - - -	- - -	
	PIPE TO ELBOW	C5.11	UT	2	- - -	- - - -	C - -	
	ANNULUS			3	- - -	- - - -	X - -	
				4	- - -	- - - -	- - -	**3378028 (6-SS-160-.71)**
312920	2-SI-79-16S	C-F-1	PT	1	- - -	- - - -	- - -	
	ELBOW TO PIPE	C5.11	UT	2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	**3378028 (6-SS-160-.71)**
312930	2-SI-79-17S	C-F-1	PT	1	- - -	- - - -	- - -	
	PIPE, TO ELBOW	C5.11	UT	2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	**3378028 (6-SS-160-.71)**
312940	2-SI-79-18F	C-F-1	PT	1	- - -	- - - -	- - -	
	ELBOW TO PIPE	C5.11	UT	2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	**3378028 (6-SS-160-.71)**
	LINE 2-SI-79 (FIG NO B-27)							
312950	2-SI-79-19F	C-F-1	PT	1	- - -	- - - -	- - -	
	PIPE TO ELBOW	C5.11	UT	2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	**3378028 (6-SS-160-.71)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-79 (FIG NO B-27)													
312960	2-SI-79-20S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312970	2-SI-79-21F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312980	2-SI-79-22S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
312990	2-SI-79-23F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
313000	2-SI-79-24S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
313010	2-SI-79-25F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
	LINE 2-RH-14 (FIG NO B-28)													
313020	2-RH-14-01F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PUMP TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-14 (FIG NO B-28)													
313030	2-RH-14-02F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO VALVE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313040	2-RH-14-03F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313050	2-RH-14-04S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	C	-	-	PIPE THICKNESS LESS THAN
	W RHR PPRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313060	2-RH-14-05F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO VALVE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313070	2-RH-14-06F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313090	2-RH-14-07S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313100	2-RH-14-08S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 C	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-14 (FIG NO B-28)													
313110	2-RH-14-09S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313120	2-RH-14-10S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313130	2-RH-14-11F	C-F-1	SEE	1 -	-	-	-	-	-	-	C	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313140	2-RH-14-29S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313150	2-RH-14-12S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313160	2-RH-14-13S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313170	2-RH-14-14S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	W RHR PPRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-14 (FIG NO B-28)													
313180	2-RH-14-15F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313185	2-RH-14-15F-PS	C-C	PT	1 -	-	-	-	-	-	-	-	-	-	BASE MATERIAL 1.0".
	PIPE SUPPORT	C3.20		2 -	-	-	-	-	-	-	C	-	-	
	W CHG PPRM			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
313190	2-RH-14-16S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313200	2-RH-14-17S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313210	2-RH-14-18S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313220	2-RH-14-19S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO TEE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313230	2-RH-14-20F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO VALVE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RH-14 (FIG NO B-28)													
313240	2-RH-14-28F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313250	2-RH-14-21F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO VALVE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313260	2-RH-14-22F	C-F-1	SEE	1	3	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313270	2-RH-14-23S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	C	-	-	-	-	PIPE THICKNESS LESS THAN
	W RHR HXRM			3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313280	2-RH-14-24S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313290	2-RH-14-25S	C-F-1	SEE	1	-	-	-	-	-	-	C	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO REDUCER	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313300	2-RH-14-26S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-14 (FIG NO B-28)													
313310	2-RH-14-27F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO NOZZLE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
	LINE 2-RH-15 (FIG NO B-29)													
313320	2-RH-15-01F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PUMP TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313330	2-RH-15-02F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO VALVE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313340	2-RH-15-03F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	ACCESS RESTRICTED BY SMALL
	VALVE TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	BORE PIPE SUPPORT.
	E RHR PPRM			3	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
				4	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
														.375".
313350	2-RH-15-04S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313370	2-RH-15-05F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO VALVE	--	INST	2	-	-	-	-	-	-	C	-	-	PIPE THICKNESS LESS THAN
	E RHR PPRM			3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RH-15 (FIG NO B-29)													
313380	2-RH-15-06F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313390	2-RH-15-07S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313400	2-RH-15-08S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313410	2-RH-15-09S	C-F-1	SEE	1	-	-	-	-	-	-	C	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313420	2-RH-15-10S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313430	2-RH-15-11S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313440	2-RH-15-12F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	C	-	-	-	-	-	PIPE THICKNESS LESS THAN
	E RHR PPRM			3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - - OUTAGE - - - - - -										
	LINE 2-RH-15 (FIG NO B-29)													
313450	2-RH-15-13S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313460	2-RH-15-14S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313470	2-RH-15-15S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313480	2-RH-15-16S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313490	2-RH-15-17F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313500	2-RH-15-18S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313510	2-RH-15-19S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-15 (FIG NO B-29)													
313520	2-RH-15-20S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313530	2-RH-15-21S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO TEE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313540	2-RH-15-22F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO VALVE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313550	2-RH-15-33F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313560	2-RH-15-23F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO VALVE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313570	2-RH-15-24F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313580	2-RH-15-25S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL ASME SEC. XI CATGY ITEM NO	NDE METH	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-15 (FIG NO B-29)													
313590	2-RH-15-26S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313600	2-RH-15-27S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313610	2-RH-15-28S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	C	-	-	PIPE THICKNESS LESS THAN
	E RHR HXRM			3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313620	2-RH-15-29S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313630	2-RH-15-30S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO REDUCER	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313640	2-RH-15-31S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
313650	2-RH-15-32F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO NOZZLE	C5.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-16 (FIG NO B-30)													
313660	2-RH-16-02S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313670	2-RH-16-03S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313680	2-RH-16-04S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	C	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313690	2-RH-16-05S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO TEE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313700	2-RH-16-06S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313710	2-RH-16-07S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313720	2-RH-16-08S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-16 (FIG NO B-30)													
313730	2-RH-16-10F	C-F-1	SEE	1 -	-	-	-	-	-	-	C	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO VALVE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313740	2-RH-16-11F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313750	2-RH-16-12S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO VALVE	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	E RHR HXRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313760	2-RH-16-13S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313770	2-RH-16-14S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313780	2-RH-16-15S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
313790	2-RH-16-16S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO REDUCER	--	INST	2 -	-	-	-	C	-	-	-	-	-	PIPE THICKNESS LESS THAN
	E RHR HXRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-16 (FIG NO B-30)														
313800	2-RH-16-17S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	REDUCER TO TEE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
313810	2-RH-16-18F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO VALVE	--	INST	2	-	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	-	
313820	2-RH-16-19S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
313830	2-RH-16-20S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.11	UT	2	-	-	-	-	-	-	-	C	-	-	
	E RHR HXRM			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
313840	2-RH-16-21S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	TEE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
313850	2-RH-16-22S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	-	
313860	2-RH-16-23S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	E RHR HXRM			3	-	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-16 (FIG NO B-30)													
313870	2-RH-16-24F	C-F-1	SEE	1	-	-	-	-	-	-	C	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313880	2-RH-16-25S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
313890	2-RH-16-26F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO VALVE	--	INST	2	-	-	-	C	-	-	-	-	-	PIPE THICKNESS LESS THAN
	W RHR HXRM			3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-RH-17 (FIG NO B-31)													
313900	2-RH-17-01F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
313910	2-RH-17-02S	C-F-1	PT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO TEE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
313920	2-RH-17-03S	C-F-1	PT	1	-	-	-	-	-	-	C	-	-	
	TEE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
313930	2-RH-17-05S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RH-17 (FIG NO B-31)													
313940	2-RH-17-06S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
313950	2-RH-17-07F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
313960	2-RH-17-08S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	C	-	-	-	-	-	
	VESTIBULE			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
313970	2-RH-17-09F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	C	-	-	
	VESTIBULE			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
313990	2-RH-17-10S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
314000	2-RH-17-11F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
314010	2-RH-17-12F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-17 (FIG NO B-31)													
314020	2-RH-17-13S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
314030	2-RH-17-14S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
314040	2-RH-17-15F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO PENETRATION	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
314045	2-RH-17-16F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	REDUCER TO PENETRATION	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
	LINE 2-RH-18 (FIG NO B-32)													
314050	2-RH-18-01F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO REDUCER	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314060	2-RH-18-02S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	REDUCER TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314070	2-RH-18-03S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO TEE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RH-18 (FIG NO B-32)													
314080	2-RH-18-04F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO TEE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314090	2-RH-18-05S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314100	2-RH-18-06S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314110	2-RH-18-07S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 C	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314120	2-RH-18-08S	C-F-1	SEE	1 -	-	-	-	-	-	-	C	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO TEE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314130	2-RH-18-09F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2 -	-	-	-	C	-	-	-	-	-	PIPE THICKNESS LESS THAN
	W RHR HXRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314140	2-RH-18-10S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-18 (FIG NO B-32)														
314150	2-RH-18-11S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO FLANGE	--	INST	2	-	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	-	
314160	2-RH-18-12S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	W RHR HXRM			3	-	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	-	
314170	2-RH-18-13S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	-	
314180	2-RH-18-14S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	-	
314190	2-RH-18-15S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	-	
314200	2-RH-18-16S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	-	
314210	2-RH-18-17F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RH-18 (FIG NO B-32)													
314220	2-RH-18-18F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO VALVE	--	INST	2	-	-	-	C	-	-	-	-	-	PIPE THICKNESS LESS THAN
	W RHR HXRM			3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314230	2-RH-18-19F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	W RHR HXRM			3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314240	2-RH-18-20S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	C	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314260	2-RH-18-21S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO ELBOW	--	INST	2	-	-	-	C	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314270	2-RH-18-22S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	C	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314280	2-RH-18-23F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	C	-	PIPE THICKNESS LESS THAN
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314290	2-RH-18-24S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RH-18 (FIG NO B-32)													
314300	2-RH-18-25S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314310	2-RH-18-26S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314320	2-RH-18-27S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314330	2-RH-18-28F	C-F-1	SEE	1	2	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	C	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314335	2-RH-18-28F-PS	C-C	PT	1	-	-	-	-	-	-	C	-	-	BASE MATERIAL 1.0".
	PIPE SUPPORT	C3.20		2	-	-	-	-	-	-	-	-	-	
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
314340	2-RH-18-30F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314350	2-RH-18-33S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD (OUTAGE 1 2 3)	SECOND PERIOD (OUTAGE 1 2 3 4)	THIRD PERIOD (OUTAGE 1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-18 (FIG NO B-32)						
314360	2-RH-18-34S	C-F-1	SEE	1 - - -	- - - -	- - -	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 - - -	- - - -	- - -	PIPE THICKNESS LESS THAN
				3 - - -	- - - -	- - -	.375".
				4 - - -	- - - -	- - -	
314370	2-RH-18-36S	C-F-1	SEE	1 - - -	- - - -	- - -	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 - - -	- - - -	- - -	PIPE THICKNESS LESS THAN
				3 - - -	- - - -	- - -	.375".
				4 - - -	- - - -	- - -	
314380	2-RH-18-37S	C-F-1	SEE	1 - - -	- - - -	- - -	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 - - -	- - - -	- - -	PIPE THICKNESS LESS THAN
				3 - - -	- - - -	- - -	.375".
				4 - - -	- - - -	- - -	
314390	2-RH-18-38S	C-F-1	SEE	1 - - -	- - - -	- - -	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 - - -	- - - -	- - -	PIPE THICKNESS LESS THAN
				3 - - -	- - - -	- - -	.375".
				4 - - -	- - - -	- - -	
314400	2-RH-18-39S	C-F-1	SEE	1 - - -	- - - -	- - -	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 - - -	- - - -	- - -	PIPE THICKNESS LESS THAN
				3 - - -	- - - -	- - -	.375".
				4 - - -	- - - -	- - -	
314410	2-RH-18-40F	C-F-1	SEE	1 - - -	- - - -	- - -	EXAMINATION NOT REQUIRED.
	PIPE TO PENETRATION	--	INST	2 - - -	- - - -	- - -	PIPE THICKNESS LESS THAN
				3 - - -	- - - -	- - -	.375".
				4 - - -	- - - -	- - -	
	LINE 2-RH-19 (FIG NO B-33)						
314420	2-RH-19-01F	C-F-1	SEE	1 - - -	- - - -	- - -	EXAMINATION NOT REQUIRED.
	HEAT EXCHANGER TO REDUCER	--	INST	2 - - -	- - - -	- - -	PIPE THICKNESS LESS THAN
				3 - - -	- - - -	- - -	.375".
				4 - - -	- - - -	- - -	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-19 (FIG NO B-33)													
314430	2-RH-19-02S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	REDUCER TO PIPE	--	INST	2 C	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314440	2-RH-19-03S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314450	2-RH-19-04S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO TEE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314460	2-RH-19-06S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314470	2-RH-19-07S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO TEE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314480	2-RH-19-08S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314490	2-RH-19-09S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-19 (FIG NO B-33)													
314500	2-RH-19-10S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314510	2-RH-19-11S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO TEE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314520	2-RH-19-12F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2	-	-	-	C	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314530	2-RH-19-13S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2	-	-	-	-	-	-	-	C	-	PIPE THICKNESS LESS THAN
	E RHR HXRM			3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314540	2-RH-19-14S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO FLANGE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314550	2-RH-19-15S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314560	2-RH-19-16S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY / ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS — FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-19 (FIG NO B-33)													
314570	2-RH-19-17S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314580	2-RH-19-18S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314590	2-RH-19-19F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314600	2-RH-19-20S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314610	2-RH-19-21F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO VALVE	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	E RHR HXRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314620	2-RH-19-22F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314630	2-RH-19-23S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-19 (FIG NO B-33)													
314640	2-RH-19-24S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO ELBOW	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314650	2-RH-19-25S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314660	2-RH-19-26F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	X	-	PIPE THICKNESS LESS THAN
	VESTIBULE			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314670	2-RH-19-27S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314690	2-RH-19-29F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314700	2-RH-19-33S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314710	2-RH-19-34S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	PLAN STATUS FIRST PERIOD 2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-19 (FIG NO B-33)													
314720	2-RH-19-35S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314730	2-RH-19-36S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO ELBOW	--	INST	2	-	-	-	C	-	-	-	-	-	PIPE THICKNESS LESS THAN
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314740	2-RH-19-37S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314750	2-RH-19-38F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PENETRATION TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-RH-20 (FIG NO B-34)													
314760	2-RH-20-01S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	FLANGE TO TEE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314770	2-RH-20-02S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2	-	-	-	C	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314780	2-RH-20-03F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2	-	-	-	C	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-20 (FIG NO B-34)													
314790	2-RH-20-04S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO PIPE	--	INST	2	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314800	2-RH-20-05S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO PIPE	--	INST	2	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314810	2-RH-20-06S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314820	2-RH-20-07S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314825	2-RH-20-07S-PS	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE SUPPORT	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314830	2-RH-20-08S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	C	-	-	PIPE THICKNESS LESS THAN
	E RHR HXRM			3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
314840	2-RH-20-09F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO VALVE	--	INST	2	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RH-20 (FIG NO B-34)													
314860	2-RH-20-10S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO FLANGE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314870	2-RH-20-11S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	FLANGE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	E RHR HXRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314880	2-RH-20-12S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314890	2-RH-20-13S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	E RHR HXRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314900	2-RH-20-14F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO VALVE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	E RHR HXRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
314910	2-RH-20-15F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
314920	2-RH-20-16S	C-F-1	PT	1 -	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-20 (FIG NO B-34)													
314930	2-RH-20-17S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
314940	2-RH-20-18S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
314950	2-RH-20-19S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
314960	2-RH-20-20F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
314970	2-RH-20-21S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
314980	2-RH-20-22F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
314990	2-RH-20-23F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (FIRST PERIOD 1 2 3 / SECOND PERIOD 1 2 3 4 / THIRD PERIOD 1 2 3 — OUTAGE)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-20 (FIG NO B-34)				
315000	2-RH-20-24F	C-F-1	PT	1 - - - - - - - - - - - -	
	PIPE TO PIPE	C5.11	UT	2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**3378029 (8-SS-140-.81)**
315010	2-RH-20-25F	C-F-1	PT	1 - - - - - - - - - - - -	
	PIPE TO ELBOW	C5.11	UT	2 - - - - - - - - - - - -	
				3 X - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**3378029 (8-SS-140-.81)**
315020	2-RH-20-26S	C-F-1	PT	1 - - - - - - - - - - - -	
	ELBOW TO PIPE	C5.11	UT	2 - - - - - - - - - - - -	
				3 X - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**3378029 (8-SS-140-.81)**
315030	2-RH-20-27F	C-F-1	PT	1 - - - - - - - - - - - -	
	PIPE TO PENETRATION	C5.11	UT	2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**3378029 (8-SS-140-.81)**
	LINE 2-RH-21 (FIG NO B-35)				
315040	2-RH-21-01S	C-F-1	SEE	1 - - - - - - - - - - - -	EXAMINATION NOT REQUIRED.
	VALVE TO TEE	--	INST	2 - - - - - - - - - - - -	PIPE THICKNESS LESS THAN
				3 - - - - - - - - - - - -	.375".
				4 - - - - - - - - - - - -	
315050	2-RH-21-02S	C-F-1	SEE	1 - - - - - - - - - - - -	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2 - - - C - - - - - - -	PIPE THICKNESS LESS THAN
	W RHR HXRM			3 - - - - - - - - - - - -	.375".
				4 - - - - - - - - - - - -	
315060	2-RH-21-03F	C-F-1	SEE	1 - - - - - - - - - - - -	
	TEE TO PIPE	--	INST	2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-21 (FIG NO B-35)														
315070	2-RH-21-04S	C-F-1	SEE	1	-	-	-	-	-	-	C	-	-		EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-		PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-		.375".
				4	-	-	-	-	-	-	-	-	-		
315080	2-RH-21-05S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-		EXAMINATION NOT REQUIRED.
	ELBOW TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-		PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-		.375".
				4	-	-	-	-	-	-	-	-	-		
315090	2-RH-21-06S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-		EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-		PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-		.375".
				4	-	-	-	-	-	-	-	-	-		
315100	2-RH-21-07F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-		EXAMINATION NOT REQUIRED.
	PIPE TO VALVE	--	INST	2	-	-	-	-	-	-	-	-	-		PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-		.375".
				4	-	-	-	-	-	-	-	-	-		
315110	2-RH-21-08S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-		EXAMINATION NOT REQUIRED.
	PIPE TO FLANGE	--	INST	2	-	-	-	-	C	-	-	-	-		PIPE THICKNESS LESS THAN
	W RHR HXRM			3	-	-	-	-	-	-	-	-	-		.375".
				4	-	-	-	-	-	-	-	-	-		
315120	2-RH-21-09S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-		EXAMINATION NOT REQUIRED.
	FLANGE TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-		PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-		.375".
				4	-	-	-	-	-	-	-	-	-		
315150	2-RH-21-10S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-		EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-		PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-		.375".
				4	-	-	-	-	-	-	-	-	-		

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (FIRST PERIOD / SECOND PERIOD / THIRD PERIOD, OUTAGE)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-21 (FIG NO B-35)				
315170	2-RH-21-11F	C-F-1	SEE	1 - - - - - - - - - - - -	EXAMINATION NOT REQUIRED.
	ELBOW TO VALVE	--	INST	2 - - - - - - - - - - - -	PIPE THICKNESS LESS THAN
				3 - - - - - - - - - - - -	.375".
				4 - - - - - - - - - - - -	
315180	2-RH-21-12F	C-F-1	PT	1 - - - - - - - - - - - -	
	VALVE TO ELBOW	C5.11	UT	2 - - - - - - - - - - - -	
				3 - - - - - X - - - - -	
				4 - - - - - - - - - - - -	**3378029 (8-SS-140-.81)**
315190	2-RH-21-13S	C-F-1	PT	1 - - - - - - - - - - - -	
	ELBOW TO PIPE	C5.11	UT	2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**3378029 (8-SS-140-.81)**
315200	2-RH-21-14S	C-F-1	PT	1 - - - - - - - - - - - -	
	PIPE TO ELBOW	C5.11	UT	2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**3378029 (8-SS-140-.81)**
315210	2-RH-21-15S	C-F-1	PT	1 - - - - - - - - - - - -	
	ELBOW TO PIPE	C5.11	UT	2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**3378029 (8-SS-140-.81)**
315220	2-RH-21-16F	C-F-1	PT	1 - - - - - - - - - - - -	
	PIPE TO ELBOW	C5.11	UT	2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**3378029 (8-SS-140-.81)**
315230	2-RH-21-17S	C-F-1	PT	1 - - - - - - - - - - - -	
	ELBOW TO PIPE	C5.11	UT	2 C - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**3378029 (8-SS-140-.81)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	OUTAGE 1	OUTAGE 2	OUTAGE 3	OUTAGE 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-21 (FIG NO B-35)													
315240	2-RH-21-18F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
315250	2-RH-21-19S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
315260	2-RH-21-20F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
315270	2-RH-21-21S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
315280	2-RH-21-22F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
315290	2-RH-21-23S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
315300	2-RH-21-24S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-21 (FIG NO B-35)													
315310	2-RH-21-25S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
315320	2-RH-21-26S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
315330	2-RH-21-27S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	X	-	
	VESTIBULE			3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
315340	2-RH-21-28F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PENETRATION	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
	LINE 2-RH-22 (FIG NO B-36)													
315350	2-RH-22-01F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
315360	2-RH-22-02S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
315370	2-RH-22-03S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RH-22 (FIG NO B-36)													
315380	2-RH-22-04S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315390	2-RH-22-05F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315400	2-RH-22-06S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	W RHR HXRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315410	2-RH-22-07S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315420	2-RH-22-08S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315430	2-RH-22-09S	C-F-1	SEE	1 -	-	-	-	-	-	-	C	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315440	2-RH-22-10F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO VALVE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-22 (FIG NO B-36)													
315450	2-RH-22-11F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315460	2-RH-22-12F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315470	2-RH-22-13F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	C	-	-	-	-	-	PIPE THICKNESS LESS THAN
	VESTIBULE			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315480	2-RH-22-14S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315490	2-RH-22-15S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315500	2-RH-22-16S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315510	2-RH-22-17S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-22 (FIG NO B-36)													
315520	2-RH-22-18F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-RH-23 (FIG NO B-37)													
315530	2-RH-23-01F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
315540	2-RH-23-02S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
315550	2-RH-23-03S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
315560	2-RH-23-04S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
315580	2-RH-23-05S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
315590	2-RH-23-06F	C-F-1	SEE	1	-	-	-	-	-	-	C	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO VALVE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-23 (FIG NO B-37)													
315600	2-RH-23-07F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315610	2-RH-23-08S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315620	2-RH-23-09S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315630	2-RH-23-10S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	E RHR HXRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315640	2-RH-23-11S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315650	2-RH-23-12S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315660	2-RH-23-13F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO TEE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-23 (FIG NO B-37)													
315670	2-RH-23-14S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2	-	-	-	-	-	-	C	-	-	PIPE THICKNESS LESS THAN
	W CHG PPRM			3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
315680	2-RH-23-15S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
315690	2-RH-23-16S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
315700	2-RH-23-17F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
315710	2-RH-23-18F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO TEE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-RH-24 (FIG NO B-38)													
315720	2-RH-24-01F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
315730	2-RH-24-02S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - -			O	U	T	A G E	- - - - - -			
	LINE 2-RH-24 (FIG NO B-38)													
315740	2-RH-24-03S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	E RHR HXRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315750	2-RH-24-04F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO VALVE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315760	2-RH-24-05F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO PIPE	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	E RHR HXRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315770	2-RH-24-06S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315780	2-RH-24-07F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315785	2-RH-24-07F-PS	C-C	PT	1 -	-	-	-	-	-	-	-	-	-	BASE MATERIAL 1.0".
	PIPE SUPPORT	C3.20		2 -	-	-	-	-	-	-	C	-	-	
	VESTIBULE			3 -	-	-	-	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
315790	2-RH-24-08S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-24 (FIG NO B-38)													
315800	2-RH-24-09S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315810	2-RH-24-10S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 C	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315820	2-RH-24-11S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
315830	2-RH-24-12F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO TEE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-RH-31 (FIG NO B-39)													
315840	2-RH-31-01F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PENETRATION TO REDUCER	C5.11	UT	2 -	-	-	C	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
315850	2-RH-31-02S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
315860	2-RH-31-03F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RH-31 (FIG NO B-39)													
315870	2-RH-31-04S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
315880	2-RH-31-05F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
315890	2-RH-31-06S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	C	-	-	-	-	-	
	ANNULUS			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
315900	2-RH-31-07F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
315910	2-RH-31-08S	C-F-1	PT	1	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
315920	2-RH-31-09F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**12-SS-40-.406-29-DCC**
315930	2-RH-31-10F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.21	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378031 (12-SS-160-1.31)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RH-31 (FIG NO B-39)													
315935	2-RH-31-10F-PS	C-C	PT	1	-	-	-	-	-	-	-	-	-	BASE MATERIAL 1.0".
	PIPE SUPPORT	C3.20		2	-	-	-	-	-	-	-	X	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
315940	2-RH-31-11F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378031 (12-SS-160-1.31)**
315950	2-RH-31-12S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378031 (12-SS-160-1.31)**
315960	2-RH-31-13S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378031 (12-SS-160-1.31)**
	LINE 2-RH-31 (FIG NO B-40)													
315970	2-RH-31-14F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	C5.11	UT	2	-	-	-	-	-	-	C	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
315980	2-RH-31-15F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
315990	2-RH-31-16F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - -			O U T A G E				- - - - - -			
	LINE 2-RH-31 (FIG NO B-40)													
316000	2-RH-31-17F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
316005	2-RH-31-17F-PS 1 AND 2	C-C	PT	1 -	-	-	-	-	-	-	-	-	-	BASE MATERIAL 1.0".
	PIPE SUPPORT	C3.20		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
316010	2-RH-31-18S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
316020	2-RH-31-19F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.11	UT	2 -	-	-	-	-	-	-	C	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
	LINE 2-RH-32 (FIG NO B-41)													
316030	2-RH-32-01F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
316040	2-RH-32-02S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21	UT	2 -	-	-	-	-	-	-	C	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**
316050	2-RH-32-03F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.21	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378029 (8-SS-140-.81)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RH-33 (FIG NO B-42)													
316060	2-RH-33-01F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
316070	2-RH-33-02S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	C	-	-	
	ANNULUS			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
316080	2-RH-33-03F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
316090	2-RH-33-04S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
316100	2-RH-33-05S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.11	UT	2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**
316110	2-RH-33-06F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PENETRATION	C5.11	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-SS-40-.438-30-DCC**

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - -			O U T A G E				- - - - - -			
	LINE 2-CS-79 (FIG NO B-43)													
316120	2-CS-79-01S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	REDUCER TO TEE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316130	2-CS-79-02S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	E CHG PPRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316140	2-CS-79-03S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316150	2-CS-79-04S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316160	2-CS-79-05S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	E CHG PPRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316170	2-CS-79-06S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO REDUCER	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316180	2-CS-79-07S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	REDUCER TO TEE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CS-79 (FIG NO B-43)													
316190	2-CS-79-08F	C-F-1	SEE	1 -	-	-	-	-	-	-	C	-	-	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2 -	-	-	-	C	-	-	-	-	-	PIPE THICKNESS LESS THAN
	W CHG PPRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316200	2-CS-79-09S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO TEE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316210	2-CS-79-10S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO TEE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316220	2-CS-79-11F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO VALVE	--	INST	2 C	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316230	2-CS-79-12S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO REDUCER	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-CS-80 (FIG NO B-44)													
316250	2-CS-80-01	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316260	2-CS-80-02	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - - O U T A G E - - - - - -										
	LINE 2-CS-80 (FIG NO B-44)													
316270	2-CS-80-03	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316280	2-CS-80-04	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316290	2-CS-80-05	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO VALVE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316300	2-CS-80-06	C-F-1	SEE	1 -	-	-	-	-	-	-	C	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316310	2-CS-80-07	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316320	2-CS-80-08	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO STRAINER	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316330	2-CS-80-09	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	STRAINER TO ELBOW	--	INST	2 C	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-80 (FIG NO B-44)													
316340	2-CS-80-10	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO FLANGE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-CS-81 (FIG NO B-45)													
316350	2-CS-81-01F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316360	2-CS-81-02F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO VALVE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316370	2-CS-81-03F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316380	2-CS-81-04S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316390	2-CS-81-05F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO STRAINER	--	INST	2 -	-	-	-	-	-	-	C	-	-	PIPE THICKNESS LESS THAN
	W CHG PPRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316400	2-CS-81-06F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	STRAINER TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CS-81 (FIG NO B-45)													
316410	2-CS-81-07S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO FLANGE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CTS-10 (FIG NO B-46)														
316420	2-CTS-10-01F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PUMP TO REDUCER	--	INST	2	-	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	-	
316430	2-CTS-10-02S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	REDUCER TO PIPE	--	INST	2	-	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN .375"
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
316450	2-CTS-10-03F	C-F-1	SEE	1	-	-	-	-	-	-	-	C	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO VALVE	--	INST	2	-	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN .375"
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
316460	2-CTS-10-04F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO TEE	C5.11	UT	2	-	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	X	-	-	-	-	-	-	.375". 7.5% AUGMENTED UT
				4	-	-	-	-	-	-	-	-	-	-	REQUIREMENT.
															10-SS-40-.365-26-DCC
316470	2-CTS-10-05S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2	C	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	-	
316480	2-CTS-10-06S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	C5.11	UT	2	-	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	X	-	-	-	-	-	-	.375". 7.5% AUGMENTED UT
				4	-	-	-	-	-	-	-	-	-	-	REQUIREMENT.
															10-SS-40-.365-26-DCC
316490	2-CTS-10-07F	C-F-1	SEE	1	-	-	-	-	-	-	-	C	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO VALVE	--	INST	2	-	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CTS-10 (FIG NO B-46)													
316500	2-CTS-10-08F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316510	2-CTS-10-09S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	C	-	-	-	-	-	PIPE THICKNESS LESS THAN
	W CTS PPRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316520	2-CTS-10-10S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO TEE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	W CTS PPRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316530	2-CTS-10-11F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO VALVE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316540	2-CTS-10-12F	C-F	PT.	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	X	-	PIPE THICKNESS LESS THAN
	W CTS PPRM			3 -	-	-	-	-	-	-	-	X	-	.375". 7.5% AUGMENTED UT
				4 -	-	-	-	-	-	-	-	-	-	REQUIREMENT.
														10-SS-40-.365-26-DCC
316550	2-CTS-10-13S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO TEE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316560	2-CTS-10-14S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO ELBOW	--	INST	2 -	-	-	-	C	-	-	-	-	-	PIPE THICKNESS LESS THAN
	W CTS PPRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - -			O U T A G E				- - - - - -			
	LINE 2-CTS-10 (FIG NO B-46)													
316570	2-CTS-10-15S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316580	2-CTS-10-16S	C-F	PT	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	X	-	-	-	-	-	-	.375". 7.5% AUGMENTED UT
				4 -	-	-	-	-	-	-	-	-	-	REQUIREMENT.
														10-SS-40-.365-26-DCC
316590	2-CTS-10-17S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	W CTS PPRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316610	2-CTS-10-18S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316615	2-CTS-10-31F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316620	2-CTS-10-19S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	W CTS PPRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316630	2-CTS-10-20S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY / ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CTS-10 (FIG NO B-46)													
316640	2-CTS-10-21S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316650	2-CTS-10-22F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO VALVE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316660	2-CTS-10-23F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316680	2-CTS-10-24S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316690	2-CTS-10-25S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	C	-	-	PIPE THICKNESS LESS THAN
	W CTS PPRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316700	2-CTS-10-26S	C-F	PT	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	C	-	-	PIPE THICKNESS LESS THAN
	W CTS HXRM			3 -	-	-	-	-	-	-	X	-	-	.375". 7.5% AUGMENTED UT
				4 -	-	-	-	-	-	-	-	-	-	REQUIREMENT.
														10-SS-40-.365-26-DCC
316710	2-CTS-10-27S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	C	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (FIRST PERIOD 1 2 3; SECOND PERIOD 1 2 3 4; THIRD PERIOD 1 2 3; OUTAGE)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CTS-10 (FIG NO B-46)				
316720	2-CTS-10-28S ELBOW TO PIPE	C-F-1 --	SEE INST	1 - - - - - - - - - - - - 2 - - - - - - - - - - - - 3 - - - - - - - - - - - - 4 - - - - - - - - - - - -	EXAMINATION NOT REQUIRED. PIPE THICKNESS LESS THAN .375".
316740	2-CTS-10-29S PIPE TO REDUCING ELBOW	C-F-1 --	SEE INST	1 - - - - - - - - - - - - 2 - - - - - - - - - - - - 3 - - - - - - - - - - - - 4 - - - - - - - - - - - -	EXAMINATION NOT REQUIRED. PIPE THICKNESS LESS THAN .375".
316745	2-CTS-10-30F REDUCING ELBOW TO PUMP	C-F-1 --	SEE INST	1 - - - - - - - - - - - - 2 - - - - - - - - - - - - 3 - - - - - - - - - - - - 4 - - - - - - - - - - - -	EXAMINATION NOT REQUIRED. PIPE THICKNESS LESS THAN .375".
	LINE 2-CTS-11 (FIG NO B-47)				
316750	2-CTS-11-01F NOZZLE TO REDUCER	C-F-1 --	SEE INST	1 - - - - - - - - - - - - 2 - - - - - - - - - - - - 3 - - - - - - - - - - - - 4 - - - - - - - - - - - -	EXAMINATION NOT REQUIRED. PIPE THICKNESS LESS THAN .375".
316760	2-CTS-11-02S REDUCER TO PIPE	C-F-1 --	SEE INST	1 - - - - - - - - - - - - 2 - - - C - - - - - - - 3 - - - - - - - - - - - - 4 - - - - - - - - - - - -	EXAMINATION NOT REQUIRED. PIPE THICKNESS LESS THAN .375".
316770	2-CTS-11-03S PIPE TO ELBOW W CTS HXRM	C-F-1 --	SEE INST	1 - - - - - - - - - - - - 2 - - - - - - - - C - - 3 - - - - - - - - - - - - 4 - - - - - - - - - - - -	EXAMINATION NOT REQUIRED. PIPE THICKNESS LESS THAN .375".
316780	2-CTS-11-04F ELBOW TO VALVE	C-F-1 --	SEE INST	1 - - - - - - - - - - - - 2 - - - C - - - - - - - 3 - - - - - - - - - - - - 4 - - - - - - - - - - - -	EXAMINATION NOT REQUIRED. PIPE THICKNESS LESS THAN .375".

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	PLAN STATUS FIRST PERIOD 2	3	OUTAGE 1	SECOND PERIOD 2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CTS-11 (FIG NO B-47)													
316790	2-CTS-11-05F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO TEE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
316800	2-CTS-11-06S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
316810	2-CTS-11-07S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO REDUCER	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
316820	2-CTS-11-08S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	REDUCER TO PIPE	--	INST	2	-	-	-	C	-	-	-	-	-	PIPE THICKNESS LESS THAN
	W CTS HXRM			3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
316830	2-CTS-11-09F	C-F	PT	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO VALVE	C5.11	UT	2	-	-	-	C	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	**6-SS-40-.280-28-DCC**
316840	2-CTS-11-10F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO TEE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	W CTS HXRM			3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
316850	2-CTS-11-11S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CTS-11 (FIG NO B-47)													
316870	2-CTS-11-12S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316880	2-CTS-11-13S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316890	2-CTS-11-14S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316900	2-CTS-11-15S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO FLANGE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316910	2-CTS-11-16S	C-F	PT	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	FLANGE TO PIPE	C5.11	UT	2 C	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	X	-	-	-	-	-	.375". 7.5% AUGMENTED UT
				4 -	-	-	-	-	-	-	-	-	-	REQUIREMENT.
														6-SS-40-.280-28-DCC
316920	2-CTS-11-17F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO PIPE	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
316930	2-CTS-11-18S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO FLANGE	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CTS-11 (FIG NO B-47)													
316940	2-CTS-11-19S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	FLANGE TO PIPE	--	INST	2	-	-	-	C	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
316950	2-CTS-11-20F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
316960	2-CTS-11-21F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
316970	2-CTS-11-22S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	X	-	PIPE THICKNESS LESS THAN
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
316980	2-CTS-11-23S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
316990	2-CTS-11-24S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
317000	2-CTS-11-25F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - - OUTAGE - - - - - -										
	LINE 2-CTS-11 (FIG NO B-47)													
317010	2-CTS-11-26S	C-F	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	C5.11	RMKS	2 C	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	**6-SS-40-.280-28-DCC**
317020	2-CTS-11-27F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317030	2-CTS-11-28S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317040	2-CTS-11-29F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317050	2-CTS-11-30F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317060	2-CTS-11-31S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO REDUCER	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317070	2-CTS-11-32F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	REDUCER TO PENETRATION	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CTS-12 (FIG NO B-48)													
317080	2-CTS-12-01F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317090	2-CTS-12-02F	C-F	PT	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO VALVE	C5.11	UT	2 C	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 X	-	-	-	-	-	-	-	-	-	.375". 7.5% AUGMENTED UT
				4 -	-	-	-	-	-	-	-	-	-	REQUIREMENT.
														8-SS-40-.322-17-DCC
317100	2-CTS-12-03F	C-F	PT	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO PIPE	C5.11	UT	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	X	-	-	-	-	-	-	.375". 7.5% AUGMENTED UT
				4 -	-	-	-	-	-	-	-	-	-	REQUIREMENT.
														8-SS-40-.322-17-DCC
317105	2-CTS-12-21S	C-F	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.11	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**8-SS-40-.322-17-DCC**
317110	2-CTS-12-04S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317120	2-CTS-12-05S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	W CTS HXRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317130	2-CTS-12-06F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CTS-12 (FIG NO B-48)													
317140	2-CTS-12-07F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317150	2-CTS-12-08F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO FLANGE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317160	2-CTS-12-09F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	FLANGE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317170	2-CTS-12-10F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317180	2-CTS-12-11S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317190	2-CTS-12-12S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	C	-	-	PIPE THICKNESS LESS THAN
	VESTIBULE			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317210	2-CTS-12-14F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CTS-12 (FIG NO B-48)													
317220	2-CTS-12-15S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
317230	2-CTS-12-16F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
317240	2-CTS-12-17S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
317250	2-CTS-12-18S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
317260	2-CTS-12-19F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
317270	2-CTS-12-20F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO PENETRATION.	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-CTS-13 (FIG NO B-49)													
317280	2-CTS-13-01F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PUMP TO REDUCER	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CTS-13 (FIG NO B-49)															
317290	2-CTS-13-02S	C-F-1	SEE	1	-	-	-	-	-	-	-	C	-	-		EXAMINATION NOT REQUIRED.
	REDUCER TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	-		PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	-		.375".
				4	-	-	-	-	-	-	-	-	-	-		
317300	2-CTS-13-03S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	-		EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	C	-	-	-	-	-	-		PIPE THICKNESS LESS THAN
	E CTS PPRM			3	-	-	-	-	-	-	-	-	-	-		.375".
				4	-	-	-	-	-	-	-	-	-	-		
317310	2-CTS-13-04F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	-		EXAMINATION NOT REQUIRED.
	PIPE TO VALVE	--	INST	2	-	-	-	C	-	-	-	-	-	-		PIPE THICKNESS LESS THAN
				3	X	-	-	-	-	-	-	-	-	-		.375". 7.5% AUGMENTED UT
				4	-	-	-	-	-	-	-	-	-	-		REQUIREMENT.
																10-SS-40-.365-26-DCC
317320	2-CTS-13-05F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	-		EXAMINATION NOT REQUIRED.
	VALVE TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	-		PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	-		.375".
				4	-	-	-	-	-	-	-	-	-	-		
317330	2-CTS-13-06S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	-		EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	-		PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	-		.375".
				4	-	-	-	-	-	-	-	-	-	-		
317340	2-CTS-13-07S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	-		EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	-		PIPE THICKNESS LESS THAN
	E CTS PPRM			3	-	-	-	-	-	-	-	-	-	-		.375".
				4	-	-	-	-	-	-	-	-	-	-		
317350	2-CTS-13-08S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	-		EXAMINATION NOT REQUIRED.
	PIPE TO TEE	--	INST	2	-	-	-	-	-	-	-	-	-	-		PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	-		.375".
				4	-	-	-	-	-	-	-	-	-	-		

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CTS-13 (FIG NO B-49)													
317360	2-CTS-13-09S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO ELBOW	C-511	UT	2 -	-	-	-	-	-	-	-	X	-	PIPE THICKNESS LESS THAN
	E CTS PPRM			3 -	X	-	-	-	-	-	-	-	-	.375". 7.5% AUGMENTED UT
				4 -	-	-	-	-	-	-	-	-	-	REQUIREMENT.
														10-SS-40-.365-26-DCC
317370	2-CTS-13-10F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO VALVE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317380	2-CTS-13-11F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317390	2-CTS-13-12S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317400	2-CTS-13-13S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317410	2-CTS-13-14S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317420	2-CTS-13-15S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO TEE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CTS-13 (FIG NO B-49)													
317430	2-CTS-13-16F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO VALVE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317440	2-CTS-13-17F	C-F-1	SEE	1 -	-	-	-	-	-	-	C	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317450	2-CTS-13-18S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317460	2-CTS-13-19S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317470	2-CTS-13-20S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO TEE	--	INST	2 C	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317480	2-CTS-13-21F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317490	2-CTS-13-22S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CTS-13 (FIG NO B-49)													
317500	2-CTS-13-23F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
317510	2-CTS-13-24S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
317520	2-CTS-13-25S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
317530	2-CTS-13-26F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
317540	2-CTS-13-27S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
317550	2-CTS-13-28S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
317560	2-CTS-13-29S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CTS-13 (FIG NO B-49)													
317570	2-CTS-13-30F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO VALVE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
317580	2-CTS-13-31F	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
317590	2-CTS-13-32S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
317600	2-CTS-13-33S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
317610	2-CTS-13-34S	C-F-1	SEE	1	-	-	-	-	-	-	C	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
317620	2-CTS-13-35S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	
317630	2-CTS-13-36S	C-F-1	SEE	1	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO ELBOW	--	INST	2	-	-	-	C	-	-	-	-	-	PIPE THICKNESS LESS THAN
	E CTS HXRM			3	-	-	-	-	-	-	-	-	-	.375".
				4	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CTS-13 (FIG NO B-49)													
317650	2-CTS-13-37F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO NOZZLE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-CTS-14 (FIG NO B-50)													
317660	2-CTS-14-01F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	NOZZLE TO REDUCER	--	INST	2 -	-	-	-	-	-	-	-	X	-	PIPE THICKNESS LESS THAN
	E CTS HXRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317670	2-CTS-14-02S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	REDUCER TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317680	2-CTS-14-03S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	X	-	PIPE THICKNESS LESS THAN
	E CTS HXRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317690	2-CTS-14-04F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO VALVE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317700	2-CTS-14-05F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO TEE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317710	2-CTS-14-06S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (FIRST PERIOD / SECOND PERIOD / THIRD PERIOD, OUTAGE)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CTS-14 (FIG NO B-50)				
317720	2-CTS-14-07S ELBOW TO REDUCER	C-F-1 --	SEE INST	1 - - - - - - - - - - - - 2 C - - - - - - - - - - - 3 - - - - - - - - - - - - 4 - - - - - - - - - - - -	EXAMINATION NOT REQUIRED. PIPE THICKNESS LESS THAN .375".
317730	2-CTS-14-08S REDUCER TO PIPE	C-F-1 --	SEE INST	1 - - - - - - - - - - - - 2 - - - - - - - - - - - - 3 - - - - - - - - - - - - 4 - - - - - - - - - - - -	EXAMINATION NOT REQUIRED. PIPE THICKNESS LESS THAN .375".
317740	2-CTS-14-09F PIPE TO VALVE	C-F-1 --	SEE INST	1 - - - - - - - - - - - - 2 - - - - - - - - - - - - 3 - - - - - - - - - - - - 4 - - - - - - - - - - - -	EXAMINATION NOT REQUIRED. PIPE THICKNESS LESS THAN .375".
317750	2-CTS-14-10F VALVE TO TEE	C-F-1 --	SEE INST	1 - - - - - - - - - - - - 2 - - - - - - - - - - - - 3 - - - - - - - - - - - - 4 - - - - - - - - - - - -	EXAMINATION NOT REQUIRED. PIPE THICKNESS LESS THAN .375".
317760	2-CTS-14-11S TEE TO PIPE	C-F-1 --	SEE INST	1 - - - - - - - - - - - - 2 - - - - - - - - - - - - 3 - - - - - - - - - - - - 4 - - - - - - - - - - - -	EXAMINATION NOT REQUIRED. PIPE THICKNESS LESS THAN .375".
317770	2-CTS-14-12S PIPE TO ELBOW E CTS HXRM	C-F-1 C5.11	PT UT	1 - - - - - - - - - - - - 2 - - - - - - - - - - - - 3 - - - - - - - - X - - 4 - - - - - - - - - - - -	EXAMINATION NOT REQUIRED. PIPE THICKNESS LESS THAN .375". 7.5% AUGMENTED UT REQUIREMENT. **6-SS-40-.280-28-DCC**
317780	2-CTS-14-13S ELBOW TO PIPE	C-F-1 --	SEE INST	1 - - - - - - - - - - - - 2 - - - - - - - - - - - - 3 - - - - - - - - - - - - 4 - - - - - - - - - - - -	EXAMINATION NOT REQUIRED. PIPE THICKNESS LESS THAN .375".

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - -			O U T A G E				- - - - - -			
	LINE 2-CTS-14 (FIG NO B-50)													
317790	2-CTS-14-14S	C-F-1	PT	1 -	-	-	-	-	-	--	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	C5.11	UT	2 -	-	-	-	-	-	-	C	-	-	PIPE THICKNESS LESS THAN
	E CTS HXRM			3 -	-	-	-	-	-	-	X	-	-	.375". 7.5% AUGMENTED UT
				4 -	-	-	-	-	-	-	-	-	-	REQUIREMENT.
														6-SS-40-.280-28-DCC
317800	2-CTS-14-15S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO FLANGE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317810	2-CTS-14-16S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	FLANGE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317820	2-CTS-14-17S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO FLANGE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317830	2-CTS-14-18S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	FLANGE TO PIPE	--	INST	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	E CTS HXRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317840	2-CTS-14-19F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317850	2-CTS-14-20S	C-F-1	SEE	1 -	-	-	-	-	--	-	C	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CTS-14 (FIG NO B-50)													
317860	2-CTS-14-21S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317870	2-CTS-14-22F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317880	2-CTS-14-23F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317890	2-CTS-14-24F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317900	2-CTS-14-25S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO REDUCER	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317910	2-CTS-14-26F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	REDUCER TO PENETRATION	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-CTS-15 (FIG NO B-51)													
317940	2-CTS-15-01F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2 -	-	-	-	-	-	-	C	-	-	PIPE THICKNESS LESS THAN
	E CTS HXRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CTS-15 (FIG NO B-51)													
317950	2-CTS-15-02F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO VALVE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	E CTS HXRM			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317960	2-CTS-15-03F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	VALVE TO TEE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317965	2-CTS-15-19S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	TEE TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317970	2-CTS-15-04S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317980	2-CTS-15-05S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
317990	2-CTS-15-06S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
318000	2-CTS-15-07S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	C5.11	UT	2 -	-	-	C	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
	E CTS HXRM			3 -	-	-	X	-	-	-	-	-	-	.375". 7.5% AUGMENTED UT
				4 -	-	-	-	-	-	-	-	-	-	REQUIREMENT.
														8-SS-40-.322-17-DCC

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD (OUTAGE 1 2 3)	SECOND PERIOD (OUTAGE 1 2 3 4)	THIRD PERIOD (OUTAGE 1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CTS-15 (FIG NO B-51)						
318010	2-CTS-15-20S	C-F-1	SEE	1 - - -	- - - -	- - -	EXAMINATION NOT REQUIRED.
	PIPE TO FLANGE	--	INST	2 - - -	- - - -	- - -	PIPE THICKNESS LESS THAN
				3 - - -	- - - -	- - -	.375".
				4 - - -	- - - -	- - -	
318020	2-CTS-15-21S	C-F-1	SEE	1 - - -	- - - -	- - -	EXAMINATION NOT REQUIRED.
	FLANGE TO PIPE	--	INST	2 - - -	- - - -	- - -	PIPE THICKNESS LESS THAN
				3 - - -	- - - -	- - -	.375".
				4 - - -	- - - -	- - -	
318030	2-CTS-15-08F	C-F-1	SEE	1 - - -	- - - -	- - -	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 C - -	- - - -	- - -	PIPE THICKNESS LESS THAN
				3 - - -	- - - -	- - -	.375".
				4 - - -	- - - -	- - -	
318040	2-CTS-15-09S	C-F-1	SEE	1 - - -	- - - -	- - -	EXAMINATION NOT REQUIRED.
	ELBOW TO ELBOW	--	INST	2 - - -	- - - -	- - -	PIPE THICKNESS LESS THAN
				3 - - -	- - - -	- - -	.375".
				4 - - -	- - - -	- - -	
318050	2-CTS-15-10S	C-F-1	SEE	1 - - -	- - - -	- - -	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 - - -	- - - -	- - -	PIPE THICKNESS LESS THAN
				3 - - -	- - - -	- - -	.375".
				4 - - -	- - - -	- - -	
318060	2-CTS-15-11F	C-F-1	SEE	1 - - -	- - - -	- - -	EXAMINATION NOT REQUIRED.
	PIPE TO PIPE	--	INST	2 - - -	- - - -	- - -	PIPE THICKNESS LESS THAN
				3 - - -	- - - -	- - -	.375".
				4 - - -	- - - -	- - -	
318070	2-CTS-15-12F	C-F-1	SEE	1 - - -	- - - -	- - -	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 - - -	- - - -	- - -	PIPE THICKNESS LESS THAN
				3 - - -	- - - -	- - -	.375".
				4 - - -	- - - -	- - -	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - - O U T A G E - - - - - -										
	LINE 2-CTS-15 (FIG NO B-51)													
318080	2-CTS-15-13S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
318090	2-CTS-15-14S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
318100	2-CTS-15-15F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	C	-	-	PIPE THICKNESS LESS THAN
	VESTIBULE			3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
318110	2-CTS-15-16S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO ELBOW	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
318120	2-CTS-15-17S	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	ELBOW TO PIPE	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	
318130	2-CTS-15-18F	C-F-1	SEE	1 -	-	-	-	-	-	-	-	-	-	EXAMINATION NOT REQUIRED.
	PIPE TO PENETRATION	--	INST	2 -	-	-	-	-	-	-	-	-	-	PIPE THICKNESS LESS THAN
				3 -	-	-	-	-	-	-	-	-	-	.375".
				4 -	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-70 (FIG NO B-52)													
318140	2-FW-70-01F	C-F-2	MT	1	-	-	-	C	-	-	-	-	-	
	VALVE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318150	2-FW-70-02S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318170	2-FW-70-03S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318180	2-FW-70-04F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318190	2-FW-70-09S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318200	2-FW-70-10F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318210	2-FW-70-11F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-70 (FIG NO B-52)													
318230	2-FW-70-13S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318240	2-FW-70-14F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318245	2-FW-70-14F-PS	C-C	MT	1	-	-	-	-	-	-	-	-	-	INACCESSIBLE DUE TO WELDED
	PIPE SUPPORT	C3.20		2	-	-	-	-	-	-	-	-	-	INSULATION ATTACHMENT.
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
318250	2-FW-70-17F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318260	2-FW-70-18F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318270	2-FW-70-19F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318290	2-FW-70-40F-PS	C-C	MT	1	-	-	-	-	-	-	-	-	-	WELD INACCESSIBLE FOR
	PIPE TO PENETRATION SEAL WELD	C3.20		2	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE BASIS FOR
				3	-	-	-	-	-	-	-	-	-	PREPARATION, SECTION 3.5.
				4	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1 2 3	SECOND PERIOD 1 2 3 4	THIRD PERIOD 1 2 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-70 (FIG NO B-52)							
318300	2-FW-70-41	C-F	MT	1	- - -	- - - -	- - -	
	BRANCH CONNECTION TO PIPE	C5.51		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
318310	2-FW-70-42	C-F-2	MT	1	- - -	- - - -	- - -	
	SADDLE TO PIPE	C5.51		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	LINE 2-FW-70 (FIG NO B-50)							
318320	2-FW-70-43	C-F	MT	1	- - -	- - - -	- - -	CODE RELIEF GRANTED FIRST
	SADDLE TO BRANCH CONNECTION	C5.51	RT	2	- - -	- - - -	- - -	INTERVAL FROM VOLUMETRIC
				3	- - -	- - - -	- - -	EXAMINATION. SEE BASIS FOR
				4	- - -	- - - -	- - -	PREPARATION, SECTION 3.5.
	LINE 2-FW-70 (FIG NO B-52)							
318330	2-FW-70-44	C-F-2	MT	1	- - -	- - - -	- - -	
	PIPE TO PIPE	C5.51	UT	2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	**6-CS-80-.432-13-DCC**
318335	2-FW-70-38F	C-F-2	MT	1	- - -	- - - -	- - -	
	PIPE TO ELBOW	C5.51	UT	2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	**6-CS-80-.432-13-DCC**
	LINE 2-FW-71 (FIG NO B-53)							
318340	2-FW-71-01F	C-F-2	MT	1	- - -	- - - -	- - -	
	VALVE TO PIPE	C5.51	UT	2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	**14-CS-80-.750-12-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - -			O U T A G E				- - - - - -			
	LINE 2-FW-71 (FIG NO B-53)													
318350	2-FW-71-02S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318370	2-FW-71-03S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318380	2-FW-71-04S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318390	2-FW-71-05S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318400	2-FW-71-06S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318410	2-FW-71-07F	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318440	2-FW-71-08F	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD (OUTAGE 1 2 3)	SECOND PERIOD (OUTAGE 1 2 3 4)	THIRD PERIOD (OUTAGE 1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-71 (FIG NO B-53)						
318460	2-FW-71-10F	C-F-2	MT	1 - - -	- - - -	- - -	
	PIPE TO PIPE	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**14-CS-80-.750-12-DCC**
318470	2-FW-71-11S	C-F-2	MT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**14-CS-80-.750-12-DCC**
318480	2-FW-71-12F	C-F-2	MT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**14-CS-80-.750-12-DCC**
318485	2-FW-71-12F-PS	C-C	MT	1 - - -	- - - -	- - -	INACCESSIBLE DUE TO WELDED
	PIPE SUPPORT	C3.20		2 - - -	- - - -	- - -	INSULATION ATTACHMENT.
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
318490	2-FW-71-13F	C-F-2	MT	1 - - -	- - - -	- - -	
	PIPE TO VALVE	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**14-CS-80-.750-12-DCC**
318500	2-FW-71-14F	C-F-2	MT	1 - - -	- - - -	- - -	
	VALVE TO PIPE	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**14-CS-80-.750-12-DCC**
318510	2-FW-71-15F	C-F-2	MT	1 - - -	- - - -	- - -	
	PIPE TO PIPE	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**14-CS-80-.750-12-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-71 (FIG NO B-53)													
318520	2-FW-71-16F-PS	C-C	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PENETRATION SEAL WELD	C3.20		2	-	-	-	C	-	-	-	-	-	
	E MS ENC			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
318530	2-FW-71-30	C-F	MT	1	-	-	-	-	-	-	-	-	-	
	BRANCH CONNECTION TO PIPE	C5.80		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
318540	2-FW-71-31	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	SADDLE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
318550	2-FW-71-32	C-F	MT	1	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED FIRST
	SADDLE TO BRANCH CONNECTION	C5.21	UT	2	-	-	-	-	-	-	-	-	-	INTERVAL FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE BASIS FOR
				4	-	-	-	-	-	-	-	-	-	PREPARATION, SECTION 3.5.
318560	2-FW-71-33	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
	LINE 2-FW-72 (FIG NO B-54)													
318570	2-FW-72-01F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318580	2-FW-72-02S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY	NDE METH	INSPECTION INTERVAL ITEM NO	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-72 (FIG NO B-54)														
318600	2-FW-72-03S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318610	2-FW-72-04S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318620	2-FW-72-05F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318630	2-FW-72-06S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318640	2-FW-72-07S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318660	2-FW-72-08F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318680	2-FW-72-10S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-72 (FIG NO B-54)													
318690	2-FW-72-11F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318700	2-FW-72-12S	C-F-2	MT	1	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318710	2-FW-72-12S-PL 1 AND 2	C-C	MT	1	-	-	-	-	-	-	C	-	-	BASE MATERIAL 1.0".
	PIPE LUG	C3.20		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	
318720	2-FW-72-13F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318760	2-FW-72-14F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318770	2-FW-72-15S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318780	2-FW-72-16S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-72 (FIG NO B-54)													
318790	2-FW-72-17F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318800	2-FW-72-17F-PS	C-C	MT	1	-	-	-	-	-	-	-	-	-	INACCESSIBLE DUE TO WELDED
	PIPE SUPPORT	C3.20		2	-	-	-	-	-	-	-	-	-	INSULATION ATTACHMENT.
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
318810	2-FW-72-18F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318820	2-FW-72-19F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318830	2-FW-72-20F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318840	2-FW-72-21F-PS	C-C	MT	1	-	-	-	-	-	-	-	-	-	BASE MATERIAL LESS THAN 0.75".
	PIPE TO PENETRATION SEAL WELD	C3.20		2	-	-	-	-	-	-	-	-	-	
	W MS ENC			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
318850	2-FW-72-35	C-F	MT	1	-	-	-	-	-	-	-	-	-	WELD INACCESSIBLE FOR
	BRANCH CONNECTION TO PIPE	C5.80		2	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE BASIS FOR
				3	-	-	-	-	-	-	-	-	-	PREPARATION, SECTION 3.5.
				4	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-FW-72 (FIG NO B-54)													
318860	2-FW-72-36	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	SADDLE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
	LINE 2-FW-72 (FIG NO B-52)													
318870	2-FW-72-37	C-F	MT	1	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED FIRST
	SADDLE TO BRANCH CONNECTION	C5.21	RT	2	-	-	-	-	-	-	-	-	-	INTERVAL FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE BASIS FOR
				4	-	-	-	-	-	-	-	-	-	PREPARATION, SECTION 3.5.
	LINE 2-FW-72 (FIG NO B-54)													
318880	2-FW-72-38	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
	LINE 2-FW-73 (FIG NO B-55)													
318890	2-FW-73-01F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318900	2-FW-73-02S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
318920	2-FW-73-03S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD (OUTAGE 1 2 3)	SECOND PERIOD (OUTAGE 1 2 3 4)	THIRD PERIOD (OUTAGE 1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-73 (FIG NO B-55)						
318930	2-FW-73-04S	C-F-2	MT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**14-CS-80-.750-12-DCC**
318940	2-FW-73-05F	C-F-2	MT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**14-CS-80-.750-12-DCC**
318950	2-FW-73-06S	C-F-2	MT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**14-CS-80-.750-12-DCC**
318960	2-FW-73-07S	C-F-2	MT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**14-CS-80-.750-12-DCC**
318970	2-FW-73-07S-PL	C-C	MT	1 - - -	- - - -	- - -	BASE MATERIAL 1.0".
	PIPE LUG	C3.20		2 - - -	- - - -	- - -	
	MS ACC			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
318990	2-FW-73-08F	C-F-2	MT	1 - - -	- - - -	- - -	
	PIPE TO PIPE	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**14-CS-80-.750-12-DCC**
319010	2-FW-73-11F-PL	C-C	MT	1 - - -	- - - -	- - -	BASE MATERIAL 1.0".
	PIPE LUG	C3.20		2 - - -	- - - -	- - -	
	MS ACC			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-73 (FIG NO B-55)													
319030	2-FW-73-12S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	C	-	-	-	-	-	
	MS ACC			3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319040	2-FW-73-13F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319050	2-FW-73-14S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319060	2-FW-73-15F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319070	2-FW-73-16S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319080	2-FW-73-17F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319085	2-FW-73-17F-PS	C-C	MT	1	-	-	-	-	-	-	-	-	-	INACCESSIBLE DUE TO WELDED
	PIPE SUPPORT	C3.20		2	-	-	-	-	-	-	-	-	-	INSULATION ATTACHMENT.
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL ASME SEC. XI CATGY ITEM NO	NDE METH	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-73 (FIG NO B-55)													
319090	2-FW-73-18F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319100	2-FW-73-19F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319110	2-FW-73-20F	C-F-2	MT	1	-	-	-	-	C	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319120	2-FW-73-38F-PS	C-C	MT	1	-	-	-	-	-	-	-	-	-	BASE MATERIAL LESS THAN 0.75".
	PIPE TO PENETRATION SEAL WELD	C3.20		2	-	-	-	-	-	-	-	-	-	
	W MS ENC			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
319130	2-FW-73-39	C-F	MT	1	-	-	-	-	-	-	-	-	-	
	BRANCH CONNECTION TO PIPE	C5.80		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
319140	2-FW-73-40	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	SADDLE TO PIPE	C5.51		2	-	-	-	C	-	-	-	-	-	
	W MS ENC			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
319150	2-FW-73-41	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED FIRST
	SADDLE TO BRANCH CONNECTION	C5.51		2	-	-	-	C	-	-	-	-	-	INTERVAL FROM VOLUMETRIC
	W MS ENC			3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE BASIS FOR
				4	-	-	-	-	-	-	-	-	-	PREPARATION, SECTION 3.5.

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-73 (FIG NO B-55)													
319160	2-FW-73-42	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
	LINE 2-FW-74 (FIG NO B-56)													
319165	2-FW-74-16S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	WELD INACCESSIBLE FOR
	PIPE TO FLUED HEAD	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE BASIS FOR
				3 -	-	-	-	-	-	-	-	-	-	PREPARATION, SECTION 3.5. CODE
				4 -	-	-	-	-	-	-	-	-	-	RELIEF GRANTED FROM
														EXAMINATION.
319170	2-FW-74-01F	C-C	MT	1 C	-	-	-	-	-	-	-	-	-	
	PENETRATION SUPPORT WELD	C3.20		2 -	-	-	C	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	X	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
319180	2-FW-74-02F	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	FLUED HEAD TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319190	2-FW-74-03S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319200	2-FW-74-04S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-74 (FIG NO B-56)													
319210	2-FW-74-05S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319220	2-FW-74-06F	C-F-2	MT	1 -	C	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319230	2-FW-74-07S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319250	2-FW-74-08F	C-F-2	MT	1 -	C	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319280	2-FW-74-09S	C-F-2	MT	1 C	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319290	2-FW-74-10F	C-F-2	MT	1 C	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319300	2-FW-74-11S	C-F-2	MT	1 C	-	-	-	-	-	-	-	-	-	
	PIPE TO REDUCER	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - -			O U T A G E							
	LINE 2-FW-74 (FIG NO B-56)													
319310	2-FW-74-12S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	REDUCER TO ELBOW	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**FW-16-CS-80-.844-45-DCC**
319320	2-FW-74-13F	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO NOZZLE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**FW-16-CS-80-.844-45-DCC**
	LINE 2-FW-75 (FIG NO B-57)													
319325	2-FW-75-16S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	WELD INACCESSIBLE FOR
	PIPE TO FLUED HEAD	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE BASIS FOR
				3 -	-	-	-	-	-	-	-	-	-	PREPARATION, SECTION 3.5. CODE
				4 -	-	-	-	-	-	-	-	-	-	RELIEF GRANTED FROM
														EXAMINATION.
319340	2-FW-75-01F	C-C	MT	1 C	-	-	-	-	-	-	-	-	-	
	PENETRATION SUPPORT WELD	C3.20		2 -	-	-	-	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
319350	2-FW-75-02F	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PENETRATION TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319360	2-FW-75-03S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-FW-75 (FIG NO B-57)													
319370	2-FW-75-04S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319380	2-FW-75-05S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	C	-	-	
	ANNULUS			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319390	2-FW-75-06F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319410	2-FW-75-07F	C-F-2	MT	1	-	C	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319420	2-FW-75-08S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319430	2-FW-75-09S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319440	2-FW-75-10F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-75 (FIG NO B-57)													
319450	2-FW-75-11S	C-F-2	MT	1 C	-	-	-	-	-	-	-	-	-	
	PIPE TO REDUCER	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319460	2-FW-75-12S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	REDUCER TO ELBOW	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**FW-16-CS-80-.844-45-DCC**
319470	2-FW-75-13F	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO NOZZLE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**FW-16-CS-80-.844-45-DCC**
	LINE 2-FW-76 (FIG NO B-58)													
319486	2-FW-76-16S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	WELD INACCESSIBLE FOR
	PIPE TO FLUED HEAD	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE BASIS FOR
				3 -	-	-	-	-	-	-	-	-	-	PREPARATION, SECTION 3.5. CODE
				4 -	-	-	-	-	-	-	-	-	-	RELIEF GRANTED FROM
														EXAMINATION.
319488	2-FW-76-15F	C-C	MT	1 -	-	-	-	-	-	-	-	-	-	
	PENETRATION SUPPORT WELD	C3.20		2 -	-	-	-	-	-	-	-	-	-	
	ANNULUS			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
319490	2-FW-76-01F	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	FLUED HEAD TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-76 (FIG NO B-58)														
319500	2-FW-76-02S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319510	2-FW-76-03S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319520	2-FW-76-04S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319530	2-FW-76-05F	C-F-2	MT	1	-	C	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319540	2-FW-76-06S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319550	2-FW-76-07F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319560	2-FW-76-08S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-76 (FIG NO B-58)													
319570	2-FW-76-09F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319580	2-FW-76-10S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO REDUCER	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319590	2-FW-76-11S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	X	-	
	CONT. L4			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	**FW-16-CS-80-.844-45-DCC**
319600	2-FW-76-12F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO NOZZLE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**FW-16-CS-80-.844-45-DCC**
	LINE 2-FW-77 (FIG NO B-59)													
319626	2-FW-77-15S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	WELD INACCESSIBLE FOR
	PIPE TO FLUED HEAD	C5.51	UT	2	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE BASIS FOR
				3	-	-	-	-	-	-	-	-	-	PREPARATION, SECTION 3.5. CODE
				4	-	-	-	-	-	-	-	-	-	RELIEF GRANTED FROM
														EXAMINATION.
319628	2-FW-77-14F	C-C	MT	1	-	-	-	-	-	-	-	-	-	
	PENETRATION SUPPORT WELD	C3.20		2	-	-	-	-	-	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-77 (FIG NO B-59)													
319630	2-FW-77-01F	C-F-2	MT	1 C	-	-	-	-	-	-	-	-	-	
	FLUED HEAD TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319640	2-FW-77-02S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319650	2-FW-77-03S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319660	2-FW-77-04S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319670	2-FW-77-05F	C-F-2	MT	1 -	C	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319675	2-FW-77-16S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319680	2-FW-77-06S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-77 (FIG NO B-59)													
319690	2-FW-77-07F	C-F-2	MT	1 C	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319700	2-FW-77-08S	C-F-2	MT	1 C	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319710	2-FW-77-09F	C-F-2	MT	1 C	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319720	2-FW-77-10S	C-F-2	MT	1 C	-	-	-	-	-	-	-	-	-	
	PIPE TO REDUCER	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**14-CS-80-.750-12-DCC**
319730	2-FW-77-11S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	REDUCER TO ELBOW	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**FW-16-CS-80-.844-45-DCC**
319770	2-FW-77-17F	C-F-2	MT	1 -	-	-	-	C	-	-	-	-	-	
	ELBOW TO NOZZLE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**FW-16-CS-80-.844-45-DCC**
	LINE 2-FW-78 (FIG NO B-60)													
319780	2-FW-78-01F	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL ASME SEC. XI CATGY ITEM NO	NDE METH	PLAN STATUS FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD			INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-78 (FIG NO B-60)																
319790	2-FW-78-02S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
319800	2-FW-78-03S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
319810	2-FW-78-04S	C-F-2	MT	1	-	-	-	-	C	-	-	-	-	-	-	-	
	FLANGE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
319822	2-FW-78-24F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
319825	2-FW-78-25S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO.ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
319828	2-FW-78-26S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
319829	2-FW-78-05S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-78 (FIG NO B-60)													
319830	2-FW-78-06S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
319850	2-FW-78-07F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
319860	2-FW-78-08S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
319870	2-FW-78-09F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
319880	2-FW-78-10S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
319890	2-FW-78-11F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
319900	2-FW-78-12S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-78 (FIG NO B-60)													
319910	2-FW-78-13S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	TEE TO CAP	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
	LINE 2-FW-79 (FIG NO B-61)													
319950	2-FW-79-01S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	CAP TO TEE	C5.51	UT	2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
319960	2-FW-79-02S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
319970	2-FW-79-03S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
319980	2-FW-79-04S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
319990	2-FW-79-05F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320000	2-FW-79-06S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-79 (FIG NO B-61)													
320010	2-FW-79-07F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320030	2-FW-79-08S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320040	2-FW-79-09S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320042	2-FW-79-23S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320045	2-FW-79-24S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320048	2-FW-79-25S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320050	2-FW-79-10S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD (OUTAGE 1 2 3)	SECOND PERIOD (OUTAGE 1 2 3 4)	THIRD PERIOD (OUTAGE 1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-79 (FIG NO B-61)						
320060	2-FW-79-11S	C-F-2	MT	1 - - -	- - - -	- - -	
	FLANGE TO PIPE	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**6-CS-80-.432-13-DCC**
320070	2-FW-79-12S	C-F-2	MT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**6-CS-80-.432-13-DCC**
	LINE 2-FW-80 (FIG NO B-62)						
320110	2-FW-80-01F	C-F-2	MT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**6-CS-80-.432-13-DCC**
320120	2-FW-80-02S	C-F-2	MT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**6-CS-80-.432-13-DCC**
320125	2-FW-80-21S	C-F-2	MT	1 - - -	- - - -	- - -	
	PIPE TO PIPE	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**6-CS-80-.432-13-DCC**
320130	2-FW-80-03S	C-F-2	MT	1 - - -	- - - -	C - -	
	PIPE TO FLANGE	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	X - -	
				4 - - -	- - - -	- - -	**6-CS-80-.432-13-DCC**
320140	2-FW-80-04S	C-F-2	MT	1 - - -	- - - -	- - -	
	FLANGE TO PIPE	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**6-CS-80-.432-13-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-80 (FIG NO B-62)													
320143	2-FW-80-22S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320148	2-FW-80-23S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320150	2-FW-80-05F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320160	2-FW-80-06S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	C	-	-	
	W MS ENC			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320163	2-FW-80-24F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320170	2-FW-80-07F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320180	2-FW-80-08S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-80 (FIG NO B-62)													
320185	2-FW-80-25F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320190	2-FW-80-09F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320200	2-FW-80-10S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320210	2-FW-80-11S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320220	2-FW-80-12S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320230	2-FW-80-13S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320240	2-FW-80-14S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	TEE TO CAP	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-81 (FIG NO B-63)													
320310	2-FW-81-01F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320320	2-FW-81-02S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320330	2-FW-81-03S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320340	2-FW-81-04S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	FLANGE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320342	2-FW-81-21S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320345	2-FW-81-22S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320348	2-FW-81-23S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-81 (FIG NO B-63)																
320350	2-FW-81-05F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320360	2-FW-81-06S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320380	2-FW-81-07F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320390	2-FW-81-08S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	C	-	-	-	-	-	-	-	-	
	596 PLAT			3	-	-	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320395	2-FW-81-24F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320400	2-FW-81-09F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
	596 PLAT			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320410	2-FW-81-10S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-FW-81 (FIG NO B-63)													
320420	2-FW-81-11S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320430	2-FW-81-12S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320440	2-FW-81-13S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320450	2-FW-81-14S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	TEE TO CAP	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-89 (FIG NO B-64)													
320500	2-MS-89-01F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	NOZZLE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
320510	2-MS-89-04S	C-F-2	MT	1	-	-	-	-	-	-	C	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
320520	2-MS-89-05S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
320530	2-MS-89-06S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO REDUCER	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
320540	2-MS-89-07F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
320550	2-MS-89-08F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
320560	2-MS-89-09S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-MS-89 (FIG NO B-64)													
320570	2-MS-89-10F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
320580	2-MS-89-10F-PS-1 AND 2	C-C	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT	C3.20		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
320610	2-MS-89-11F	C-F-2	MT	1	-	-	-	-	C	-	-	-	-	WELD INACCESSIBLE FOR
	PIPE TO FLUED HEAD	C5.51	UT	2	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE BASIS FOR
				3	-	-	-	-	-	-	-	-	-	PREPARATION, SECTION 3.5. CODE
				4	-	-	-	-	-	-	-	-	-	RELIEF GRANTED FROM
														EXAMINATION.
														30-CS-X-1.00-38-DCC
320620	2-MS-89-12S-PS	C-F	MT	1	-	-	-	-	-	-	-	-	-	
	PENETRATION SUPPORT WELD	C3.20		2	-	-	-	-	C	-	-	-	-	
	ANNULUS			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
320630	2-MS-89-13S	C-F-2	MT	1	-	-	-	-	C	-	-	-	-	WELD INACCESSIBLE FOR
	FLUED HEAD TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE BASIS FOR
				3	-	-	-	-	-	-	-	-	-	PREPARATION, SECTION 3.5. CODE
				4	-	-	-	-	-	-	-	-	-	RELIEF GRANTED FROM
														EXAMINATION.
	LINE 2-MS-90 (FIG NO B-65)													
320640	2-MS-90-01S-PS	C-C	MT	1	-	-	-	-	-	-	-	-	-	BASE MATERIAL 1.0".
	PIPE TO PENETRATION SEAL WELD	C3.20		2	-	-	-	-	-	-	C	-	-	
	E MS ENC			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-90 (FIG NO B-65)														
320650	2-MS-90-02F	C-F-2	MT	1	-	-	-		C	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
320660	2-MS-90-03S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
320670	2-MS-90-04F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	TEE TO VALVE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
320680	2-MS-90-05F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	TEE TO TEE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
320690	2-MS-90-06S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	TEE TO CAP	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
320693	2-MS-90-06S-PS 1 AND 2	C-C	MT	1	-	-	-	-	-	-	-	-	-	-	BASE MATERIAL 2.0".
	PIPE SUPPORT	C3.20		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
320698	2-MS-90-06S-PS 3 AND 4	C-C	MT	1	-	-	-	-	-	-	-	-	-	-	BASE MATERIAL 2.0".
	PIPE SUPPORT	C3.20		2	-	-	-	-	-	-	-	-	-	-	
	E MS ENC			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-90 (FIG NO B-65)													
320700	2-MS-90-07S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	TEE TO CAP	C5.51	UT	2	-	-	-	C	-	-	-	-	-	
	E MS ENC			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
320710	2-MS-90-08S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320720	2-MS-90-09S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320730	2-MS-90-10S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320740	2-MS-90-11S	C-F-2	MT	1	-	-	-	-	C	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320750	2-MS-90-12S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
320760	2-MS-90-13S	C-F-2	MT	1	-	-	-	-	-	C	-	-	-	CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4	-	-	-	-	-	-	-	-	-	

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-MS-90 (FIG NO B-65)													
320770	2-MS-90-14S	C-F-2	MT	1 -	-	-	-	-	C	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
320780	2-MS-90-15S	C-F-2	MT	1 -	-	-	-	-	C	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
320790	2-MS-90-16S	C-F-2	MT	1 -	-	-	-	-	C	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
320800	2-MS-90-17S	C-F-2	MT	1 -	-	-	-	-	C	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
320810	2-MS-90-18S	C-F-2	MT	1 -	-	-	-	-	C	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
320820	2-MS-90-26	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2 C	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
320830	2-MS-90-27	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-MS-90 (FIG NO B-65)													
320840	2-MS-90-28	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
320850	2-MS-90-29	C-F-2	MT	1 -	-	-	C	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
320860	2-MS-90-30	C-F-2	MT	1 -	-	-	C	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
320870	2-MS-90-31	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
320880	2-MS-90-32	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
320890	2-MS-90-33	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
320900	2-MS-90-34	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-90 (FIG NO B-65)													
320910	2-MS-90-35	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
320920	2-MS-90-36	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
320930	2-MS-90-37	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
320940	2-MS-90-38	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
	LINE 2-MS-91 (FIG NO B-66)													
320950	2-MS-91-01F	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	NOZZLE TO ELBOW	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
320960	2-MS-91-02S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
320970	2-MS-91-03S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-91 (FIG NO B-66)													
320980	2-MS-91-04S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO REDUCER	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
320990	2-MS-91-05F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321000	2-MS-91-06F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321010	2-MS-91-07S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321020	2-MS-91-08F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	C	-	-	-	-	
	CONT. L2			3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321060	2-MS-91-09F	C-F-2	MT	1	-	-	-	-	C	-	-	-	-	WELD INACCESSIBLE FOR
	PIPE TO FLUED HEAD	C5.51	UT	2	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE BASIS FOR
				3	-	-	-	-	-	-	-	-	-	PREPARATION, SECTION 3.5. CODE
				4	-	-	-	-	-	-	-	-	-	RELIEF GRANTED FROM
														EXAMINATION.
														30-CS-X-1.00-38-DCC
321070	2-MS-91-10S-PS	C-C	MT	1	-	-	-	-	-	-	-	-	-	
	PENETRATION SUPPORT WELD	C3.20		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD			INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-91 (FIG NO B-66)																
321080	2-MS-91-11F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	-	-	WELD INACCESSIBLE FOR
	FLUED HEAD TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE BASIS FOR
				3	-	-	-	-	-	-	-	-	-	-	-	-	PREPARATION, SECTION 3.5. CODE
				4	-	-	-	-	-	-	-	-	-	-	-	-	RELIEF GRANTED FROM
																	EXAMINATION.
	LINE 2-MS-92 (FIG NO B-67)																
321090	2-MS-92-01S-PS	C-C	MT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO PENETRATION SEAL WELD	C3.20		2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
321100	2-MS-92-02F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321110	2-MS-92-03S	C-F-2	MT	1	-	-	C	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321120	2-MS-92-04F	C-F-2	MT	1	-	-	C	-	-	-	-	-	-	-	-	-	
	TEE TO VALVE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321130	2-MS-92-05F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	TEE TO TEE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-92 (FIG NO B-67)													
321135	2-MS-92-05F-PS 1 AND 2	C-C	MT	1	-	-	-	-	-	-	-	-	-	BASE MATERIAL 2.0".
	PIPE SUPPORT	C3.20		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
321140	2-MS-92-07S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	TEE TO CAP	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321145	2-MS-92-07S-PS 1 AND 2	C-C	MT	1	-	-	-	-	-	-	-	-	-	BASE MATERIAL 2.0".
	PIPE SUPPORT	C3.20		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
321150	2-MS-92-08S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	TEE TO CAP	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321160	2-MS-92-09S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2	-	-	-	-	-	-	C	-	-	
	W MS ENC			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
321170	2-MS-92-10S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
321180	2-MS-92-11S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD (OUTAGE) 1	SECOND PERIOD (OUTAGE) 2	SECOND PERIOD (OUTAGE) 3	SECOND PERIOD (OUTAGE) 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-92 (FIG NO B-67)													
321190	2-MS-92-12S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
321200	2-MS-92-13S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
321210	2-MS-92-14S	C-F-2	MT	1	-	-	-	-	C	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4	-	-	-	-	-	-	-	-	-	
321220	2-MS-92-15S	C-F-2	MT	1	-	-	-	-	C	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4	-	-	-	-	-	-	-	-	-	
321230	2-MS-92-16S	C-F-2	MT	1	-	-	-	-	C	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4	-	-	-	-	-	-	-	-	-	
321240	2-MS-92-17S	C-F-2	MT	1	-	-	-	-	C	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4	-	-	-	-	-	-	-	-	-	
321250	2-MS-92-18S	C-F-2	MT	1	-	-	-	-	C	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4	-	-	-	-	-	-	-	-	-	

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-MS-92 (FIG NO B-67)													
321260	2-MS-92-19S	C-F-2	MT	1 -	-	-	-	C	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
321270	2-MS-92-26	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
321280	2-MS-92-27	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
321290	2-MS-92-28	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
321300	2-MS-92-29	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
321310	2-MS-92-30	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
321320	2-MS-92-31	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-92 (FIG NO B-67)													
321330	2-MS-92-32	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
321340	2-MS-92-33	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
321350	2-MS-92-34	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
321360	2-MS-92-35	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
321370	2-MS-92-36	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
321380	2-MS-92-37	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
321390	2-MS-92-38	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-93 (FIG NO B-68)													
321400	2-MS-93-01F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	NOZZLE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321410	2-MS-93-02S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321420	2-MS-93-03S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321430	2-MS-93-04S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO REDUCER	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321440	2-MS-93-05F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321450	2-MS-93-06F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321460	2-MS-93-07S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-93 (FIG NO B-68)													
321470	2-MS-93-08F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321510	2-MS-93-09F	C-F-2	MT	1	-	-	-	-	C	-	-	-	-	WELD INACCESSIBLE FOR
	PIPE TO FLUED HEAD	C5.51	UT	2	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE BASIS FOR
				3	-	-	-	-	-	-	-	-	-	PREPARATION, SECTION 3.5. CODE
				4	-	-	-	-	-	-	-	-	-	RELIEF GRANTED FROM
														EXAMINATION.
														30-CS-X-1.00-38-DCC
321520	2-MS-93-10S-PS	C-C	MT	1	-	-	-	-	-	-	-	-	-	
	PENETRATION SUPPORT WELD	C3.20		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
321530	2-MS-93-11S	C-F-2	MT	1	-	-	-	-	C	-	-	-	-	WELD INACCESSIBLE FOR
	FLUED HEAD TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE BASIS FOR
				3	-	-	-	-	-	-	-	-	-	PREPARATION, SECTION 3.5. CODE
				4	-	-	-	-	-	-	-	-	-	RELIEF GRANTED FROM
														EXAMINATION.
	LINE 2-MS-94 (FIG NO B-69)													
321540	2-MS-94-01S-PS	C-C	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PENETRATION SEAL WELD	C3.20		2	-	-	-	-	-	-	-	-	-	
	W MS ENC			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
321550	2-MS-94-02F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-94 (FIG NO B-69)													
321560	2-MS-94-03S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321570	2-MS-94-21F	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321580	2-MS-94-04F	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321590	2-MS-94-05S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321600	2-MS-94-06F	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321610	2-MS-94-07S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321615	2-MS-94-07S-PS 1 AND 2	C-C	MT	1 -	-	-	-	-	-	-	-	-	-	BASE MATERIAL 2.0".
	PIPE SUPPORT	C3.20		2 -	-	-	-	-	-	-	-	-	-	
	W MS ENC			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-94 (FIG NO B-69)													
321620	2-MS-94-08S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO CAP	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321625	2-MS-94-08S-PS 1 AND 2	C-C	MT	1	-	-	-	-	-	-	-	-	-	BASE MATERIAL 2.0".
	PIPE SUPPORT	C3.20		2	-	-	-	-	-	-	-	-	-	
	W MS ENC			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
321630	2-MS-94-09S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO CAP	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321640	2-MS-94-10S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
321650	2-MS-94-11S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
321660	2-MS-94-12S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
321670	2-MS-94-13S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-MS-94 (FIG NO B-69)													
321680	2-MS-94-14S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
321690	2-MS-94-15S	C-F-2	MT	1 -	-	-	-	C	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	X	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
321700	2-MS-94-16S	C-F-2	MT	1 -	-	-	-	C	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	X	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
321710	2-MS-94-17S	C-F-2	MT	1 -	-	-	-	C	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
321720	2-MS-94-18S	C-F-2	MT	1 -	-	-	-	C	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
321730	2-MS-94-19S	C-F-2	MT	1 -	-	-	-	C	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	
321740	2-MS-94-20S	C-F-2	MT	1 -	-	-	-	C	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-	

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-MS-94 (FIG NO B-69)													
321750	2-MS-94-27S	C-F-2	MT	1	-	-	-	-	-	-	C	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4	-	-	-	-	-	-	-	-	-	
321760	2-MS-94-28	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4	-	-	-	-	-	-	-	-	-	
321770	2-MS-94-29S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4	-	-	-	-	-	-	-	-	-	
321780	2-MS-94-30	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4	-	-	-	-	-	-	-	-	-	
321790	2-MS-94-31S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4	-	-	-	-	-	-	-	-	-	
321800	2-MS-94-32	C-F-2	MT	1	-	-	-	-	-	-	C	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4	-	-	-	-	-	-	-	-	-	
321810	2-MS-94-33S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4	-	-	-	-	-	-	-	-	-	

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-94 (FIG NO B-69)													
321820	2-MS-94-34	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4	-	-	-	-	-	-	-	-	-	
321830	2-MS-94-35S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4	-	-	-	-	-	-	-	-	-	
321840	2-MS-94-36	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4	-	-	-	-	-	-	-	-	-	
321850	2-MS-94-37S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4	-	-	-	-	-	-	-	-	-	
321860	2-MS-94-38	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4	-	-	-	-	-	-	-	-	-	
321870	2-MS-94-39	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
	LINE 2-MS-95 (FIG NO B-70)													
321880	2-MS-95-01F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	NOZZLE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-95 (FIG NO B-70)														
321890	2-MS-95-02S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321900	2-MS-95-03S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321910	2-MS-95-04S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO REDUCER	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321920	2-MS-95-05F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321930	2-MS-95-06F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321940	2-MS-95-07S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
321950	2-MS-95-08F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-MS-95 (FIG NO B-70)													
321990	2-MS-95-09F	C-F-2	MT	1	-	-	-	C	-	-	-	-	-	WELD INACCESSIBLE FOR
	PIPE TO FLUED HEAD	C5.51	UT	2	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE BASIS FOR
				3	-	-	-	-	-	-	-	-	-	PREPARATION, SECTION 3.5. CODE
				4	-	-	-	-	-	-	-	-	-	RELIEF GRANTED FROM
														EXAMINATION.
														30-CS-X-1.00-38-DCC
322000	2-MS-95-10F-PS	C-C	MT	1	-	-	-	-	-	-	-	-	-	
	PENETRATION SUPPORT WELD	C3.20		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
322010	2-MS-95-11S	C-F-2	MT	1	-	-	-	-	C	-	-	-	-	WELD INACCESSIBLE FOR
	FLUED HEAD TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE BASIS FOR
				3	-	-	-	-	-	-	-	-	-	PREPARATION, SECTION 3.5. CODE
				4	-	-	-	-	-	-	-	-	-	RELIEF GRANTED FROM
														EXAMINATION.
	LINE 2-MS-96 (FIG NO B-71)													
322020	2-MS-96-01S-PS	C-C	MT	1	-	-	-	-	-	-	-	-	-	BASE MATERIAL 1.0".
	PENETRATION SEAL WELD	C3.20		2	-	-	-	-	-	-	-	-	-	
	E MS ENC			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
322030	2-MS-96-02F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PENETRATION TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
322040	2-MS-96-03S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-MS-96 (FIG NO B-71)													
322050	2-MS-96-04F	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO VALVE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
322060	2-MS-96-05F	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO TEE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
322065	2-MS-96-05F-PS 1 AND 2	C-C	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT	C3.20		2 -	-	-	-	-	-	-	-	-	-	
	E MS ENC			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
322070	2-MS-96-06S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO CAP	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
322075	2-MS-96-06S-PS 1 AND 2	C-C	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT	C3.20		2 -	-	-	-	-	-	-	-	-	-	
	E MS ENC			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
322080	2-MS-96-07S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO CAP	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**30-CS-X-1.00-38-DCC**
322090	2-MS-96-08S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY / ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-96 (FIG NO B-71)													
322110	2-MS-96-09S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322130	2-MS-96-10S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322150	2-MS-96-11S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322170	2-MS-96-12S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322180	2-MS-96-13S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4	-	-	-	-	-	-	-	-	-	
322190	2-MS-96-14S	C-F-2	MT	1	-	-	-	-	C	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4	-	-	-	-	-	-	-	-	-	
322200	2-MS-96-15S	C-F-2	MT	1	-	-	-	-	C	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4	-	-	-	-	-	-	-	-	-	

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-96 (FIG NO B-71)														
322210	2-MS-96-16S	C-F-2	MT	1 -	-	-	-	C	-	-	-	-	-		CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-		2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-		EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-		
322220	2-MS-96-17S	C-F-2	MT	1 -	-	-	-	C	-	-	-	-	-		CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-		2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-		EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-		
322230	2-MS-96-18S	C-F-2	MT	1 -	-	-	-	C	-	-	-	-	-		CODE RELIEF GRANTED 1ST AND
	PIPE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-		2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-		EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-		
322240	2-MS-96-25	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-		CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-		2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-		EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-		
322250	2-MS-96-26	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-		CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-		2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-		EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-		
322260	2-MS-96-27S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-		CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-		2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-		EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-		
322270	2-MS-96-28	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-		CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-		2ND INTERVALS FROM VOLUMETRIC
				3 -	-	-	-	-	-	-	-	-	-		EXAMINATION. SEE APPENDIX E.
				4 -	-	-	-	-	-	-	-	-	-		

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1 2 3	SECOND PERIOD 1 2 3 4	THIRD PERIOD 1 2 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-96 (FIG NO B-71)						
322280	2-MS-96-29S	C-F-2	MT	1 - - -	- - - -	- - -	CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2 - - -	- - - -	- - -	2ND INTERVALS FROM VOLUMETRIC
				3 - - -	- - - -	- - -	EXAMINATION. SEE APPENDIX E.
				4 - - -	- - - -	- - -	
322290	2-MS-96-30	C-F-2	MT	1 - - -	- - - -	- - -	CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2 - - -	- - - -	- - -	2ND INTERVALS FROM VOLUMETRIC
				3 - - -	- - - -	- - -	EXAMINATION. SEE APPENDIX E.
				4 - - -	- - - -	- - -	
322300	2-MS-96-31S	C-F-2	MT	1 - - -	- - - -	- - -	CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2 - - -	- - - -	- - -	2ND INTERVALS FROM VOLUMETRIC
				3 - - -	- - - -	- - -	EXAMINATION. SEE APPENDIX E.
				4 - - -	- - - -	- - -	
322310	2-MS-96-32	C-F-2	MT	1 - - -	- - - -	- - -	CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2 - - -	C - - -	- - -	2ND INTERVALS FROM VOLUMETRIC
	E MS ENC			3 - - -	- - - -	- - -	EXAMINATION. SEE APPENDIX E.
				4 - - -	- - - -	- - -	
322320	2-MS-96-33S	C-F-2	MT	1 - - -	- - - -	- - -	CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2 - - -	- - - -	- - -	2ND INTERVALS FROM VOLUMETRIC
				3 - - -	- - - -	- - -	EXAMINATION. SEE APPENDIX E.
				4 - - -	- - - -	- - -	
322330	2-MS-96-34	C-F-2	MT	1 - - -	- - - -	- - -	CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2 - - -	- - - -	- - -	2ND INTERVALS FROM VOLUMETRIC
				3 - - -	- - - -	- - -	EXAMINATION. SEE APPENDIX E.
				4 - - -	- - - -	- - -	
322340	2-MS-96-35S	C-F-2	MT	1 - - -	- - - -	- - -	CODE RELIEF GRANTED 1ST AND
	SADDLE TO PIPE	C5.51	UT	2 - - -	- - - -	- - -	2ND INTERVALS FROM VOLUMETRIC
				3 - - -	- - - -	- - -	EXAMINATION. SEE APPENDIX E.
				4 - - -	- - - -	- - -	

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-96 (FIG NO B-71)														
322350	2-MS-96-36	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	CODE RELIEF GRANTED 1ST AND
	SADDLE TO BRANCH CONNECTION	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	2ND INTERVALS FROM VOLUMETRIC
				3	-	-	-	-	-	-	-	-	-	-	EXAMINATION. SEE APPENDIX E.
				4	-	-	-	-	-	-	-	-	-	-	
322360	2-MS-96-37	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
	LINE 2-MS-193 (FIG NO B-72)														
322370	2-MS-193-01F	C-F-2	MT	1	-	-	-	-	C	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322380	2-MS-193-02S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322390	2-MS-193-03S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322400	2-MS-193-04S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322410	2-MS-193-05F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS — FIRST PERIOD (OUTAGE 1 2 3)	SECOND PERIOD (OUTAGE 1 2 3 4)	THIRD PERIOD (OUTAGE 1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-193 (FIG NO B-72)						
322420	2-MS-193-06S	C-F-2	MT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**6-CS-80-.432-13-DCC**
322430	2-MS-193-07S	C-F-2	MT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**6-CS-80-.432-13-DCC**
322440	2-MS-193-08S	C-F-2	MT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**6-CS-80-.432-13-DCC**
322450	2-MS-193-09S	C-F-2	MT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**6-CS-80-.432-13-DCC**
322470	2-MS-193-10F	C-F-2	MT	1 - - -	- - - -	- - -	
	ELBOW TO VALVE	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**6-CS-80-.432-13-DCC**
322480	2-MS-193-11F	C-F-2	MT	1 - - -	- - - -	- - -	
	VALVE TO PIPE	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**6-CS-80-.432-13-DCC**
322490	2-MS-193-12F	C-F-2	MT	1 - - -	- - - -	- - -	
	PIPE TO VALVE	C5.51	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**6-CS-80-.432-13-DCC**

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-194 (FIG NO B-73)													
322500	2-MS-194-01F	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322510	2-MS-194-02S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322520	2-MS-194-03S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322530	2-MS-194-04S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322540	2-MS-194-05F	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322550	2-MS-194-06S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322560	2-MS-194-07S	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-194 (FIG NO B-73)													
322570	2-MS-194-08S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322580	2-MS-194-09S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322600	2-MS-194-10F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322610	2-MS-194-11F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322620	2-MS-194-12F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
	LINE 2-MS-195 (FIG NO B-74)													
322630	2-MS-195-01F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322640	2-MS-195-02S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-MS-195 (FIG NO B-74)													
322650	2-MS-195-03S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322660	2-MS-195-04F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322670	2-MS-195-05S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322690	2-MS-195-06S	C-F-2	MT	1	-	-	-	-	-	-	C	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322710	2-MS-195-07S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO.PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322730	2-MS-195-08S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322740	2-MS-195-09S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-MS-195 (FIG NO B-74)													
322750	2-MS-195-10F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322760	2-MS-195-11F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322770	2-MS-195-12F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
	LINE 2-MS-196 (FIG NO B-75)													
322780	2-MS-196-01F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322790	2-MS-196-02S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322800	2-MS-196-03S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**
322810	2-MS-196-04S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-196 (FIG NO B-75)														
322820	2-MS-196-05S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**6-CS-80-.432-13-DCC**
322840	2-MS-196-06S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**6-CS-80-.432-13-DCC**
322860	2-MS-196-07S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**6-CS-80-.432-13-DCC**
322880	2-MS-196-08S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-		
	PIPE TO ELBOW	C5.51	UT	2	-	-	-	C	-	-	-	-	-		
	W MS ENC			3	-	-	-	X	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**6-CS-80-.432-13-DCC**
322890	2-MS-196-09S	C-F-2	MT	1	-	-	-	-	-	-	-	-	-		
	ELBOW TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**6-CS-80-.432-13-DCC**
322900	2-MS-196-10F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-		
	PIPE TO VALVE	C5.51	UT	2	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**6-CS-80-.432-13-DCC**
322910	2-MS-196-11F	C-F-2	MT	1	-	-	-	-	-	-	-	-	-		
	VALVE TO PIPE	C5.51	UT	2	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**6-CS-80-.432-13-DCC**

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-MS-196 (FIG NO B-75)													
322920	2-MS-196-12F	C-F-2	MT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.51	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**6-CS-80-.432-13-DCC**

SAFETY INJECTION PUMP NO. 1 (FIGURE B-76)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	INTEGRAL ATTACHMENTS													
322923	SUPPORTS	C-C C3.30	PT	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION PUMP NO. 2 (FIGURE B-76)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	PLAN STATUS FIRST PERIOD 2	3	OUTAGE 1	SECOND PERIOD 2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	INTEGRAL ATTACHMENTS													
322925	SUPPORTS	C-C C3.30	PT	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

RESIDUAL HEAT REMOVAL PUMP NO. 1 (FIGURE B-77)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	INTEGRAL ATTACHMENTS													
322930	SUPPORTS	C-C C3.30	PT	1 -	-	-	-	-	-	-	-	-	-	
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

RESIDUAL HEAT REMOVAL PUMP NO. 2 (FIGURE B-77)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD OUTAGE 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	INTEGRAL ATTACHMENTS													
322940	SUPPORTS	C-C	PT	1 -	-	-	-	-	-	-	-	-	-	
		C3.30		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

MAIN STEAM ISOLATION VALVE-LINE 2-MS-90(B-78,B-79)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	VALVE BODY WELDS														
322950	MSIV-MRV-210-1	C-G	MT	1	-	-	-	-	-	-	-	-	-		
	CYLINDER WELD	C6.20		2	-	-	-	C	-	-	-	-	-		
	E MS ENC			3	-	-	-	X	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
	INTEGRAL ATTACHMENTS														
322960	MSIV-MRV-210-S1	C-C	MT	1	-	-	-	-	-	-	-	-	-		
		C3.40		2	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
322970	MSIV-MRV-210-S2	C-C	MT	1	-	-	-	-	-	-	-	-	-		
		C3.40		2	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
	PRESSURE RETAINING BOLTING (>2")														
322980	MSIV-MRV-210	C-D	UT	1	-	-	-	-	-	-	-	-	-		
	FLANGE BOLTING	C4.40		2	-	-	-	-	-	-	C	-	-		
	E MS ENC			3	-	-	-	-	-	-	X	-	-		
				4	-	-	-	-	-	-	-	-	-		**2.75-S-8-CS-40-DCC**

MAIN STEAM ISOLATION VALVE-LINE 2-MS-92(B-78,B-79)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	VALVE BODY WELDS													
323000	MSIV-MRV-220-1	C-G	MT	1	-	-	-	-	-	-	-	-	-	
	CYLINDER WELD	C6.20		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	INTEGRAL ATTACHMENTS													
323010	MSIV-MRV-220-S1	C-C	MT	1	-	-	-	-	-	-	-	-	-	
		C3.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
323020	MSIV-MRV-220-S2	C-C	MT	1	-	-	-	-	-	-	-	-	-	
		C3.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	PRESSURE RETAINING BOLTING (>2")													
323030	MSIV-MRV-220	C-D	UT	1	-	-	-	-	-	-	-	-	-	
	FLANGE BOLTING	C4.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**2.75-S-8-CS-40-DCC**

MAIN STEAM ISOLATION VALVE-LINE 2-MS-94(B-78,B-79)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD (OUTAGE) 1	SECOND PERIOD (OUTAGE) 2	SECOND PERIOD (OUTAGE) 3	SECOND PERIOD (OUTAGE) 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	VALVE BODY WELDS													
323050	MSIV-MRV-230-1	C-G	MT	1	-	-	-	-	-	-	-	-	-	
	CYLINDER WELD	C6.20		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	INTEGRAL ATTACHMENTS													
323060	MSIV-MRV-230-S1	C-C	MT	1	-	-	-	-	-	-	-	-	-	
		C3.40		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
323070	MSIV-MRV-230-S2	C-C	MT	1	-	-	-	-	-	-	-	-	-	
		C3.40		2	-	-	-	-	C	-	-	-	-	
	W MS ENC			3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	PRESSURE RETAINING BOLTING (>2")													
323080	MSIV-MRV-230	C-D	UT	1	-	-	-	-	-	-	-	-	-	
	FLANGE BOLTING	C4.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**2.75-S-8-CS-40-DCC**

MAIN STEAM ISOLATION VALVE-LINE 2-MS-96(B-78,B-79)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	VALVE BODY WELDS													
323100	MSIV-MRV-240-1	C-G	MT	1	-	-	-	-	-	-	-	-	-	
	CYLINDER WELD	C6.20		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	INTEGRAL ATTACHMENTS													
323110	MSIV-MRV-240-S1	C-C	MT	1	-	-	-	-	-	-	-	-	-	
		C3.20		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
323120	MSIV-MRV-240-S2	C-C	MT	1	-	-	-	-	-	-	-	-	-	
		C3.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	PRESSURE RETAINING BOLTING (>2")													
323130	MSIV-MRV-240	C-D	UT	1	-	-	-	-	-	-	-	-	-	
	FLANGE BOLTING	C4.40		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**2.75-S-8-CS-40-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-10 (FIG NO B-80)													
324500	2-SI-10-01F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO VALVE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**8-SS-10-.148-16-DCC**
324505	2-SI-10-02F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO TEE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**8-SS-10-.148-16-DCC**
324510	2-SI-10-03S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**8-SS-10-.148-16-DCC**
324515	2-SI-10-04S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**8-SS-10-.148-16-DCC**
324520	2-SI-10-05S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**8-SS-10-.148-16-DCC**
324525	2-SI-10-06F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**8-SS-10-.148-16-DCC**
324530	2-SI-10-07S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**8-SS-10-.148-16-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-10 (FIG NO B-80)													
324535	2-SI-10-08S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-SS-40-.280-28-DCC**
324540	2-SI-10-09F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-SS-40-.280-28-DCC**
324545	2-SI-10-10F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO REDUCER	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-SS-40-.280-28-DCC**
324550	2-SI-10-11F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO TEE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-SS-40-.280-28-DCC**
324555	2-SI-10-12S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO FLANGE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-SS-40-.280-28-DCC**
324560	2-SI-10-13F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-SS-40-.280-28-DCC**
324565	2-SI-10-14S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**6-SS-40-.280-28-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD (OUTAGE 1 2 3)	SECOND PERIOD (OUTAGE 1 2 3 4)	THIRD PERIOD (OUTAGE 1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-10 (FIG NO B-80)						
324570	2-SI-10-15S	C-F-1	PT	1 - - -	- - - -	- - -	
	ELBOW TO REDUCER	C5.21H	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**6-SS-40-.280-28-DCC**
324575	2-SI-10-16S	C-F-1	PT	1 - - -	- - - -	- - -	
	REDUCER TO FLANGE	C5.21H	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**4-SS-10S-.120-21-DCC**
324580	2-SI-10-17F	C-F-1	PT	1 - - -	- - - -	- - -	
	REDUCER TO PIPE	C5.21H	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**6-SS-40-.280-28-DCC**
324585	2-SI-10-18S	C-F-1	PT	1 - - -	- - - -	- - -	
	PIPE TO TEE	C5.21H	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**6-SS-40-.280-28-DCC**
324590	2-SI-10-19F	C-F-1	PT	1 - - -	- - - -	- - -	
	TEE TO CAPE	C5.21H	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**4-SS-10S-.120-21-DCC**
324595	2-SI-10-20S	C-F-1	PT	1 - - -	- - - -	- - -	
	TEE TO PIPE	C5.21H	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**6-SS-40-.280-28-DCC**
324600	2-SI-10-21S	C-F-1	PT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	C5.21H	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**6-SS-40-.280-28-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-10 (FIG NO B-80)													
324605	2-SI-10-22S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**6-SS-40-.280-28-DCC**
324610	2-SI-10-23F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**6-SS-40-.280-28-DCC**
324615	2-SI-10-24F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**6-SS-40-.280-28-DCC**
324620	2-SI-10-25F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**6-SS-40-.280-28-DCC**
324625	2-SI-10-26S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO FLANGE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**6-SS-40-.280-28-DCC**
324630	2-SI-10-27S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**6-SS-40-.280-28-DCC**
324635	2-SI-10-28S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**6-SS-40-.280-28-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-10 (FIG NO B-80)													
324640	2-SI-10-29S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO REDUCER	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**6-SS-40-.280-28-DCC**
324645	2-SI-10-30S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	REDUCER TO FLANGE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-10S-.120-21-DCC**
	LINE 2-SI-10A (FIG NO B-81)													
324700	2-SI-10A-01F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**8-SS-10-.148-16-DCC**
324705	2-SI-10A-02S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**8-SS-10-.148-16-DCC**
324710	2-SI-10A-03S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**8-SS-10-.148-16-DCC**
324715	2-SI-10A-04S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**8-SS-10-.148-16-DCC**
324720	2-SI-10A-05S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**8-SS-10-.148-16-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-10A (FIG NO B-81)													
324725	2-SI-10A-06S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**8-SS-10-.148-16-DCC**
324730	2-SI-10A-07S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**8-SS-10-.148-16-DCC**
324735	2-SI-10A-08S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**8-SS-10-.148-16-DCC**
324740	2-SI-10A-09F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**8-SS-10-.148-16-DCC**
324745	2-SI-10A-10F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**8-SS-10-.148-16-DCC**
	LINE 2-SI-42A (FIG NO B-82)													
325000	2-SI-42A-01S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	FLANGE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**2.5-SS-40-.203-15-DCC**
325010	2-SI-42A-02S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS — FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-42A (FIG NO B-82)													
325020	2-SI-42A-03F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325030	2-SI-42A-04F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO VALVE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325040	2-SI-42A-05F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325050	2-SI-42A-06S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325060	2-SI-42A-07F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325070	2-SI-42A-08F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
	LINE 2-SI-42 (FIG NO B-83)													
325500	2-SI-42-01S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	FLANGE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**2.5-SS-40-.203-15-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-42 (FIG NO B-83)													
325510	2-SI-42-02S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325520	2-SI-42-03F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	X	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325530	2-SI-42-04F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO VALVE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325540	2-SI-42-05F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325550	2-SI-42-06S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325560	2-SI-42-07S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325570	2-SI-42-08F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO BRANCH CONNECTION	C5.21H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
							OUTAGE							
	LINE 2-SI-42 (FIG NO B-83)													
325580	2-SI-42-09F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325590	2-SI-42-10S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325600	2-SI-42-11S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	X	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325610	2-SI-42-12S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325620	2-SI-42-13S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	X	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325630	2-SI-42-14S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325640	2-SI-42-15S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-42 (FIG NO B-83)													
325650	2-SI-42-16F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325660	2-SI-42-17S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325670	2-SI-42-18S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	FLANGE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325680	2-SI-42-19F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325690	2-SI-42-20F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325700	2-SI-42-21S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325710	2-SI-42-22S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD (OUTAGE) 1	SECOND PERIOD (OUTAGE) 2	SECOND PERIOD (OUTAGE) 3	SECOND PERIOD (OUTAGE) 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-42 (FIG NO B-83)													
325720	2-SI-42-23S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325730	2-SI-42-24F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325740	2-SI-42-25S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325750	2-SI-42-26F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325760	2-SI-42-27F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
325770	2-SI-42-28F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
325780	2-SI-42-29F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1 (OUTAGE)	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-42 (FIG NO B-83)													
325790	2-SI-42-30F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
325800	2-SI-42-31S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
325810	2-SI-42-32S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
325820	2-SI-42-33F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
325830	2-SI-42-34F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
325840	2-SI-42-35S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
325850	2-SI-42-36F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-42 (FIG NO B-83)													
325860	2-SI-42-37S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
325870	2-SI-42-38S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
325880	2-SI-42-39S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
325890	2-SI-42-40F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
325900	2-SI-42-41F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
325910	2-SI-42-42S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
325920	2-SI-42-43F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - - OUTAGE - - - - - -										
	LINE 2-SI-42 (FIG NO B-83)													
325930	2-SI-42-44S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
325940	2-SI-42-45S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
325950	2-SI-42-46F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO PENETRATION #43	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
	LINE 2-SI-42 (FIG NO B-84)													
326000	2-SI-42-47F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326010	2-SI-42-48S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326020	2-SI-42-49S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326030	2-SI-42-50S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-42 (FIG NO B-84)													
326040	2-SI-42-51F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326050	2-SI-42-52F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326060	2-SI-42-53S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326070	2-SI-42-54S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326080	2-SI-42-55F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326090	2-SI-42-56S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326100	2-SI-42-57S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - - O	U	T	A	G	E	- - - - - -			
	LINE 2-SI-42 (FIG NO B-84)													
326110	2-SI-42-58S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326120	2-SI-42-59F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326130	2-SI-42-60S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326140	2-SI-42-61S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326150	2-SI-42-62S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326160	2-SI-42-63S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326170	2-SI-42-64S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-42 (FIG NO B-84)													
326180	2-SI-42-65S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326190	2-SI-42-66F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326200	2-SI-42-67F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326210	2-SI-42-68S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326220	2-SI-42-69S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326230	2-SI-42-70S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326240	2-SI-42-71S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - - OUTAGE - - - - - -										
	LINE 2-SI-42 (FIG NO B-84)													
326250	2-SI-42-72S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326260	2-SI-42-73S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
326270	2-SI-42-74F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
	LINE 2-SI-52 (FIG NO B-85)													
326500	2-SI-52-01F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326510	2-SI-52-02S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326520	2-SI-52-03S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326530	2-SI-52-04S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-52 (FIG NO B-85)													
326540	2-SI-52-05F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326550	2-SI-52-06S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326560	2-SI-52-07S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326570	2-SI-52-08S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326580	2-SI-52-09F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326590	2-SI-52-10S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO BEND	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326600	2-SI-52-11S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	BEND TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-52 (FIG NO B-85)													
326610	2-SI-52-12S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO TEE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326620	2-SI-52-13S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326630	2-SI-52-14S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326640	2-SI-52-15S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326650	2-SI-52-16F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO BEND	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326660	2-SI-52-17F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	BEND TO VALVE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326670	2-SI-52-18F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-52 (FIG NO B-85)													
326680	2-SI-52-19S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326690	2-SI-52-20S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326700	2-SI-52-21F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326710	2-SI-52-22F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO TEE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326720	2-SI-52-23S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326730	2-SI-52-24S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326740	2-SI-52-25S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-52 (FIG NO B-85)													
326750	2-SI-52-26S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326760	2-SI-52-27S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
326770	2-SI-52-28F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO NOZZLE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
	LINE 2-SI-64 (FIG NO B-86)													
327000	2-SI-64-01F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PENETRATION #43 TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
327010	2-SI-64-02S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
327020	2-SI-64-03F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
327030	2-SI-64-04S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-64 (FIG NO B-86)													
327040	2-SI-64-05S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
327050	2-SI-64-06S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO REDUCER	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
327060	2-SI-64-07F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**2-SS-160-.344-6-DCC**
327070	2-SI-64-08F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**2-SS-160-.344-6-DCC**
327080	2-SI-64-09F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**2-SS-160-.344-6-DCC**
327090	2-SI-64-10F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO REDUCER	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
327100	2-SI-64-11F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO VALVE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (FIRST PERIOD 1 2 3 / SECOND PERIOD 1 2 3 4 / THIRD PERIOD 1 2 3 — OUTAGE)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-64 (FIG NO B-86)				
327110	2-SI-64-12F	C-F-1	PT	1 - - - - - - - - - - - -	
	VALVE TO PIPE	C5.21H	UT	2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**3378027 (4-SS-120-.430)**
327120	2-SI-64-13S	C-F-1	PT	1 - - - - - - - - - - - -	
	PIPE TO ELBOW	C5.21H	UT	2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**3378027 (4-SS-120-.430)**
327130	2-SI-64-14S	C-F-1	PT	1 - - - - - - - - - - - -	
	ELBOW TO PIPE	C5.21H	UT	2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**3378027 (4-SS-120-.430)**
327140	2-SI-64-15S	C-F-1	PT	1 - - - - - - - - - - - -	
	PIPE TO ELBOW	C5.21H	UT	2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**3378027 (4-SS-120-.430)**
327150	2-SI-64-16F	C-F-1	PT	1 - - - - - - - - - - - -	
	ELBOW TO TEE	C5.21H	UT	2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**3378027 (4-SS-120-.430)**
	LINE 2-SI-72 (FIG NO B-87)				
329000	2-SI-72-01F	C-F-1	PT	1 - - - - - - - - - - - -	
	PIPE TO ELBOW	C5.21H	UT	2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**4-SS-80-.337-20-DCC**
329010	2-SI-72-02S	C-F-1	PT	1 - - - - - - - - - - - -	
	ELBOW TO PIPE	C5.21H	UT	2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**4-SS-80-.337-20-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-72 (FIG NO B-87)													
329020	2-SI-72-03S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
329030	2-SI-72-04S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
329040	2-SI-72-05S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO FLANGE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	X	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
329050	2-SI-72-06S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	FLANGE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
329060	2-SI-72-07S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
329070	2-SI-72-08S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
329080	2-SI-72-09S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-72 (FIG NO B-87)													
329090	2-SI-72-10S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
329100	2-SI-72-11S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
329110	2-SI-72-12S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
329120	2-SI-72-13F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**4-SS-80-.337-20-DCC**
329130	2-SI-72-14F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
329140	2-SI-72-15S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
329150	2-SI-72-16F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY	ITEM NO	METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-SI-72 (FIG NO B-87)														
329160	2-SI-72-17F	C-F-1		PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.21H		UT	2	-	-	-	-	-	-	-	-	-	
					3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
329170	2-SI-72-18S	C-F-1		PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H		UT	2	-	-	-	-	-	-	-	-	-	
					3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
329180	2-SI-72-19F	C-F-1		PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H		UT	2	-	-	-	-	-	-	-	-	-	
					3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
329190	2-SI-72-20S	C-F-1		PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H		UT	2	-	-	-	-	-	-	-	-	-	
					3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
329200	2-SI-72-21S	C-F-1		PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H		UT	2	-	-	-	-	-	-	-	-	-	
					3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
329210	2-SI-72-22S	C-F-1		PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H		UT	2	-	-	-	-	-	-	-	-	-	
					3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
329220	2-SI-72-23F	C-F-1		PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H		UT	2	-	-	-	-	-	-	-	-	-	
					3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-72 (FIG NO B-88)													
329300	2-SI-72-24S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
329310	2-SI-72-25F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
329320	2-SI-72-26S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
329330	2-SI-72-27S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
329340	2-SI-72-28S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
329350	2-SI-72-29S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
329360	2-SI-72-30F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD (OUTAGE 1 2 3)	SECOND PERIOD (OUTAGE 1 2 3 4)	THIRD PERIOD (OUTAGE 1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-72 (FIG NO B-88)						
329370	2-SI-72-31S	C-F-1	PT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	C5.21H	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378027 (4-SS-120-.430)**
329380	2-SI-72-32S	C-F-1	PT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	C5.21H	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378027 (4-SS-120-.430)**
329390	2-SI-72-33S	C-F-1	PT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	C5.21H	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378027 (4-SS-120-.430)**
329400	2-SI-72-34S	C-F-1	PT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	C5.21H	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378027 (4-SS-120-.430)**
329410	2-SI-72-35S	C-F-1	PT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	C5.21H	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378027 (4-SS-120-.430)**
329420	2-SI-72-36F	C-F-1	PT	1 - - -	- - - -	- - -	
	PIPE TO PIPE	C5.21H	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378027 (4-SS-120-.430)**
329430	2-SI-72-37S	C-F-1	PT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	C5.21H	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378027 (4-SS-120-.430)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-72 (FIG NO B-88)													
329440	2-SI-72-38S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
329450	2-SI-72-39F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
329460	2-SI-72-40S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
329470	2-SI-72-41S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
329480	2-SI-72-42S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
329490	2-SI-72-43S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
329500	2-SI-72-44S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-72 (FIG NO B-88)													
329510	2-SI-72-45F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO PENETRATION #68	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
	LINE 2-SI-73 (FIG NO B-89)													
330000	2-SI-73-01F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	NOZZLE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378028 (6-SS-160-.71)**
330010	2-SI-73-02S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	X	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330020	2-SI-73-03S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330030	2-SI-73-04F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330040	2-SI-73-05S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330050	2-SI-73-06F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-73 (FIG NO B-89)													
330060	2-SI-73-07S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330070	2-SI-73-08S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330080	2-SI-73-09F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330090	2-SI-73-10S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330100	2-SI-73-11F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
	LINE 2-SI-73 (FIG NO B-90)													
330200	2-SI-73-12S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330210	2-SI-73-13S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO BEND	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-73 (FIG NO B-90)													
330220	2-SI-73-14S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	BEND TO TEE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330230	2-SI-73-15S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330240	2-SI-73-16F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330270	2-SI-73-19F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330280	2-SI-73-20S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330290	2-SI-73-21S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO BEND	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330300	2-SI-73-22S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	BEND TO BEND	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY	ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-73 (FIG NO B-90)														
330310	2-SI-73-23F	C-F-1		PT	1	-	-	-	-	-	-	-	-	-	
	BEND TO VALVE	C5.21H		UT	2	-	-	-	-	-	-	-	-	-	
					3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
	LINE 2-SI-75 (FIG NO B-91)														
330500	2-SI-75-01F	C-F-1		PT	1	-	-	-	-	-	-	-	-	-	
	PENETRATION #68	C5.21H		UT	2	-	-	-	-	-	-	-	-	-	
					3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**TO BE DETERMINED**
330510	2-SI-75-02F	C-F-1		PT	1	-	-	-	-	-	-	-	-	-	
	PENETRATION #68 TO ELBOW	C5.21H		UT	2	-	-	-	-	-	-	-	-	-	
					3	-	-	-	-	X	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330520	2-SI-75-03S	C-F-1		PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H		UT	2	-	-	-	-	-	-	-	-	-	
					3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330530	2-SI-75-04F	C-F-1		PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H		UT	2	-	-	-	-	-	-	-	-	-	
					3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330540	2-SI-75-05S	C-F-1		PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H		UT	2	-	-	-	-	-	-	-	-	-	
					3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330550	2-SI-75-06S	C-F-1		PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H		UT	2	-	-	-	-	-	-	-	-	-	
					3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-75 (FIG NO B-91)													
330560	2-SI-75-07S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330570	2-SI-75-08S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330580	2-SI-75-09S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330590	2-SI-75-10S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO REDUCER	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330600	2-SI-75-11F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	REDUCER TO BEND	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	**2-SS-160-.344-6-DCC**
330610	2-SI-75-12F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	BEND TO VALVE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**2-SS-160-.344-6-DCC**
330620	2-SI-75-13F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**2-SS-160-.344-6-DCC**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-75 (FIG NO B-91)													
330630	2-SI-75-14F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO REDUCER	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**2-SS-160-.344-6-DCC**
330640	2-SI-75-15F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	REDUCER TO VALVE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
330650	2-SI-75-16F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO TEE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
	LINE 2-SI-81 (FIG NO B-92)													
331000	2-SI-81-01F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	X	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
331010	2-SI-81-02S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
331020	2-SI-81-03S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
331030	2-SI-81-04S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-81 (FIG NO B-92)													
331040	2-SI-81-05S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
331050	2-SI-81-06S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
331060	2-SI-81-07S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
331070	2-SI-81-08S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
331080	2-SI-81-09S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
331090	2-SI-81-10S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
331100	2-SI-81-11S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-81 (FIG NO B-92)													
331110	2-SI-81-12S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
331120	2-SI-81-13S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
331130	2-SI-81-14S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
331140	2-SI-81-15S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
331150	2-SI-81-16S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
331160	2-SI-81-17S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
331170	2-SI-81-18S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1 (OUTAGE)	SECOND PERIOD 2 (OUTAGE)	SECOND PERIOD 3 (OUTAGE)	SECOND PERIOD 4 (OUTAGE)	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-81 (FIG NO B-92)													
331180	2-SI-81-19S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
331190	2-SI-81-20S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
331200	2-SI-81-21S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
331210	2-SI-81-22S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
331220	2-SI-81-23F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
331230	2-SI-81-24S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
331240	2-SI-81-25S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-81 (FIG NO B-92)																
331250	2-SI-81-26F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-82 (FIG NO B-93)														
332000	2-CS-82-01S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	FLANGE TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
332010	2-CS-82-02F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
332020	2-CS-82-03F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
332030	2-CS-82-04S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
332040	2-CS-82-05S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
332050	2-CS-82-06S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
332060	2-CS-82-07S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD (1 2 3)	SECOND PERIOD (1 2 3 4)	THIRD PERIOD (1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-82 (FIG NO B-93)						
332070	2-CS-82-08F	C-F-1	PT	1 - - -	- - - -	- - -	
	PIPE TO TEE	C5.21H	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378026 (3-SS-160-.430)**
332080	2-CS-82-09S	C-F-1	PT	1 - - -	- - - -	- - -	
	TEE TO PIPE	C5.21H	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378026 (3-SS-160-.430)**
332090	2-CS-82-10S	C-F-1	PT	1 - - -	- - - -	- - -	
	PIPE TO PIPE	C5.21H	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378026 (3-SS-160-.430)**
332100	2-CS-82-11F	C-F-1	PT	1 - - -	- - - -	- - -	
	PIPE TO PIPE	C5.21H	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378026 (3-SS-160-.430)**
332110	2-CS-82-12S	C-F-1	PT	1 - - -	- - - -	- - -	
	PIPE TO FLANGE	C5.21H	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378026 (3-SS-160-.430)**
332120	2-CS-82-13S	C-F-1	PT	1 - - -	- - - -	- - -	
	FLANGE TO PIPE	C5.21H	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378026 (3-SS-160-.430)**
332130	2-CS-82-14S	C-F-1	PT	1 - - -	- - - -	- - -	
	PIPE TO TEE	C5.21H	UT	2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	**3378026 (3-SS-160-.430)**

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CS-82 (FIG NO B-93)													
332140	2-CS-82-15S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
332150	2-CS-82-16S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
332160	2-CS-82-17S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
332170	2-CS-82-18F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
	LINE 2-CS-83 (FIG NO B-94)													
333000	2-CS-83-01S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	REDUCER TO TEE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
333010	2-CS-83-02S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
333020	2-CS-83-03S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY	NDE ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-CS-83 (FIG NO B-94)														
333030	2-CS-83-04S	C-F-1		PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H		UT	2	-	-	-	-	-	-	-	-	-	
					3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
333040	2-CS-83-05S	C-F-1		PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H		UT	2	-	-	-	-	-	-	-	-	-	
					3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
333050	2-CS-83-06S	C-F-1		PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	C5.21H		UT	2	-	-	-	-	-	-	-	-	-	
					3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
333060	2-CS-83-07S	C-F-1		PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H		UT	2	-	-	-	-	-	-	-	-	-	
					3	-	-	-	-	-	-	X	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
333070	2-CS-83-08S	C-F-1		PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	C5.21H		UT	2	-	-	-	-	-	-	-	-	-	
					3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
333080	2-CS-83-09F	C-F-1		PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO PIPE	C5.21H		UT	2	-	-	-	-	-	-	-	-	-	
					3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
333090	2-CS-83-10F	C-F-1		PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H		UT	2	-	-	-	-	-	-	-	-	-	
					3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CS-83 (FIG NO B-94)													
333100	2-CS-83-11S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
333110	2-CS-83-12S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
333120	2-CS-83-13S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
333130	2-CS-83-14S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
333140	2-CS-83-15S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
333150	2-CS-83-16S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
333160	2-CS-83-17S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CS-83 (FIG NO B-94)													
333170	2-CS-83-18S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
333180	2-CS-83-19S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
333190	2-CS-83-20F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
333200	2-CS-83-21F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
333210	2-CS-83-22F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
333220	2-CS-83-23S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
333230	2-CS-83-24F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY / ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CS-83 (FIG NO B-94)													
333240	2-CS-83-25F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
333250	2-CS-83-26S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
333260	2-CS-83-27S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
333270	2-CS-83-28F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
	LINE 2-CS-84 (FIG NO B-95)													
334000	2-CS-84-01S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	FLANGE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
334010	2-CS-84-02S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
334020	2-CS-84-03S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (FIRST PERIOD 1 2 3 / SECOND PERIOD 1 2 3 4 / THIRD PERIOD 1 2 3 — OUTAGE)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-84 (FIG NO B-95)				
334030	2-CS-84-04S	C-F-1	PT	1 - - - - - - - - - - - -	
	ELBOW TO PIPE	C5.21H	UT	2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**3378027 (4-SS-120-.430)**
334040	2-CS-84-05S	C-F-1	PT	1 - - - - - - - - - - - -	
	PIPE TO ELBOW	C5.21H	UT	2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**3378027 (4-SS-120-.430)**
334050	2-CS-84-06S	C-F-1	PT	1 - - - - - - - - - - - -	
	ELBOW TO PIPE	C5.21H	UT	2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**3378027 (4-SS-120-.430)**
334060	2-CS-84-07S	C-F-1	PT	1 - - - - - - - - - - - -	
	PIPE TO ELBOW	C5.21H	UT	2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**3378027 (4-SS-120-.430)**
334070	2-CS-84-08F	C-F-1	PT	1 - - - - - - - - - - - -	
	ELBOW TO VALVE	C5.21H	UT	2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**3378027 (4-SS-120-.430)**
334080	2-CS-84-09F	C-F-1	PT	1 - - - - - - - - - - - -	
	VALVE TO TEE	C5.21H	UT	2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**3378027 (4-SS-120-.430)**
334090	2-CS-84-10S	C-F-1	PT	1 - - - - - - - - - - - -	
	TEE TO PIPE	C5.21H	UT	2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	**3378027 (4-SS-120-.430)**

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CS-84 (FIG NO B-95)													
334100	2-CS-84-11F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
334110	2-CS-84-12S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
334120	2-CS-84-13F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
334130	2-CS-84-14F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
334140	2-CS-84-15S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
334150	2-CS-84-16S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
334160	2-CS-84-17S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	X	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - - OUTAGE - - - - - -										
	LINE 2-CS-84 (FIG NO B-95)													
334170	2-CS-84-18S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
334180	2-CS-84-19S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
334190	2-CS-84-20F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
	LINE 2-CS-85 (FIG NO B-96)													
335000	2-CS-85-01S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	FLANGE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
335010	2-CS-85-02S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
335020	2-CS-85-03S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
335030	2-CS-85-04S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-85 (FIG NO B-96)													
335040	2-CS-85-05S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
335050	2-CS-85-06S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
335060	2-CS-85-07S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
335070	2-CS-85-08F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
335080	2-CS-85-09F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO TEE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
335090	2-CS-85-10S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
335100	2-CS-85-11F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-85 (FIG NO B-96)													
335110	2-CS-85-12S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
335120	2-CS-85-13F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
335130	2-CS-85-14F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
335140	2-CS-85-15S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
335150	2-CS-85-16S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
335160	2-CS-85-17S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
335170	2-CS-85-18S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-85 (FIG NO B-96)														
335180	2-CS-85-19S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
335190	2-CS-85-20F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378027 (4-SS-120-.430)**
	LINE 2-CS-86 (FIG NO B-97)														
336000	2-CS-86-01F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
336010	2-CS-86-02S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
336020	2-CS-86-03S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
336030	2-CS-86-04S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
336040	2-CS-86-05S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CS-86 (FIG NO B-97)													
336050	2-CS-86-06S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
336060	2-CS-86-07S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
336070	2-CS-86-08F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
336080	2-CS-86-09S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
336090	2-CS-86-10F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
336100	2-CS-86-11S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
336110	2-CS-86-12S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CS-86 (FIG NO B-97)													
336120	2-CS-86-13S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
336130	2-CS-86-14F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
336140	2-CS-86-15S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	X	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
336150	2-CS-86-16S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
336160	2-CS-86-17F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
	LINE 2-CS-87 (FIG NO B-98)													
337000	2-CS-87-01F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
337010	2-CS-87-02S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	FIRST PERIOD 2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-87 (FIG NO B-98)													
337020	2-CS-87-03F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
337030	2-CS-87-04F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO VALVE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
337040	2-CS-87-05S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
337050	2-CS-87-06F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
337060	2-CS-87-07F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
337070	2-CS-87-08F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
337080	2-CS-87-09F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	OUTAGE 1	OUTAGE 2	OUTAGE 3	OUTAGE 4	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-87 (FIG NO B-98)													
337090	2-CS-87-10S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
337100	2-CS-87-11S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
337110	2-CS-87-12S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
337120	2-CS-87-13S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
337130	2-CS-87-14S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
337140	2-CS-87-15S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
337150	2-CS-87-16F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY / ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-87 (FIG NO B-98)													
337160	2-CS-87-17S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
337170	2-CS-87-18F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO ELBOW	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
337180	2-CS-87-19F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
	LINE 2-CS-103 (FIG NO B-99)													
338000	2-CS-103-01S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO TEE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
338010	2-CS-103-02S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
338020	2-CS-103-03S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
338030	2-CS-103-04S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	TEE TO REDUCER	C5.21H	UT	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CS-103 (FIG NO B-99)													
338040	2-CS-103-05S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO ELBOW	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
338050	2-CS-103-06F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO VALVE	C5.21H	UT	2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	**3378026 (3-SS-160-.430)**
	LINE 2-CS-794 (FIG NO B-100)													
339000	2-CS-794-01F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
339010	2-CS-794-02S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
339020	2-CS-794-03S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
339030	2-CS-794-04S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
339040	2-CS-794-05S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-794 (FIG NO B-100)													
339050	2-CS-794-06S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO REDUCER	C5.30H		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
339060	2-CS-794-07S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	C5.30H		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
339070	2-CS-794-08S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.30H		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
339080	2-CS-794-09S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.30H		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
339090	2-CS-794-10F	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.30H		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
339100	2-CS-794-11S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.30H		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
339110	2-CS-794-12S	C-F-1	PT	1	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.30H		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CS-794 (FIG NO B-100)													
339120	2-CS-794-13S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
339130	2-CS-794-14S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
339140	2-CS-794-15F	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-CS-794 (FIG NO B-101)													
339150	2-CS-794-16S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
339160	2-CS-794-17S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	
339170	2-CS-794-18S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
339180	2-CS-794-19S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	X	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1 2 3	PLAN STATUS FIRST PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-794 (FIG NO B-101)											
339190	2-CS-794-20F	C-F-1	PT	1	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.30H		2	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	
	LINE 2-CS-794A (FIG NO B-102)											
340000	2-CS-794A-01F	C-F-1	PT	1	-	-	-	-	-	-	-	
	TEE TO PIPE	C5.30H		2	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	
340010	2-CS-794A-02S	C-F-1	PT	1	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.30H		2	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	
340020	2-CS-794A-03S	C-F-1	PT	1	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.30H		2	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	
340030	2-CS-794A-04S	C-F-1	PT	1	-	-	-	-	-	-	-	
	PIPE TO VALVE	C5.30H		2	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	
340040	2-CS-794A-05S	C-F-1	PT	1	-	-	-	-	-	-	-	
	VALVE TO PIPE	C5.30H		2	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	
340050	2-CS-794A-06S	C-F-1	PT	1	-	-	-	-	-	-	-	
	PIPE TO REDUCER	C5.30H		2	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-794A (FIG NO B-102)													
340060	2-CS-794A-07S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	REDUCER TO PIPE	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
340070	2-CS-794A-08S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
340080	2-CS-794A-09S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
340090	2-CS-794A-10S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
340100	2-CS-794A-11S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
340110	2-CS-794A-12S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
340120	2-CS-794A-13S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CS-794A (FIG NO B-102)													
340130	2-CS-794A-14S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
340140	2-CS-794A-15S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
340150	2-CS-794A-16S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO ELBOW	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
340160	2-CS-794A-17S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
340170	2-CS-794A-18S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	PIPE TO TEE	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
340180	2-CS-794A-19S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	TEE TO ELBOW	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
340190	2-CS-794A-20S	C-F-1	PT	1 -	-	-	-	-	-	-	-	-	-	
	ELBOW TO PIPE	C5.30H		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD (OUTAGE 1 2 3)	SECOND PERIOD (OUTAGE 1 2 3 4)	THIRD PERIOD (OUTAGE 1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-794A (FIG NO B-102)						
340200	2-CS-794A-21S	C-F-1	PT	1 - - -	- - - -	- - -	
	PIPE TO VALVE	C5.30H		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
	LINE 2-CS-805 (FIG NO B-103)						
341000	2-CS-805-01S	C-F-1	PT	1 - - -	- - - -	- - -	
	REDUCER TO ELBOW	C5.30H		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
341010	2-CS-805-02S	C-F-1	PT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	C5.30H		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
341020	2-CS-805-03S	C-F-1	PT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	C5.30H		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
341030	2-CS-805-04S	C-F-1	PT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	C5.30H		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
341040	2-CS-805-05S	C-F-1	PT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	C5.30H		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
341050	2-CS-805-06S	C-F-1	PT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	C5.30H		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
				1 2 3	1 2 3 4 (OUTAGE)	1 2 3	
	LINE 2-CS-805 (FIG NO B-103)						
341060	2-CS-805-07S	C-F-1	PT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	C5.30H		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
341070	2-CS-805-08S	C-F-1	PT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	C5.30H		2 - - -	- - - -	- - -	
				3 - X -	- - - -	- - -	
				4 - - -	- - - -	- - -	
341080	2-CS-805-09S	C-F-1	PT	1 - - -	- - - -	- - -	
	PIPE TO VALVE	C5.30H		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
	LINE 2-CS-808 (FIG NO B-104)						
342000	2-CS-808-01F	C-F-1	PT	1 - - -	- - - -	- - -	
	REDUCER TO PIPE	C5.30H		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
342010	2-CS-808-02S	C-F-1	PT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	C5.30H		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
342020	2-CS-808-03S	C-F-1	PT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	C5.30H		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
342030	2-CS-808-04S	C-F-1	PT	1 - - -	- - - -	- - -	
	PIPE TO ELBOW	C5.30H		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
				1 2 3	1 2 3 4 (OUTAGE)	1 2 3	
	LINE 2-CS-808 (FIG NO B-104)						
342040	2-CS-808-05S	C-F-1	PT	1 - - -	- - - -	- - -	
	ELBOW TO PIPE	C5.30H		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
342050	2-CS-808-06S	C-F-1	PT	1 - - -	- - - -	- - -	
	PIPE TO VALVE	C5.30H		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-C-31													
500000	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
500100	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-C-64													
500200	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
500300	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-C-66, SH. 1 OF 2													
500400	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
500500	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	SEE AEP DWG. NO. 2-C-66, SH. 2 OF 2														
500600	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
500700	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-C-74, SH. 1 OF 2														
500800	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
500900	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-C-74, SH. 2 OF 2														
501000	PRESSURE RETAINING COMONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
501100	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASHE SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	SEE AEP DWG. NO. 2-AC-160, REV. 2													
501200	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
501300	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-13													
501400	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1 -	-	-	-	-	-	-	-	-	-	
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
501500	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1 -	-	-	-	-	-	-	-	-	-	
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-16													
501600	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1 -	-	-	-	-	-	-	-	-	-	
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
501700	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1 -	-	-	-	-	-	-	-	-	-	
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-17													
501800	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1 -	-	-	-	-	-	-	-	-	-	
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
501900	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1 -	-	-	-	-	-	-	-	-	-	
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	SEE AEP DWG. NO. 2-CCW-18														
502000	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
502100	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-19														
502200	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
502300	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-22														
502400	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
502500	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-26													
502510	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
502515	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-37													
502590	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
502595	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-38, SH. 2 OF 2													
502600	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
502700	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE 1 2 3	1 2 3 4	1 2 3	
	SEE AEP DWG. NO. 2-CCW-38, SH. 1 OF 2							
502800	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
502900	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-CCW-39							
503000	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
503100	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-CCW-41							
503200	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
503300	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-42, SH. 1 OF 3													
503400	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1 -	-	-	-	-	-	-	-	-	-	
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
503500	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1 -	-	-	-	-	-	-	-	-	-	
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-42, SH. 2 OF 3													
503600	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1 -	-	-	-	-	-	-	-	-	-	
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
503700	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1 -	-	-	-	-	-	-	-	-	-	
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-43, SH. 3 OF 3													
503800	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1 -	-	-	-	-	-	-	-	-	-	
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
503900	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1 -	-	-	-	-	-	-	-	-	-	
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1 2 3	SECOND PERIOD 1 2 3 4	THIRD PERIOD 1 2 3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-43, SH. 2 OF 3							
504000	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
504100	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-CCW-44							
504200	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
504300	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-CCW-45							
504400	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
504500	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	SEE AEP DWG. NO. 2-CCW-46													
504600	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
504700	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-47, SH. 1 OF 2													
504800	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
504900	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-47, SH. 2 OF 2													
505000	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
505100	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE 1 2 3	1 2 3 4	1 2 3	
	SEE AEP DWG. NO. 2-CCW-57							
505150	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
505155	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-CCW-59							
505180	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
505185	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-CCW-79							
505200	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
505300	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL ASME SEC. XI CATGY ITEM NO	NDE METH	PLAN STATUS FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-80																
505400	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
505500	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
	SEE AEP DWG. NO. 2-CCW-81																
505600	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
505700	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
	SEE AEP DWG. NO. 2-CCW-82																
505710	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
505715	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (FIRST PERIOD / SECOND PERIOD / THIRD PERIOD — OUTAGE)	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-83				
505720	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1 - - - - - - - - - - - -	
				2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	
505725	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1 - - - - - - - - - - - -	
				2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	
	SEE AEP DWG. NO. 2-CCW-86				
505730	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1 - - - - - - - - - - - -	
				2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	
505735	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1 - - - - - - - - - - - -	
				2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	
	SEE AEP DWG. NO. 2-CCW-87				
505740	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1 - - - - - - - - - - - -	
				2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	
505745	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1 - - - - - - - - - - - -	
				2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	SEE AEP DWG. NO. 2-CCW-113													
505750	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
505755	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-114													
505760	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
505765	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-127, SH. 1 OF 3													
505800	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
505900	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	SEE AEP DWG. NO. 2-CCW-127, SH. 2 OF 3													
506000	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
506100	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-128													
506120	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
506125	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-129													
506140	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
506145	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-130													
506160	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
506165	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-131, SH. 2 OF 3													
506200	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
506300	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-131, SH. 3 OF 3													
506400	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
506500	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-132													
506510	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
506515	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-133													
506520	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
506525	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-135													
506540	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
506545	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL ASME SEC. XI CATGY ITEM NO	NDE METH	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	SEE AEP DWG. NO. 2-CCW-139													
506600	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
506700	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
					1 2 3	OUTAGE 1 2 3 4	1 2 3	
	SEE AEP DWG. NO. 2-ESW-3							
510400	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
510500	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-ESW-4							
510600	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
510700	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-ESW-6							
510800	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
510900	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
						OUTAGE		
					1 2 3	1 2 3 4	1 2 3	
	SEE AEP DWG. NO. 2-ESW-7							
511000	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
511100	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-ESW-10							
511110	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
511115	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-ESW-11							
511120	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
511125	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-ESW-14													
511130	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
511135	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-ESW-16													
511140	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
511145	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-ESW-19													
511150	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
511155	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-ESW-20													
511160	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1 -	-	-	-	-	-	-	-	-	-	
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
511165	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1 -	-	-	-	-	-	-	-	-	-	
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-ESW-22													
511170	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1 -	-	-	-	-	-	-	-	-	-	
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
511175	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1 -	-	-	-	-	-	-	-	-	-	
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-ESW-24													
511180	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1 -	-	-	-	-	-	-	-	-	-	
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
511185	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1 -	-	-	-	-	-	-	-	-	-	
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	SEE AEP DWG. NO. 2-ESW-25													
511200	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
511300	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-ESW-26													
511400	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
511500	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-ESW-32													
511580	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
511585	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE 1 2 3	1 2 3 4	1 2 3	
	SEE AEP DWG. NO. 2-ESW-34							
511600	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
511700	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-ESW-36							
511800	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
511900	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-ESW-38							
512000	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
512100	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-ESW-42													
512200	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
512300	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-ESW-48													
512400	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
512500	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-ESW-49													
512600	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
512700	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-ESW-50													
512800	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
512900	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-ESW-53													
513000	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
513100	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-ESW-54													
513200	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
513300	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD (OUTAGE 1 2 3)	SECOND PERIOD (OUTAGE 1 2 3 4)	THIRD PERIOD (OUTAGE 1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-ESW-55							
513400	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
513500	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-ESW-58							
513600	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
513700	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-ESW-59							
513800	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
513900	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD (OUTAGE 1 2 3)	SECOND PERIOD (OUTAGE 1 2 3 4)	THIRD PERIOD (OUTAGE 1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-ESW-63							
514000	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
514100	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-ESW-66, SH. 1 OF 2							
514200	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
514300	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-ESW-66, SH. 2 OF 2							
514400	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
514500	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	FIRST PERIOD 1 2 3	SECOND PERIOD 1 2 3 4	THIRD PERIOD 1 2 3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-ESW-67, SH. 1 OF 2							
514600	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
514700	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-ESW-67, SH. 2 OF 2							
514800	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
514900	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 12-GESW-X-1, SH. 1 OF 2							
515000	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
515100	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	SEE AEP DWG. NO. 12-GESW-X-2													
515200	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
515300	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	FIRST PERIOD 2	3	OUTAGE 1	SECOND PERIOD 2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-20													
520000	PRESSURE RETAINING COMPONENTS	D-B D2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
520010	INTEGRAL ATTACHMENTS	D-B D2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-32													
521200	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
521210	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-33													
521300	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
521310	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-37													
521700	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
521710	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-38													
521800	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
521810	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-44													
522400	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
522410	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE 1 2 3	1 2 3 4	1 2 3	
	SEE AEP DWG. NO. 2-FW-45							
522500	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
522510	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-FW-48							
522800	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
522810	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-FW-50							
523500	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
523510	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL ASME SEC. XI CATGY ITEM NO	NDE METH	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-53, SH. 1 OF 4													
524100	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
524110	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-53, SH. 2 OF 4													
524200	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
524210	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-53, SH. 3 OF 4													
524300	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
524310	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
				1 2 3	1 2 3 4 (OUTAGE)	1 2 3	
	SEE AEP DWG. NO. 2-FW-53, SH. 4 OF 4						
524400	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1 - - -	- - - -	- - -	
				2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
524410	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1 - - -	- - - -	- - -	
				2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-FW-54, SH. 1 OF 4						
524500	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1 - - -	- - - -	- - -	
				2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
524510	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1 - - -	- - - -	- - -	
				2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-FW-54, SH. 2 OF 4						
524600	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1 - - -	- - - -	- - -	
				2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
524610	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1 - - -	- - - -	- - -	
				2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD	SECOND PERIOD (OUTAGE)	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
				1 2 3	1 2 3 4	1 2 3	
	SEE AEP DWG. NO. 2-FW-54, SH. 3 OF 4						
524700	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1 - - -	- - - -	- - -	
				2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
524710	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1 - - -	- - - -	- - -	
				2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-FW-54, SH. 4 OF 4						
524800	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1 - - -	- - - -	- - -	
				2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
524810	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1 - - -	- - - -	- - -	
				2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-FW-55, SH. 1 OF 4						
525000	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1 - - -	- - - -	- - -	
				2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
525010	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1 - - -	- - - -	- - -	
				2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-55, SH. 2 OF 4														
525100	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
525110	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-55, SH. 3 OF 4														
525200	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
525210	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-55, SH. 4 OF 4														
525300	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
525310	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	FIRST PERIOD 1 2 3	SECOND PERIOD 1 2 3 4	THIRD PERIOD 1 2 3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-56, SH. 1 OF 2							
525400	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
525410	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-FW-56, SH. 2 OF 2							
525500	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
525510	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-FW-57, SH. 1 OF 2							
525600	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
525610	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE 1 2 3	1 2 3 4	1 2 3	
	SEE AEP DWG. NO. 2-FW-57, SH. 2 OF 2							
525700	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
525710	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-FW-88							
526500	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
526510	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-FW-89							
526600	PRESSURE RETAINING COMPONENTS	D-B F2.10	VT-2	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
526610	INTEGRAL ATTACHMENTS	D-B F2.20	VT-3	1	- - -	- - - -	- - -	
				2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

COOK NUCLEAR PLANT UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 1 ALL STATUS COMPONENTS

PRESSURIZER

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - -			O U T A G E				- - - - - -			
	SUPPORT COMPONENT (FIG NO A-4)													
600002	2-PRZ-SUPPORT	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
		F1.40		2 -	-	-	C	-	-	-	-	-	-	
				3 -	X	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

STEAM GENERATORS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	VESSEL SUPPORTS															
600004	STM-21-SUPPORT	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
		F1.40		2	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-		
600005	STM-22-SUPPORT	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
		F1.40		2	-	-	-	C	-	-	-	-	-	-		
				3	-	-	-	X	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-		
600006	STM-23-SUPPORT	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
		F1.40		2	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-		
600007	STM-24-SUPPORT	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
		F1.40		2	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-		

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-RC-21 (FIG NO A-19)														
600010	2-GRC-R-619	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10A		2	C	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-22 (FIG NO A-20)														
600060	2-GRC-R-605	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WB		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
600100	2-GRC-C-606	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10C		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
600200	2-GRC-S-609	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10S		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
600300	2-GRC-C-608	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10C		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-23 (FIG NO A-21)														
600350	2-GRC-C-610	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10C		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-27 (FIG NO A-25)														
600380	2-GRC-S-596	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WS		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-28 (FIG NO A-26)														
600400	2-GRC-R-500	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10C		2	-	-	-	-	C	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
600500	2-GRC-R-521	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2	-	-	-	-	C	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	
600600	2-GRC-R-502	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2	-	-	-	-	C	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
600700	2-GRC-R-524	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2	-	-	-	-	C	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
600800	2-GRC-R-503	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WB		2	-	-	-	-	C	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-28 (FIG NO A-27)														
600900	2-GRC-V-505	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10C		2	-	-	-	-	C	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY	NDE ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-28 (FIG NO A-27)														
601000	2-GRC-R-621	F-A		VT-3	1 -	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WB			2 -	-	-	-	C	-	-	-	-	-	
	CONT. PRT				3 -	-	-	-	-	-	-	-	-	-	
					4 -	-	-	-	-	-	-	-	-	-	
601100	2-GRC-C-515	F-A		VT-3	1 -	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10BC			2 -	-	-	-	C	-	-	-	-	-	
	PRESS.				3 -	-	-	-	-	-	-	-	-	-	
					4 -	-	-	-	-	-	-	-	-	-	
601200	2-ARC-R-522B	F-A		VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10B			2 -	-	-	-	C	-	-	-	-	-	
	PRESS.				3 -	-	-	-	X	-	-	-	-	-	
					4 -	-	-	-	-	-	-	-	-	-	
601300	2-GRC-S-623	F-A		VT-3	1 -	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10S			2 C	-	-	-	-	-	-	-	-	-	
					3 -	-	-	-	-	-	-	-	-	-	
					4 -	-	-	-	-	-	-	-	-	-	
601400	2-GRC-C-519	F-A		VT-3	1 -	-	-	C	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10C			2 -	-	-	-	C	-	-	-	-	-	
	PRESS. DH				3 -	-	-	-	-	-	-	-	-	-	
					4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-29 (FIG NO A-28)														
601500	2-GRC-R-504	F-A		VT-3	1 -	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA			2 -	-	-	-	-	-	-	C	-	-	
	CONT. PRT				3 -	X	-	-	-	-	-	-	-	-	
					4 -	-	-	-	-	-	-	-	-	-	
601600	2-GRC-R-501	F-A		VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA			2 -	-	-	-	-	-	-	-	-	-	
					3 -	-	-	-	-	-	-	-	-	-	
					4 -	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD (OUTAGE) 1	SECOND PERIOD (OUTAGE) 2	SECOND PERIOD (OUTAGE) 3	SECOND PERIOD (OUTAGE) 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-29 (FIG NO A-28)														
601700	2-GRC-R-525	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-30 (FIG NO A-29)														
601800	2-GRC-R-534	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WB		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
601900	2-GRC-R-506	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2	-	-	-	-	-	-	-	-	X	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-31 (FIG NO A-30)														
602000	2-GRC-R-540	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10WB		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
602100	2-GRC-R-539	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
602200	2-GRC-S-537	F-A	VT-3	1	-	-	-	C	-	-	-	C	-	-	
	PIPE RESTRAINT COMPONENT	F1.10S		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-31 (FIG NO A-31)														
602300	2-GRC-R-536	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
602400	2-GRC-R-535	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10S		2	-	-	-	-	-	-	-	C	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
602500	2-GRC-S-538	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.10S		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-32 (FIG NO A-32)														
602600	2-GRC-R-558	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WB		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
602700	2-GRC-R-557	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
602800	2-GRC-S-562	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE RESTRAINT COMPONENT	F1.10S		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-32 (FIG NO A-33)														
602900	2-GRC-R-556	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD OUTAGE 1	SECOND PERIOD OUTAGE 2	SECOND PERIOD OUTAGE 3	SECOND PERIOD OUTAGE 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-32 (FIG NO A-33)													
603000	2-GRC-R-554	F-A	VT-3	1	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10BS		2	-	-	-	-	-	-	-	X	-	
	CONT. L2			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	
603100	2-GRC-S-555	F-A	VT-3	1	-	-	C	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.10S		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-33 (FIG NO A-34)													
603400	2-GRC-R-577	F-A	VT-3	1	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WB		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
603500	2-GRC-R-576	F-A	VT-3	1	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
603600	2-GRC-S-575	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.10S		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-33 (FIG NO A-35)													
603700	2-GRC-R-574	F-A	VT-3	1	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2	-	-	-	-	-	-	-	-	-	
				3	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-RC-33 (FIG NO A-35)														
603800	2-GRC-R-572	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10BS		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
603900	2-GRC-S-573	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE RESTRAINT COMPONENT	F1.10S		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-34 (FIG NO A-36)														
604100	2-GRC-R-568	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WB		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
604200	2-GRC-R-567	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
604300	2-GRC-S-566	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE RESTRAINT COMPONENT	F1.10S		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-34 (FIG NO A-37)														
604400	2-GRC-R-565	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10A		2	-	-	-	-	C	-	-	-	X	-	
	CONT. L4			3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-RC-34 (FIG NO A-37)														
604500	2-GRC-R-563	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10BS		2	-	-	-	-	C	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
604600	2-GRC-S-564	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE RESTRAINT COMPONENT	F1.10S		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-512 (FIG NO A-38)														
604700	2-GRC-R-545	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2	-	-	-	-	C	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
604800	2-GRC-R-544	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WB		2	-	-	-	-	C	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-513 (FIG NO A-39)														
604850	2-GRC-R-542	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2	-	-	-	-	C	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-514 (FIG NO A-40)														
604900	2-GRC-R-561	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2	-	-	-	-	C	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RC-514 (FIG NO A-40)													
605000	2-GRC-R-560	F-A	VT-3	1 -	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10WB		2 -	-	-	-	C	-	-	-	-	-	
	CONT. L2			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-515 (FIG NO A-41)													
605100	2-GRC-R-559	F-A	VT-3	1 -	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-516 (FIG NO A-42)													
605200	2-ARC-R-662	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10A		2 -	-	-	-	C	-	-	-	-	-	
	CONT. L3			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
605300	2-GRC-R-581	F-A	VT-3	1 -	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2 -	-	-	-	C	-	-	-	-	-	
	CONT. L3			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
605400	2-GRC-R-580	F-A	VT-3	1 -	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10WB		2 -	-	-	-	C	-	-	-	-	-	
	CONT. L3			3 -	-	-	X	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-RC-517 (FIG NO A-43)													
605490	2-ARC-L-661	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.10A		2 -	-	-	-	C	-	-	-	-	-	
	CONT. L3			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
						PLAN STATUS		
						OUTAGE		
					1 2 3	1 2 3 4	1 2 3	
	LINE 2-RC-517 (FIG NO A-43)							
605500	2-GRC-R-579	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.10WA		2	- - -	- C - -	- - -	
	CONT. L3			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	LINE 2-RC-518 (FIG NO A-44)							
605520	2-GRC-R-570	F-A	VT-3	1	- - -	- - - -	C - -	
	PIPE SUPPORT COMPONENT	F1.10WB		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
605540	2-GRC-R-571	F-A	VT-3	1	- - -	C - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.10WA		2	- - -	- - - -	C - -	
	CONT. L4			3	- - -	- - - -	X - -	
				4	- - -	- - - -	- - -	
	LINE 2-RC-519 (FIG NO A-45)							
605600	2-GRC-R-569	F-A	VT-3	1	- - -	- - - -	C - -	
	PIPE SUPPORT COMPONENT	F1.10WA		2	- - -	- C - -	- - -	
	CONT. L4			3	X - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	LINE 2-RC-525 (FIG NO A-46)							
605700	2-ARC-R-551	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.10WB		2	- - -	- C - -	- - -	
	CONT. L4			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-56 (FIG NO A-47)													
605800	2-GSI-R-550	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-78 (FIG NO A-47)													
605900	2-GSI-V-604	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	
	PIPE SUPPORT COMPONENT	F1.10C		2	-	-	-	-	-	-	-	C	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-76 (FIG NO A-48)													
606100	2-GSI-V-670	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10C		2	-	-	-	-	-	-	-	C	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-58 (FIG NO A-49)													
606400	2-GSI-R-546	F-A	VT-3	1	-	-	-	C	-	-	-	C	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2	-	-	-	C	-	-	-	-	-	
				3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-77 (FIG NO A-49)													
606600	2-GSI-V-606	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10C		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-59 (FIG NO A-50)													
606700	2-GSI-R-549	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-60 (FIG NO A-51)														
607000	2-GSI-R-666	F-A	VT-3	1	-	-	C	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10B		2	-	-	C	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-62 (FIG NO A-54)														
607100	2-GSI-R-658	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10A		2	-	-	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
607200	2-GSI-R-659	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-66 (FIG NO A-57)														
607210	F-A F1.10A	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
607220	2-GSI-R-567	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10B		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
607230	2-GSI-R-504	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10B		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	PRESERVICE YEAR INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE									
	LINE 2-SI-67 (FIG NO A-58)													
607240	2-GSI-R-569	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10A		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
607250	2-GSI-R-563	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10B		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
607260	2-AEP-SPR-211	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-67 (FIG NO A-59)													
607270	2-GSI-R-505	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10B		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
607275	2-GSI-R-506	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10B		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	
607280	2-GSI-R-507	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10B		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-73 (FIG NO A-60)													
607290	2-GSI-L-840	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1 2 3	SECOND PERIOD OUTAGE 1 2 3 4	THIRD PERIOD 1 2 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-73 (FIG NO A-60)							
607295	2-GSI-L-841	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.10A		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	LINE 2-SI-566 (FIG NO A-62)							
607300	2-GSI-R-717	F-A	VT-3	1	- - -	C - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.10A		2	- - -	C - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
607400	2-GSI-R-694	F-A	VT-3	1	- - -	- - - -	C - -	
	PIPE SUPPORT COMPONENT	F1.10B		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
607500	2-GSI-V-695	F-A	VT-3	1	- - -	- - - -	C - -	
	PIPE SUPPORT COMPONENT	F1.10C		2	- - -	- - - -	- - -	
				3	- - -	- - - -	X - -	
				4	- - -	- - - -	- - -	
	LINE 2-SI-567 (FIG NO A-63)							
607510	2-GSI-R-624	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.10B		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
607520	2-GSI-R-626	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.10B		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1 2 3	SECOND PERIOD 1 2 3 4 (OUTAGE)	THIRD PERIOD 1 2 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-567 (FIG NO A-63)							
607530	2-GSI-R-628	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.10WB		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
607540	2-GSI-R-633	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.10A		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
607550	2-GSI-R-592	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.10A		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
607560	2-GSI-R-594	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.10A		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
607570	2-GSI-R-634	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.10A		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
607580	2-GSI-R-596	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.10B		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
607590	2-GSI-R-503	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.10B		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-567 (FIG NO A-65)															
607600	2-GSI-R-559	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WB		2	-	-	-	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	X	
				4	-	-	-	-	-	-	-	-	-	-	-	
607800	2-GSI-R-698	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	C	
	PIPE SUPPORT COMPONENT	F1.10A		2	-	-	-	-	C	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	
607900	2-GSI-R-697	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10B		2	-	-	-	-	C	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	
607950	2-GSI-V-696	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10C		2	-	-	-	-	C	-	-	-	-	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-568 (FIG NO A-67)															
608000	2-GSI-R-576	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10A		2	-	-	-	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	
608100	2-GSI-R-577	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	C	
	PIPE SUPPORT COMPONENT	F1.10B		2	-	-	-	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	
608200	2-GSI-R-578	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10B		2	-	-	-	C	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-568 (FIG NO A-67)													
608300	2-GSI-R-701	F-A	VT-3	1	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10A		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
608400	2-GSI-R-700	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10B		2	-	-	-	-	-	-	C	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
608500	2-GSI-V-699	F-A	VT-3	1	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10C		2	-	-	-	-	-	-	C	-	-	
	CONT. L2			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-569 (FIG NO A-68)													
608510	2-GSI-R-631	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10A		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
608520	2-GSI-R-586	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10B		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
608530	2-GSI-R-587	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10B		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
608540	2-GSI-R-632	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10A		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-SI-569 (FIG NO A-68)														
608550	2-GSI-R-588	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10B		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
608560	2-GSI-R-589	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10B		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-569 (FIG NO A-69)														
608600	2-GSI-R-590	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10A		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
608700	2-GSI-S-707	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10S		2	-	-	-	-	-	-	-	-	X	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
608800	2-GSI-S-706	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
608900	2-GSI-R-705	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10B		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
609000	2-GSI-R-704	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-569 (FIG NO A-69)													
609100	2-GSI-R-703	F-A	VT-3	1	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10B		2	-	-	-	-	-	-	C	-	-	
	CONT. L3			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	
609200	2-GSI-V-702	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10C		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-CS-119 (FIG NO A-70)														
609205	2-GCS-R-511	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2	-	-	-	-	C	-	-	-	X	-	
	CONT. L4			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-CS-119 (FIG NO A-71)														
609210	2-GCS-R-529	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10WB		2	-	-	-	-	C	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
609215	2-GCS-R-505	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WB		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-CS-120 (FIG NO A-72)														
609220	2-GCS-R-543	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WB		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
609225	2-GCS-R-542	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
609230	2-GCS-R-541	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-CS-120 (FIG NO A-72)														
609235	2-GCS-R-540	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10A		2	-	-	-	-	-	-	-	-	X	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-CS-121 (FIG NO A-73)														
609237	2-GCS-R-506	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-CS-687 (FIG NO A-74)														
609245	2-GCS-R-515	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10WB		2	-	-	-	-	C	-	-	-	-	-	
	REGEN HXRM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
609250	2-GCS-R-601	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WB		2	-	-	-	-	C	-	-	-	-	-	
	REGEN HXRM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
609255	2-GCS-R-507	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2	-	-	-	-	C	-	-	-	-	-	
	CONT. L4			3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
609260	2-GCS-R-600	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10WB		2	-	-	-	-	C	-	-	-	-	-	
	CONT. PRT			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-RH-33 (FIG NO A-77)														
609400	2-GRH-V-509	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.10WC		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
609500	2-GRH-R-507	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.10WA		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT PUMPS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	PUMP SUPPORTS														
609600	RC PUMP NO. 21	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
		F1.40		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
609610	RC PUMP NO. 22	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
		F1.40		2	-	-	-	-	-	-	-	C	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
609620	RC PUMP NO. 23	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
		F1.40		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
609630	RC PUMP NO. 24	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
		F1.40		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

STEAM GENERATORS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	UPPER LATERAL SUPPORTS														
700001	SG-21-SNUBBERS 1 THRU 4	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	EXAMINED BY MAINTENANCE
		F1.40		2	-	-	-	-	-	-	-	-	-	-	PROCEDURES PER TECHNICAL
	CONT. L1			3	-	-	-	-	-	-	-	X	-	-	SPECIFICATION 3/4.7.7.
				4	-	-	-	-	-	-	-	-	-	-	
700002	SG-22-SNUBBERS 1 THRU 4	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	EXAMINED BY MAINTENANCE
		F1.40		2	-	-	-	-	-	-	-	-	-	-	PROCEDURES PER TECHNICAL
	CONT. L2			3	-	-	-	-	-	-	-	X	-	-	SPECIFICATION 3/4.7.7.
				4	-	-	-	-	-	-	-	-	-	-	
700003	SG-23-SNUBBERS 1 THRU 4	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	EXAMINED BY MAINTENANCE
		F1.40		2	-	-	-	-	-	-	-	-	-	-	PROCEDURES PER TECHNICAL
	CONT. L3			3	X	-	-	-	-	-	-	-	-	-	SPECIFICATION 3/4.7.7.
				4	-	-	-	-	-	-	-	-	-	-	
700004	SG-24-SNUBBERS 1 THRU 4	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	EXAMINED BY MAINTENANCE
		F1.40		2	-	-	-	-	-	-	-	-	-	-	PROCEDURES PER TECHNICAL
	CONT. L4			3	-	-	-	-	-	-	-	X	-	-	SPECIFICATION 3/4.7.7.
				4	-	-	-	-	-	-	-	-	-	-	

REGENERATIVE HEAT EXCHANGER (FIGURE B-5)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	SUPPORT COMPONENT														
700010	CS-1	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	BRACKET	F1.40		2	-	-	-	-	C	-	-	-	-	-	
	REGEN HXRM			3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
700020	CS-2	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	BRACKET	F1.40		2	-	-	-	-	C	-	-	-	-	-	
	REGEN HXRM			3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
700030	CS-3	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	BRACKET	F1.40		2	-	-	-	-	C	-	-	-	-	-	
	REGEN HXRM			3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
700040	CS-4	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	BRACKET	F1.40		2	-	-	-	-	C	-	-	-	-	-	
	REGEN HXRM			3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
700050	CS-5	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	BRACKET	F1.40		2	-	-	-	-	-	-	-	C	-	-	
	REGEN HXRM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
700060	CS-6	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	BRACKET	F1.40		2	-	-	-	-	-	-	-	C	-	-	
	REGEN HXRM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL TANK (FIGURE B-6)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	SUPPORT COMPONENT													
700070	2-CVCT-SC-1	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
		F1.40		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
700080	2-CVCT-SC-2	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
		F1.40		2	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
700090	2-CVCT-SC-3	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
		F1.40		2	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
700100	2-CVCT-SC-4	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
		F1.40		2	-	-	-	-	C	-	-	-	-	
	VCT RM			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

RHR HEAT EXCHANGER EAST (FIGURE B-9)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - -			O U T A G E				- - - - - -			
	SUPPORT COMPONENT													
700150	E-RHRHEX-SC-1	F-A F1.40	VT-3	1 -	-	-	-	-	-	-	-	-	-	
				2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
700160	E-RHRHEX-SC-2	F-A F1.40	VT-3	1 -	-	-	-	-	-	-	-	-	-	
				2 -	-	-	-	C	-	-	-	-	-	
	E RHR HXRM			3 -	-	-	-	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

RHR HEAT EXCHANGER WEST (FIGURE B-10)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SUPPORT COMPONENT														
700170	W-RHRHEX-SC-1	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
		F1.40		2	-	-	-	-	-	-	-	C	-	-	
	W RHR HXRM			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
700180	W-RHRHEX-SC-2	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
		F1.40		2	-	-	-	-	-	-	-	-	X	-	
	W RHR HXRM			3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	

BORON INJECTION TANK (FIGURE B-11)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY	ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	SUPPORT COMPONENT														
700190	2-BIT-CS-1	F-A		VT-3	1	-	-	-	-	-	-	-	-	-	
		F1.40			2	C	-	-	-	-	-	-	-	-	
					3	X	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	
700200	2-BIT-CS-2	F-A		VT-3	1	-	-	-	-	-	-	-	-	-	
		F1.40			2	-	-	-	C	-	-	-	-	-	
	BIT RH				3	X	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	
700210	2-BIT-CS-3	F-A		VT-3	1	-	-	-	-	-	-	-	-	-	
		F1.40			2	-	-	-	-	-	-	-	C	-	
	BIT RH				3	X	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	
700220	2-BIT-CS-4	F-A		VT-3	1	-	-	-	-	-	-	-	-	-	
		F1.40			2	-	-	-	-	-	-	-	-	X	
	BIT RH				3	X	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-7 (FIG NO B-12)															
710000	2-GSI-V-111	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.20WC		2	C	-	-	-	-	-	-	-	-	-		
				3	X	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-		
710020	2-GSI-L-110	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	C	-	-		
	VESTIBULE			3	-	-	-	-	-	-	-	X	-	-		
				4	-	-	-	-	-	-	-	-	-	-		
710030	2-GSI-R-46	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
	F-A F1.20WACOMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-		
710040	2-GSI-S-47	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
	PIPE RESTRAINT COMPONENT	F1.20S		2	C	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-		
710100	2-GRH-L-34	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-		
	PIPE SUPPORT COMPONENT	F1.20WB		2	-	-	-	-	C	-	-	-	-	-		
	W RHR PPRM			3	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-		
710120	2-GRH-L-35	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
	PIPE RESTRAINT COMPONENT	F1.20WA		2	-	-	-	-	C	-	-	-	-	-		
	W RHR PPRM			3	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-		
710155	2-GCTS-L-68	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	C	-	-	-	-	-		
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-		

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE. METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-7 (FIG NO B-12)													
710160	2-GCTS-S-115	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WS		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
710165	2-GCTS-S-116	F-A	VT-3	1	-	-	-	-	-	-	C	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WS		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
710185	2-GCTS-R-66	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	-	-	
	W CTS PPRM			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
710200	2-GCTS-R-65	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-8 (FIG NO B-13)													
710400	2-GSI-V-112	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WC		2	-	-	-	-	-	-	-	-	-	
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
710410	2-GSI-R-50	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
710420	2-GSI-S-51	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20S		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	2	3	PLAN STATUS FIRST PERIOD 1	SECOND PERIOD 2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-8 (FIG NO B-13)													
710455	2-GRH-L-36	F-A	VT-3	1	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
710480	2-GRH-L-37	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WA		2	-	-	-	-	-	-	C	-	-	
	E RHR PPRM			3	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	
710510	2-GCTS-L-69	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
710515	2-GCTS-S-114	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WS		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
710520	2-GCTS-S-113	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WS		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
710530	2-GCTS-R-70	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	C	-	-	-	-	
	E CTS PPRM			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
710540	2-GCTS-R-72	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	C	-	-	-	-	
	E CTS PPRM			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-SI-9 (FIG NO B-14)														
710700	2-GSI-V-39	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
710725	2-GSI-L-40	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	C	-	-	
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
710800	2-GSI-V-41	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2	-	-	-	-	-	-	-	C	-	-	
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
710900	2-GSI-R-43	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	C	-	-	
	VESTIBULE			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
711000	2-GSI-R-42	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	C	-	-	
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-56 (FIG NO B-15)														
711100	2-GSI-R-551	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-57 (FIG NO B-16)														
711200	2-GSI-R-544	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
							OUTAGE							
	LINE 2-SI-58 (FIG NO B-17)													
711300	2-GSI-R-547	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-59 (FIG NO B-18)													
711400	2-GSI-R-548	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-60 (FIG NO B-19)													
711500	2-GSI-V-534	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
711510	2-GSI-R-535	F-A	VT-3	1 -	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	X	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
711520	2-GSI-S-575	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20S		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
711530	2-GSI-R-536	F-A	VT-3	1 -	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-60 (FIG NO B-19)													
711540	2-GSI-R-537	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	F-A F1.20ACOMPONENT	F1.20A		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	X	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
711550	2-GSI-R-538	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
711560	2-GSI-R-539	F-A	VT-3	1 -	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2 -	-	-	C	-	-	-	-	X	-	
	ANNULUS			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
711570	2-GSI-V-673	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
711580	2-GSI-R-672	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20B		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
711590	2-GSI-R-665	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-62 (FIG NO B-21)													
711600	2-GSI-R-543	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-62 (FIG NO B-21)														
711610	2-GSI-R-555	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	C	-	-	-	C	-	-	
	ANNULUS			3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
711620	2-GSI-R-554	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
711630	2-GSI-R-540	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
711640	2-GSI-R-664	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
711650	2-GSI-R-661	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
711660	2-GSI-R-660	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-76 (FIG NO B-23)														
711670	2-GSI-R-663	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-SI-77 (FIG NO B-24)														
711680	2-GSI-R-662	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-78 (FIG NO B-25)														
711690	2-GSI-R-671	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-79 (FIG NO B-26)														
711700	2-GSI-R-667	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
711710	2-GSI-R-668	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
711720	2-GSI-R-669	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
711730	2-GSI-V-608	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
					1 2 3	1 2 3 4	1 2 3	
	LINE 2-RH-14 (FIG NO B-28)							
713000	2-GRH-R-27	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WA		2	C - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
713010	2-GRH-R-26	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WA		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
713040	2-GRH-S-25	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE RESTRAINT COMPONENT	F1.20D		2	C - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
713055	2-GRH-V-23	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WC		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
713060	2-GRH-V-22	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WC		2	- - -	- - - -	- - -	
	W RHR PPRM			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
713070	2-GRH-S-24	F-A	VT-3	1	- - -	- - - -	C - -	
	PIPE RESTRAINT COMPONENT	F1.20		2	C - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
713073	2-ARH-L-21	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE RESTRAINT COMPONENT	F1.20		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	PRESERVICE YEAR INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-14 (FIG NO B-28)													
713077	2-ARH-L-20	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
713090	2-GRH-R-19	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	C	-	-	
	W CHG PPRM			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
713093	2-ARH-R-5006	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	
	W CHG PPRM			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
713097	2-ARH-R-5011	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	F-A F1.20ACOMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	
	W CHG PPRM			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
713100	2-GRH-R-17	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-RH-15 (FIG NO B-29)													
713200	2-GRH-L-1	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	C	-	-	
	E RHR PPRM			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
713210	2-ARJ-R-5003	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	-	-	
	E RHR PPRM			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-15 (FIG NO B-29)													
713240	2-GRH-L-2	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
713250	2-GRH-S-7	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20S		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
713260	2-GRH-S-6	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20S		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
713270	2-GRH-V-8	F-A	VT-3	1	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
713285	2-GRH-V-9	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WC		2	-	-	-	-	C	-	-	-	-	
	E RHR PPRM			3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
713290	2-GRH-L-11	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	-	-	
	E RHR PPRM			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
713295	2-GRH-L-10	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	-	-	
	E RHR PPRM			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (FIRST PERIOD 1 2 3 / SECOND PERIOD 1 2 3 4 / THIRD PERIOD 1 2 3 — OUTAGE)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-15 (FIG NO B-29)				
713300	2-GRH-R-11	F-A	VT-3	1 - - - - - - - - - - - -	
	PIPE SUPPORT COMPONENT	F1.20WA		2 - - - - - - - - - C - -	
	E CHG PPRM			3 - - - - - - - - - X - -	
				4 - - - - - - - - - - - -	
713310	2-GRH-V-13	F-A	VT-3	1 - - - - - - - - - - - -	
	PIPE SUPPORT COMPONENT	F1.20WC		2 - - - - C - - - - - -	
	E RHR HXRM			3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	
713312	2-GRH-R-5005	F-A	VT-3	1 - - - - - - - - - - - -	
	PIPE SUPPORT COMPONENT	F1.20A		2 - - - - - - - - - - - -	
	E RHR PPRM			3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	
713314	2-GRH-R-5008	F-A	VT-3	1 - - - - - - - - - - - -	
	PIPE SUPPORT COMPONENT	F1.20A		2 - - - - - - - - - - - -	
	E RHR PPRM			3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	
713316	2-GRH-R-5010	F-A	VT-3	1 - - - - - - - - - - - -	
	PIPE SUPPORT COMPONENT	F1.20A		2 - - - - - - - - - - - -	
	E RHR PPRM			3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	
713320	2-GRH-R-14	F-A	VT-3	1 - - - - - - - - - - - -	
	PIPE SUPPORT COMPONENT	F1.20WA		2 - - - - C - - - - - -	
	E RHR HXRM			3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	
	LINE 2-RH-16 (FIG NO B-30)				
713350	2-GRH-R-3	F-A	VT-3	1 - - - - - - - - - - - -	
	PIPE SUPPORT COMPONENT	F1.20WA		2 C - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-RH-16 (FIG NO B-30)														
713360	2-GRH-V-15	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	X	-	
	E RHR HXRM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
713370	2-GRH-R-5	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	C	-	-	
	E RHR HXRM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
713380	2-GRH-R-4	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	C	-	-	
	W RHR HXRM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RH-17 (FIG NO B-31)														
713400	2-GRH-L-805	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	C	-	-	
	E RHR HXRM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
713405	2-ARH-R-5007	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	-	
	E RHR HXRM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
713410	2-GRH-R-804	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	C	-	-	
	E RHR HXRM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
713420	2-GRH-L-802	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RH-17 (FIG NO B-31)													
713430	2-GRH-V-801	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2 -	-	-	-	C	-	-	-	-	-	
	VESTIBULE			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
713440	2-GRH-L-800	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2 -	-	-	-	-	-	-	-	-	-	
	VESTIBULE			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-RH-18 (FIG NO B-32)													
713800	2-GRH-R-28	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
713860	2-GCTS-V-42	F-A	VT-3	1 -	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2 -	-	-	-	C	-	-	-	-	-	
	W RHR HXRM			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
713870	2-GCTS-L-43	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2 -	-	-	-	C	-	-	-	-	-	
	W RHR HXRM			3 -	-	-	-	X	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
713880	2-GCTS-L-44	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2 -	-	-	-	C	-	-	-	-	-	
	W RHR HXRM			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
713900	2-GCTS-R-45	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2 -	-	-	-	C	-	-	-	-	-	
	VESTIBULE			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-18 (FIG NO B-32)														
713940	2-GCTS-R-46	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	C	- -
	PIPE SUPPORT COMPONENT	F1.20B		2 -	-	-	-	C	-	-	-	-	-	-	- -
	VESTIBULE			3 -	-	-	-	X	-	-	-	-	-	-	- -
				4 -	-	-	-	-	-	-	-	-	-	-	- -
713965	2-GCTS-L-47	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	C	- -
	PIPE SUPPORT COMPONENT	F1.20B		2 -	-	-	-	C	-	-	-	-	-	-	- -
	VESTIBULE			3 -	-	-	-	-	-	-	-	-	-	-	- -
				4 -	-	-	-	-	-	-	-	-	-	-	- -
713970	2-GCTS-R-48	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	C	- -
	PIPE SUPPORT COMPONENT	F1.20B		2 -	-	-	-	C	-	-	-	-	-	-	- -
	VESTIBULE			3 -	-	-	-	-	-	-	-	-	-	-	- -
				4 -	-	-	-	-	-	-	-	-	-	-	- -
713985	2-GCTS-L-49	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	-	- -
	PIPE SUPPORT COMPONENT	F1.20B		2 -	-	-	-	C	-	-	-	-	-	-	- -
	VESTIBULE			3 -	-	-	-	-	-	-	-	-	-	-	- -
				4 -	-	-	-	-	-	-	-	-	-	-	- -
714000	2-GCTS-R-50	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	-	- -
	PIPE SUPPORT COMPONENT	F1.20A		2 -	-	-	-	C	-	-	-	-	-	-	- -
	VESTIBULE			3 -	-	-	-	-	-	-	-	-	-	-	- -
				4 -	-	-	-	-	-	-	-	-	-	-	- -
	LINE 2-RH-19 (FIG NO B-33)														
714100	2-GRH-L-50	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	-	- -
	PIPE SUPPORT COMPONENT	F1.20WA		2 C	-	-	-	-	-	-	-	-	-	-	- -
				3 -	-	-	-	-	-	-	-	-	-	-	- -
				4 -	-	-	-	-	-	-	-	-	-	-	- -
714110	2-GCTS-L-53	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	-	- -
	PIPE SUPPORT COMPONENT	F1.20A		2 -	-	-	-	-	-	-	-	-	-	-	- -
				3 -	-	-	-	-	-	-	-	-	-	-	- -
				4 -	-	-	-	-	-	-	-	-	-	-	- -

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-RH-19 (FIG NO B-33)														
714120	2-GCTS-V-54	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2	-	-	-	-	C	-	-	-	-	-	
	E RHR HXRM			3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
714140	2-GCTS-L-55	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2	-	-	-	-	C	-	-	-	-	-	
	E RHR HXRM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
714180	2-GCTS-R-57	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	C	-	-	-	-	-	
	E RHR HXRM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
714205	2-GCTS-R-58	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2	-	-	-	-	C	-	-	-	-	-	
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
714260	2-GCTS-L-59	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2	-	-	-	-	C	-	-	-	-	-	
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
714280	2-GCTS-R-60	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2	-	-	-	-	C	-	-	-	-	-	
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RH-20 (FIG NO B-34)														
714435	2-GRH-R-33	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RH-20 (FIG NO B-34)													
714450	2-GRH-L-18	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20A		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
714542	2-GSI-L-70	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2 -	-	-	-	-	-	-	-	-	-	
	VESTIBULE			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
714544	2-GSI-L-72	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2 -	-	-	-	-	-	-	-	-	-	
	VESTIBULE			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
714546	2-ASI-L-71A	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2 -	-	-	-	-	-	-	-	-	-	
	VESTIBULE			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
714548	2-GSI-R-71	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2 -	-	-	-	-	-	-	-	-	-	
	VESTIBULE			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
714550	2-GSI-R-73	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2 -	-	-	-	-	-	-	-	-	-	
	VESTIBULE			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
714565	2-GSI-L-76	F-A	VT-3	1 -	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2 -	-	-	-	-	-	-	C	-	-	
	VESTIBULE			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE			
					1 2 3	1 2 3 4	1 2 3	
	LINE 2-RH-21 (FIG NO B-35)							
714640	2-GSI-R-69	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20A		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
714650	2-GSI-R-68	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20A		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
714725	2-GSI-L-65	F-A	VT-3	1	- - -	- - - -	C - -	
	PIPE SUPPORT COMPONENT	F1.20WA		2	C - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
714740	2-GSI-L-64A	F-A	VT-3	1	- - -	- - - -	C - -	
	PIPE RESTRAINT COMPONENT	F1.20WA		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
714755	2-GSI-R-64	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WA		2	- - -	- - - -	C - -	
	VESTIBULE			3	- - -	- - - -	X - -	
				4	- - -	- - - -	- - -	
714770	2-GSI-L-63	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20A		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	LINE 2-RH-22 (FIG NO B-36)							
714860	2-GRH-R-32	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WA		2	- - -	- - - -	C - -	
	W RHR HXRM			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-22 (FIG NO B-36)														
714890	2-GRH-R-31	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	C	-	-	
	W RHR HXRM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
714895	2-GSI-R-90	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	C	-	-	
	VESTIBULE			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
714897	2-GSI-L-89	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	-	
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RH-23 (FIG NO B-37)														
715010	2-GRH-L-6A	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
715075	2-GSI-L-54	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2	-	-	-	-	-	-	-	-	-	-	
	E RHR HXRM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
715095	2-GSI-V-53	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2	-	-	-	-	-	-	-	-	-	-	
	W CHG PPRM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-RH-24 (FIG NO B-38)														
715200	2-GRH-V-806	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2	-	-	-	-	-	-	-	-	-	-	
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1 2 3	SECOND PERIOD 1 2 3 4	THIRD PERIOD 1 2 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-RH-24 (FIG NO B-38)							
715210	2-GRH-L-807	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20B		2	- - -	- - - -	- - -	
	VESTIBULE			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	LINE 2-RH-31 (FIG NO B-39)							
715300	2-GRH-R-508	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WB		2	C - -	- - - -	- - -	
				3	X - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
715310	2-GRH-R-505	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WA		2	- - -	C - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
715320	2-GRH-R-503	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WB		2	- - -	C - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
715330	2-GRH-R-500	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WA		2	- - -	C - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
715340	2-GRH-R-501	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WB		2	- - -	C - - -	C - -	
	ANNULUS			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
715350	2-GRH-R-502	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WA		2	- - -	C - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-RH-31 (FIG NO B-39)													
715360	2-GRH-R-504	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-RH-33 (FIG NO B-42)													
715400	2-GRH-R-506	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-79 (FIG NO B-43)													
715430	2-GCS-R-94	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	C	-	-	-	-	
	W CHG PPRM			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
715440	2-GCS-R-32	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20D		2	-	-	-	-	C	-	-	-	-	
	E CHG PPRM			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
715445	2-GCS-L-31	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2	-	-	-	-	-	-	-	-	-	
	E CHG PPRM			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-CS-80 (FIG NO B-44)													
715450	2-GCS-V-95	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2	-	-	-	-	C	-	-	-	-	
	E CHG PPRM			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CTS-10 (FIG NO B-46)														
715580	2-ACTS-R-5005	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	-	
	W CTS PPRH			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
715585	2-GCTS-R-1	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2	-	-	-	-	C	-	-	-	-	-	
	W CTS PPRH			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
715590	2-GCTS-R-2	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
715600	2-GCTS-R-3	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
715635	2-GCTS-V-4	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	C	-	-	
	W CTS HXRH			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
715650	2-GCTS-V-5	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20WC		2	-	-	-	-	-	-	-	C	-	-	
	W CTS HXRH			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-CTS-11 (FIG NO B-47)														
715810	2-GCTS-R-13	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CTS-11 (FIG NO B-47)													
715830	2-GCTS-R-14	F-A	VT-3	1	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
715880	2-GCTS-R-15	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
715890	2-GCTS-R-33	F-A	VT-3	1	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	X	-	
	VESTIBULE			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	
715893	2-GCTS-R-33A	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2	-	-	-	-	-	-	-	-	-	
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
715895	2-GCTS-R-34	F-A	VT-3	1	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
715910	2-GCTS-R-34A	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	X	-	
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-CTS-12 (FIG NO B-48)													
716045	2-GCTS-R-16	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2	-	-	-	-	C	-	-	-	-	
	W CTS HXRM			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL ASME SEC. XI CATGY	NDE ITEM NO METH	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CTS-12 (FIG NO B-48)													
716065	2-GCTS-R-17	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	C	-	-	-	X	
	W CTS HXRM			3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
716070	2-GCTS-R-31	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	C	-	-	-	-	
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
716075	2-GCTS-R-31A	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2	-	-	-	-	-	-	-	-	-	
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
716080	2-GCTS-R-32	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	C	-	-	-	-	
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
716095	2-GCTS-R-32A	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	C	-	-	-	-	
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-CTS-13 (FIG NO B-49)													
716215	2-GCTS-V-6	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2	-	-	-	-	C	-	-	-	-	
	E CTS PPRM			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
716220	2-ACTS-R-5000	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	
	E CTS PPRM			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
							OUTAGE							
	LINE 2-CTS-13 (FIG NO B-49)													
716230	2-GCTS-R-7	F-A	VT-3	1 -	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2 -	-	-	-	C	-	-	-	-	-	
	E CTS PPRM			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
716235	2-ACTS-R-5001	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2 -	-	-	-	-	-	-	-	-	-	
	E CTS PPRM			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
716240	2-GCTS-R-8	F-A	VT-3	1 -	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2 -	-	-	-	C	-	-	-	-	-	
	E CTS PPRM			3 -	-	-	-	X	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
716270	2-ACTS-L-8A	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2 -	-	-	-	C	-	-	-	-	-	
	E CTS PPRM			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
716275	2-ACTS-R-7A	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20B		2 -	-	-	-	C	-	-	-	-	-	
	E CTS PPRM			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
716310	2-GCTS-R-10	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2 -	-	-	-	C	-	-	-	-	-	
	E CTS PPRM			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
716313	2-GCTS-L-10A	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2 -	-	-	-	-	-	-	-	-	-	
	E CTS PPRM			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CTS-13 (FIG NO B-49)														
716315	2-ACTS-R-10B	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20A		2	-	-	-	-	C	-	-	-	-	-	
	E CTS HXRM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
716355	2-GCTS-V-11	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WC		2	-	-	-	-	C	-	-	-	-	-	
	E CTS HXRM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
716385	2-GCTS-V-12	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WC		2	-	-	-	-	C	-	-	-	-	-	
	E CTS HXRM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-CTS-14 (FIG NO B-50)														
716550	2-GCTS-R-18	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	C	-	-	
	E CTS HXRM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
716630	2-GCTS-R-19	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	C	-	-	
	E CTS HXRM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
716660	2-GCTS-L-20	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
716670	2-GCTS-L-26	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2	-	-	-	-	-	-	-	C	-	-	
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

CONTAINMENT SPRAY SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-CTS-14 (FIG NO B-50)														
716680	2-GCTS-R-27	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
716695	2-GCTS-R-28	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	C	-	-	
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-CTS-15 (FIG NO B-51)														
716810	2-GCTS-R-21	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
716850	2-GCTS-L-22	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2	-	-	-	-	-	-	-	-	X	-	
	E CTS HXRM			3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
716890	2-GCTS-R-23	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
716930	2-GCTS-V-24	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2	-	-	-	-	-	-	-	-	X	-	
	VESTIBULE			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
716940	2-GCTS-R-25	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-FW-70 (FIG NO B-52)														
750100	2-GFW-L-867	F-A	VT-3	1	-	C	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WA		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
750200	2-GFW-S-868	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20S		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
750300	2-GFW-S-869	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE RESTRAINT COMPONENT	F1.20S		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
750400	2-GFW-V-870	F-A	VT-3	1	-	C	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20C		2	-	-	-	-	C	-	-	-	-	-	
	E MS ENC			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
750500	2-GFW-L-871	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20A		2	-	-	-	-	C	-	-	-	-	-	
	E MS ENC			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
750600	2-FW-70-HANGER	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	ADDITIONAL HANGER, NO I.D.
	PIPE RESTRAINT COMPONENT	F1.20WB		2	-	-	-	-	C	-	-	-	-	-	NUMBER. SEE AEP DWG. NO.
	E MS ENC			3	-	-	-	-	-	-	-	-	-	-	1-2-3952A.
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-FW-71 (FIG NO B-53)														
750700	2-GFW-L-872	F-A	VT-3	1	-	C	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WA		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-71 (FIG NO B-53)														
750800	2-GFW-S-873	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20S		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
750900	2-GFW-V-874	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE RESTRAINT COMPONENT	F1.20C		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
751000	2-GFW-V-875	F-A	VT-3	1	-	C	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20C		2	-	-	-	-	-	-	-	C	-	-	
	E MS ENC			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
751100	2-GFW-R-876	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
751200	2-FW-71-HANGER	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	ADDITIONAL HANGER, NO I.D.
	PIPE RESTRAINT COMPONENT	F1.20WB		2	-	-	-	-	-	-	-	C	-	-	NUMBER. SEE AEP DWG. NO.
	E MS ENC			3	-	-	-	-	-	-	-	X	-	-	1-2-3952A.
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-FW-72 (FIG NO B-54)														
751300	2-GFW-L-878	F-A	VT-3	1	-	C	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WA		2	-	-	-	-	C	-	-	-	-	-	
	MS ACC			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
751400	2-GFW-V879	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20C		2	-	-	-	-	C	-	-	-	-	-	
	MS ACC			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
					PLAN STATUS (OUTAGE)			
	LINE 2-FW-72 (FIG NO B-54)							
751500	2-GFW-L-880	F-A	VT-3	1	- - -	- - - -	C - -	
	PIPE RESTRAINT COMPONENT	F1.20A		2	- - -	- C - -	- - -	
	MS ACC			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
751600	2-GFW-V-881	F-A	VT-3	1	- C -	- - - -	- - -	
	PIPE RESTRAINT COMPONENT	F1.20C		2	- - -	- C - -	- - -	
	MS ACC			3	- - -	- X - -	- - -	
				4	- - -	- - - -	- - -	
751700	2-GFW-L-882	F-A	VT-3	1	- - -	C - - -	- - -	
	PIPE RESTRAINT COMPONENT	F1.20WB		2	- - -	- C - -	- - -	
	MS ACC			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
751800	2-GFW-V-883	F-A	VT-3	1	- - -	- - - -	C - -	
	PIPE RESTRAINT COMPONENT	F1.20WA		2	C - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
752000	2-GFW-S-885	F-A	VT-3	1	- - -	C - - -	- - -	
	PIPE RESTRAINT COMPONENT	F1.20S		2	C - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
752100	2-FW-72-HANGER	F-A	VT-3	1	- - -	- - - -	- - -	ADDITIONAL HANGER, NO I.D.
	PIPE SUPPORT COMPONENT	F1.20WB		2	C - -	- - - -	- - -	NUMBER. SEE AEP DWG. NO.
				3	- - -	- - - -	- - -	1-2-3952A.
				4	- - -	- - - -	- - -	
	LINE 2-FW-73 (FIG NO B-55)							
752200	2-GFW-L-887	F-A	VT-3	1	- - -	C - - -	- - -	
	PIPE RESTRAINT COMPONENT	F1.20WB		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY / ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-73 (FIG NO B-55)													
752300	2-GFW-L-888	F-A	VT-3	1 -	-	-	-	-	-	-	C	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WA		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
752400	2-GFW-V-889	F-A	VT-3	1 -	C	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20C		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
752500	2-GFW-R-890	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WB		2 -	-	-	-	-	-	-	-	X	-	
	HS ACC			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
752600	2-GFW-S-891	F-A	VT-3	1 -	-	-	-	-	-	-	C	-	-	
	PIPE RESTRAINT COMPONENT	F1.20S		2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
752700	2-GFW-V-892	F-A	VT-3	1 -	C	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20C		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
752800	2-FW-73-HANGER	F-A	VT-3	1 -	-	-	-	C	-	-	-	-	-	ADDITIONAL HANGER, NO I.D.
	PIPE RESTRAINT COMPONENT	F1.20WA		2 -	-	-	-	-	-	-	C	-	-	NUMBER. SEE AEP DWG. NO.
	W HS ENC			3 -	-	-	-	-	-	-	-	-	-	1-2-3952A.
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-FW-74 (FIG NO B-56)													
753000	2-FW-S-6	F-A	VT-3	1 -	C	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20S		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-74 (FIG NO B-56)														
753100	2-FW-S-5	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20S		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
753200	2-FW-H-2	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2	-	-	-	-	C	-	-	-	-	-	
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
753300	2-FW-S-4	F-A	VT-3	1	-	C	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WS		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-FW-75 (FIG NO B-57)														
753700	2-FW-S-9	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20S		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
753800	2-FW-H-3	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2	-	-	-	-	C	-	-	-	-	-	
	CONT. L3			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
753900	2-FW-S-7	F-A	VT-3	1	-	C	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WS		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
754000	2-FW-S-8	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WS		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-FW-76 (FIG NO B-58)													
754500	2-FW-S-12	F-A	VT-3	1 -	C	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20S		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
754600	2-FW-H-4	F-A	VT-3	1 -	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2 -	-	-	-	C	-	-	-	-	-	
	CONT. L4			3 -	-	-	-	X	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
754800	2-FW-S-11	F-A	VT-3	1 -	C	-	-	-	-		-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WS		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
754900	2-FW-S-10	F-A	VT-3	1 -	-	-	C	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WS		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-FW-77 (FIG NO B-59)													
755300	2-FW-S-3	F-A	VT-3	1 -	-	-	-	-	-	-	C	-	-	
	PIPE RESTRAINT COMPONENT	F1.20S		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
755400	2-FW-H-1	F-A	VT-3	1 -	C	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
755500	2-FW-S-1	F-A	VT-3	1 -	-	-	C	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WS		2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
					PLAN STATUS			
					1 2 3	1 2 3 4	1 2 3	
	LINE 2-FW-77 (FIG NO B-59)							
755600	2-FW-S-2	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE RESTRAINT COMPONENT	F1.20WS		2	C - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	LINE 2-FW-78 (FIG NO B-60)							
756000	2-GFW-L-842	F-A	VT-3	1	- C -	- - - -	- - -	
	PIPE RESTRAINT COMPONENT	F1.20WB		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
756100	2-GFW-L-843	F-A	VT-3	1	- - -	C - - -	- - -	
	PIPE RESTRAINT COMPONENT	F1.20A		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
756200	2-GFW-R-844	F-A	VT-3	1	- - -	- - - -	C - -	
	PIPE RESTRAINT COMPONENT	F1.20A		2	C - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	LINE 2-FW-79 (FIG NO B-61)							
756300	2-GFW-R-841	F-A	VT-3	1	- C -	- - - -	- - -	
	PIPE RESTRAINT COMPONENT	F1.20A		2	- - -	- C - -	- - -	
	E MS ENC			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
756400	2-GFW-R-840	F-A	VT-3	1	- - -	C - - -	- - -	
	PIPE RESTRAINT COMPONENT	F1.20A		2	- - -	- C - -	- - -	
	E MS ENC			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	2	3	PLAN STATUS FIRST PERIOD 1	SECOND PERIOD 2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
							OUTAGE							
	LINE 2-FW-79 (FIG NO B-61)													
756500	2-GFW-L-839	F-A	VT-3	1 -	-	-	-	-	-	-	C	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WB		2 -	-	-	-	C	-	-	-	-	-	
	E MS ENC			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-FW-80 (FIG NO B-62)													
756600	2-GFW-V-838	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20C		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
756700	2-GFW-L-837	F-A	VT-3	1 -	C	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20A		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
756800	2-GFW-L-836	F-A	VT-3	1 -	C	-	C	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20B		2 -	-	-	-	-	-	-	-	-	-	
	596 PLAT			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
756900	2-GFW-L-835	F-A	VT-3	1 -	-	-	-	-	-	-	C	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WB		2 -	-	-	-	-	-	-	-	-	-	
	W MS ENC			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-FW-81 (FIG NO B-63)													
757000	2-GFW-V-834	F-A	VT-3	1 -	C	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20C		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-FW-81 (FIG NO B-63)													
757100	2-GFW-L-833	F-A	VT-3	1 -	-	-	-	-	-	-	C	-	-	
	PIPE RESTRAINT COMPONENT	F1.20B		2 -	-	-	-	-	-	-	-	X	-	
	596 PLAT			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
757200	2-GFW-V-832	F-A	VT-3	1 -	-	-	C	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20C		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
757250	2-GFW-L-831	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	SUPPORT COMPONENTS	F1.20A		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
757300	2-GFW-L-830	F-A	VT-3	1 -	-	-	C	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WB		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-MS-89 (FIG NO B-64)														
757400	2-MSH-1	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2	-	-	-	-	C	-	-	-	-	-	
	CONT. L1			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
757500	2-MSS-1	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WS		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
757600	2-MSS-2	F-A	VT-3	1	-	C	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WS		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-MS-90 (FIG NO B-65)														
758200	2-MS-90-06S-PR1	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WA		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
758300	2-MS-90-06S-PR2	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	MAIN STEAM ISOLATION VALVE-LINE 2-MS-90 (FIG NO B-65,B-78)														
758400	MSIV-MRV-210-S1	F-A	VT-3	1	-	-	-	-	C	-	-	C	-	-	
	VALVE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	MAIN STEAM ISOLATION VALVE-LINE 2-MS-90 (FIG NO B-65,B-78)																
758500	MSIV-MRV-210-S2	F-A	VT-3	1	-	-	-	-	C	-	-	C	-	-			
	VALVE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	-	-	-			
				3	-	-	-	-	-	-	-	-	-	-			
				4	-	-	-	-	-	-	-	-	-	-			
	LINE 2-MS-91 (FIG NO B-66)																
759200	2-MSH-2	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	-			
	PIPE SUPPORT COMPONENT	F1.20C		2	-	-	-	-	C	-	-	-	-	-			
	CONT. L2			3	-	-	-	-	-	-	-	-	-	-			
				4	-	-	-	-	-	-	-	-	-	-			
759300	2-MSS-3	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-			
	PIPE RESTRAINT COMPONENT	F1.20WS		2	C	-	-	-	-	-	-	-	-	-			
				3	-	-	-	-	-	-	-	-	-	-			
				4	-	-	-	-	-	-	-	-	-	-			
759400	2-MSS-4	F-A	VT-3	1	-	C	-	-	-	-	-	-	-	-			
	PIPE RESTRAINT COMPONENT	F1.20WS		2	C	-	-	-	-	-	-	-	-	-			
				3	-	-	-	-	-	-	-	-	-	-			
				4	-	-	-	-	-	-	-	-	-	-			
	LINE 2-MS-92 (FIG NO B-67)																
759500	2-MS-92-05F-PS	F-A	VT-3	1	-	-	-	-	C	-	-	-	-	-			
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	C	-	-	-	-	-			
	W MS ENC			3	-	-	-	-	-	-	-	-	-	-			
				4	-	-	-	-	-	-	-	-	-	-			
759600	2-MS-92-07S-PS	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	-			
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	C	-	-	-	-	-			
	W MS ENC			3	-	-	-	-	-	-	-	X	-	-			
				4	-	-	-	-	-	-	-	-	-	-			

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	MAIN STEAM ISOLATION VALVE-LINE 2-MS-92 (FIG NO B-67,B-78)													
759700	MSIV-MRV-220-S1	F-A	VT-3	1 -	-	-	-	-	-	-	C	-	-	
	VALVE SUPPORT COMPONENT	F1.40WA		2 -	-	-	-	C	-	-	-	-	-	
	W MS ENC			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
759800	MSIV-MRV-220-S2	F-A	VT-3	1 -	-	-	-	-	-	-	C	-	-	
	VALVE SUPPORT COMPONENT	F1.40WA		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-MS-93 (FIG NO B-68)													
760400	2-MSH-3	F-A	VT-3	1 -	-	-	C	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
760500	2-MSS-6	F-A	VT-3	1 -	-	-	-	-	-	-	C	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WS		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
760600	2-MSS-5	F-A	VT-3	1 -	C	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WS		2 C	-	-	-	-	-	-	-	X	-	
	CONT. L3			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-MS-94 (FIG NO B-69)													
760700	2-MS-94-07S-PS	F-A	VT-3	1 -	-	-	-	C	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2 -	-	-	-	C	-	-	-	-	-	
	W MS ENC			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	2	3	PLAN STATUS FIRST PERIOD 1	SECOND PERIOD 2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
							OUTAGE							
	LINE 2-MS-94 (FIG NO B-69)													
760800	2-MS-94-08S-PS	F-A	VT-3	1	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2	-	-	-	C	-	-	-	-	-	
	W MS ENC			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	MAIN STEAM ISOLATION VALVE-LINE 2-MS-94 (FIG NO B-69,B-78)													
760900	MSIV-MRV-230-S1	F-A	VT-3	1	-	-	-	-	-	-	C	-	-	
	VALVE SUPPORT COMPONENT	F1.40WA		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
761000	MSIV-MRV-230-S2	F-A	VT-3	1	-	-	-	-	-	-	C	-	-	
	VALVE SUPPORT COMPONENT	F1.40WA		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-MS-95 (FIG NO B-70)													
761500	2-MSH-4	F-A	VT-3	1	-	C	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2	-	-	-	-	-	-	C	-	-	
	CONT. L4			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
761600	2-MSS-8	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WS		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
761700	2-MSS-7	F-A	VT-3	1	-	-	-	-	-	-	C	-	-	
	PIPE RESTRAINT COMPONENT	F1.20WS		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY / ITEM NO	NDE METH	INSPECTION INTERVAL 1	2	3	PLAN STATUS FIRST PERIOD 1	SECOND PERIOD 2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-MS-96 (FIG NO B-71)													
761800	2-MS-96-05F-PS	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
761900	2-MS-96-06S-PS	F-A	VT-3	1	-	-	-	-	C	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	C	-	
	E MS ENC			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	
	MAIN STEAM ISOLATION VALVE-LINE 2-MS-96 (FIG NO B-71,B-78)													
762000	MSIV-MRV-240-S1	F-A	VT-3	1	-	-	-	-	C	-	-	C	-	
	VALVE SUPPORT COMPONENT	F1.40WA		2	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
762100	MSIV-MRV-240-S2	F-A	VT-3	1	-	-	-	-	C	-	-	C	-	
	VALVE SUPPORT COMPONENT	F1.40WA		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-MS-193 (FIG NO B-72)													
762200	2-GMS-V-1154	F-A	VT-3	1	-	-	-	C	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WC		2	-	-	-	-	C	-	-	-	-	
	E MS ENC			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-MS-194 (FIG NO B-73)													
762300	2-GMS-V-1155	F-A	VT-3	1	-	-	-	-	-	-	-	C	-	
	PIPE SUPPORT COMPONENT	F1.20WC		2	-	-	-	-	C	-	-	-	-	
	E MS ENC			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

MAIN STEAM SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-MS-195 (FIG NO B-74)													
762400	2-GMS-L-1158	F-A	VT-3	1 -	C	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2 -	-	-	-	C	-	-	-	-	-	
	W MS ENC			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
762600	2-GMS-V-1156	F-A	VT-3	1 -	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2 -	-	-	-	C	-	-	-	-	-	
	W MS ENC			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-MS-196 (FIG NO B-75)													
762700	2-GMS-V-1161	F-A	VT-3	1 -	C	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
762900	2-GMS-V-1159	F-A	VT-3	1 -	-	-	-	-	-	-	C	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD (OUTAGE 1 2 3)	SECOND PERIOD (OUTAGE 1 2 3 4)	THIRD PERIOD (OUTAGE 1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-42A (FIG NO B-82)						
763000	2-GSI-L-804	F-A	VT-3	1 - - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WA		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
763010	2-GSI-R-17	F-A	VT-3	1 - - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20A		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
763020	2-GSI-L-813	F-A	VT-3	1 - - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20B		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
	LINE 2-SI-42 (FIG NO B-83)						
763100	2-GSI-L-800	F-A	VT-3	1 - - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WA		2 - - -	- - - -	- - -	
				3 - X -	- - - -	- - -	
				4 - - -	- - - -	- - -	
763110	2-GSI-L-18	F-A	VT-3	1 - - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20A		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
763120	2-GSI-L-801	F-A	VT-3	1 - - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20B		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
763130	2-GSI-L-802	F-A	VT-3	1 - - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20A		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-SI-42 (FIG NO B-83)														
763140	2-GSI-L-803	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
763150	2-GSI-L-21	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
763160	2-GSI-L-22	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
763170	2-GSI-L-23	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	
763180	2-GSI-V-805	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
763190	2-GSI-L-806	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
763200	2-GSI-L-26	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-SI-42 (FIG NO B-83)														
763210	2-GSI-L-27	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
763220	2-GSI-R-28	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
763230	2-GSI-L-29	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
763240	2-GSI-L-30	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-42 (FIG NO B-84)														
763290	2-GSI-L-807	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
763300	2-GSI-L-808	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
763310	2-GSI-L-809	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1 2 3	SECOND PERIOD 1 2 3 4	THIRD PERIOD 1 2 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-42 (FIG NO B-84)							
763320	2-GSI-L-810	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WB		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	LINE 2-SI-52 (FIG NO B-85)							
763400	2-GSI-L-95	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20A		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
763410	2-GSI-R-96	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20A		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
763420	2-GSI-V-99	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WC		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
763430	2-GSI-L-98	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WA		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- X -	
				4	- - -	- - - -	- - -	
763440	2-GSI-V-97	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WC		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	LINE 2-SI-64 (FIG NO B-86)							
763500	2-GSI-R-588	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WB		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (FIRST PERIOD 1 2 3 / SECOND PERIOD 1 2 3 4 / THIRD PERIOD 1 2 3 — OUTAGE)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-72 (FIG NO B-87)				
763600	2-GSI-L-819	F-A	VT-3	1 - - - - - - - - - - - -	
	PIPE SUPPORT COMPONENT	F1.20A		2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	
763610	2-GSI-L-834	F-A	VT-3	1 - - - - - - - - - - - -	
	PIPE SUPPORT COMPONENT	F1.20A		2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	
763620	2-GSI-L-816	F-A	VT-3	1 - - - - - - - - - - - -	
	PIPE SUPPORT COMPONENT	F1.20WA		2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	
763630	2-GSI-L-817	F-A	VT-3	1 - - - - - - - - - - - -	
	PIPE SUPPORT COMPONENT	F1.20WB		2 - - - - - - - - - - - -	
				3 - - - - - - - - - X -	
				4 - - - - - - - - - - - -	
763640	2-GSI-L-818	F-A	VT-3	1 - - - - - - - - - - - -	
	PIPE SUPPORT COMPONENT	F1.20A		2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	
	LINE 2-SI-72 (FIG NO B-88)				
763690	2-GSI-L-820	F-A	VT-3	1 - - - - - - - - - - - -	
	PIPE SUPPORT COMPONENT	F1.20B		2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	
763700	2-GSI-L-821	F-A	VT-3	1 - - - - - - - - - - - -	
	PIPE SUPPORT COMPONENT	F1.20A		2 - - - - - - - - - - - -	
				3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-72 (FIG NO B-88)													
763710	2-GSI-L-822	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	X	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
763720	2-GSI-L-823	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
763730	2-GSI-L-825	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
763740	2-GSI-L-826	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	X	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
763750	2-GSI-L-827	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
763760	2-GSI-L-828	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2 -	-	-	-	-	-	-	-	-	-	
				3 -	X	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-73 (FIG NO B-89)													
763800	2-GSI-V-829	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY	NDE ITEM NO	NDE METH	INSPECTION INTERVAL PLAN STATUS: FIRST PERIOD (OUTAGE 1 2 3)	SECOND PERIOD (OUTAGE 1 2 3 4)	THIRD PERIOD (OUTAGE 1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-SI-73 (FIG NO B-89)							
763810	2-GSI-R-830	F-A		VT-3	1 - - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WA			2 - - -	- - - -	- - -	
					3 - - -	- - - -	- - -	
					4 - - -	- - - -	- - -	
763820	2-GSI-L-831	F-A		VT-3	1 - - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WA			2 - - -	- - - -	- - -	
					3 - - -	- - - -	- - -	
					4 - - -	- - - -	- - -	
763830	2-GSI-L-832	F-A		VT-3	1 - - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WB			2 - - -	- - - -	- - -	
					3 - X -	- - - -	- - -	
					4 - - -	- - - -	- - -	
763840	2-GSI-L-833	F-A		VT-3	1 - - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WA			2 - - -	- - - -	- - -	
					3 - - -	- - - -	- - -	
					4 - - -	- - - -	- - -	
	LINE 2-SI-73 (FIG NO B-90)							
763900	2-GSI-R-835	F-A		VT-3	1 - - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WA			2 - - -	- - - -	- - -	
					3 - - -	- - - -	- - -	
					4 - - -	- - - -	- - -	
763910	2-GSI-R-836	F-A		VT-3	1 - - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WA			2 - - -	- - - -	- - -	
					3 - - -	- - - -	- - -	
					4 - - -	- - - -	- - -	
763920	2-GSI-R-837	F-A		VT-3	1 - - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.20WA			2 - - -	- - - -	- - -	
					3 - - -	- - - -	- - -	
					4 - - -	- - - -	- - -	

EMERGENCY CORE COOLING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-SI-73 (FIG NO B-90)													
763930	2-GSI-R-838	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-75 (FIG NO B-91)													
764000	2-GSI-V-556	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WC		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-SI-81 (FIG NO B-92)													
764100	2-ASI-L-916	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
764110	2-ASI-L-915	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
764120	2-ASI-L-914	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
764130	2-ASI-L-913	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CS-82 (FIG NO B-93)													
764200	2-ACS-L-900	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
764210	2-GCS-R-115	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	X	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
764220	2-ACS-L-901	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
764230	2-ACS-L-114	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-CS-83 (FIG NO B-94)													
764300	2-GCS-L-38	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
764310	2-GCS-L-121	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2 -	-	-	-	-	-	-	-	-	-	
				3 -	X	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
764320	2-GCS-R-37	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CS-83 (FIG NO B-94)													
764330	2-GCS-R-36	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
764340	2-GCS-L-120	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
764350	2-GCS-R-35	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
764360	2-GCS-V-34	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
764370	2-GCS-L-122	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
764380	2-GCS-L-123	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-CS-84 (FIG NO B-95)													
764400	2-GCS-V-43	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CS-84 (FIG NO B-95)													
764410	2-GCS-R-39	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-CS-85 (FIG NO B-96)													
764500	2-BCS-V-142	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
764510	2-GCS-L-40	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2 -	-	-	-	-	-	-	-	-	-	
				3 -	X	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-CS-86 (FIG NO B-97)													
764600	2-GCS-L-41	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
764610	2-GCS-L-42	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
764620	2-GCS-L-43	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	LINE 2-CS-86 (FIG NO B-97)														
764630	2-GCS-R-44	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
764640	2-GCS-L-45	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
764650	2-GCS-L-46	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
764660	2-GCS-L-47	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
764670	2-GCS-R-48	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
764680	2-GCS-R-149	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	
	LINE 2-CS-87 (FIG NO B-98)														
764700	2-GCS-V-49	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WC		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	LINE 2-CS-87 (FIG NO B-98)													
764710	2-GCS-L-50	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
764720	2-GCS-L-148	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WA		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-CS-103 (FIG NO B-99)													
764800	2-GCS-L-150	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20C		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	LINE 2-CS-794 (FIG NO B-100)													
764900	2-ACS-R-953	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WB		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
764910	2-ACS-R-910	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
764920	2-ACS-R-911	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20WC		2	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	LINE 2-CS-794 (FIG NO B-101)													
765000	2-ACS-R-914	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	LINE 2-CS-794A (FIG NO B-102)													
765100	2-ACS-R-952	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
765110	2-ACS-R-906	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
765120	2-ACS-R-907	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
765130	2-ACS-R-908	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.20B		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

CTS HEAT EXCHANGER EAST (FIGURE B-7)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	INTEGRALLY WELDED VESSEL SUPPORTS													
798000	E-CTSHEX-1VS VESSEL SUPPORT	F-A F1.40	VT-3	1 -	-	-	-	-	-	-	-	-	-	REFERENCE NO. 300675 FOR 1ST INTERVAL. REFERENCE NO. 400000 FOR 2ND INTERVAL.
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
798010	E-CTSHEX-2VS VESSEL SUPPORT	F-A F1.40	VT-3	1 -	-	-	-	-	-	-	-	-	-	REFERENCE NO. 300676 FOR 1ST INTERVAL. REFERENCE NO. 400010 FOR 2ND INTERVAL.
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
798020	E-CTSHEX-3VS VESSEL SUPPORT	F-A F1.40	VT-3	1 -	-	-	-	-	-	-	-	-	-	REFERENCE NO. 400020 FOR 1ST AND 2ND INTERVALS.
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
798030	E-CTSHEX-4VS VESSEL SUPPORT	F-A F1.40	VT-3	1 -	-	-	-	-	-	-	-	-	-	REFERENCE NO. 400030 FOR 1ST AND 2ND INTERVALS.
				2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

CTS HEAT EXCHANGER WEST (FIGURE B-8)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	INTEGRALLY WELDED VESSEL SUPPORTS													
798040	W-CTSHEX-1VS	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	REFERENCE NO. 400040 FOR 1ST
	VESSEL SUPPORT	F1.40		2	-	-	-	-	C	-	-	-	-	-	AND 2ND INTERVALS.
	W CTS HXRM			3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
798050	W-CTSHEX-2VS	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	REFERENCE NO. 400050 FOR 1ST
	VESSEL SUPPORT	F1.40		2	-	-	-	-	-	-	-	-	X	-	AND 2ND INTERVALS.
	W CTS HXRM			3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	
798060	W-CTSHEX-3VS	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	REFERENCE NO. 400060 FOR 1ST
	VESSEL SUPPORT	F1.40		2	-	-	-	-	-	-	-	-	X	-	AND 2ND INTERVALS.
	W CTS HXRM			3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	
798070	W-CTSHEX-4VS	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	REFERENCE NO. 400070 FOR 1ST
	VESSEL SUPPORT	F1.40		2	-	-	-	-	C	-	-	-	-	-	AND 2ND INTERVALS.
	W CTS HXRM			3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

CTS HEAT EXCHANGER EAST (FIGURE B-7)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SUPPORT COMPONENT													
798910	E-CTSHEX-SC-1	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	REFERENCE NO. 700110 FOR 1ST
		F1.40		2 -	-	-	-	-	-	-	-	-	-	INTERVAL. REFERENCE NO.
				3 -	-	-	-	-	-	-	-	-	-	762910 FOR 2ND INTERVAL.
				4 -	-	-	-	-	-	-	-	-	-	
798920	E-CTSHEX-SC-2	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	REFERENCE NO. 700120 FOR 1ST
		F1.40		2 -	-	-	-	-	-	-	-	-	-	INTERVAL. REFERENCE NO.
				3 -	-	-	-	-	-	-	-	-	-	762920 FOR 2ND INTERVAL.
				4 -	-	-	-	-	-	-	-	-	-	
798930	E-CTSHEX-SC-3	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	REFERENCE NO. 762930 FOR 1ST
		F1.40		2 -	-	-	-	-	-	-	-	-	-	AND 2ND INTERVALS.
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
798940	E-CTSHEX-SC-4	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	REFERENCE NO. 762940 FOR 1ST
		F1.40		2 -	-	-	-	-	-	-	-	-	-	AND 2ND INTERVALS.
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

CTS HEAT EXCHANGER WEST (FIGURE B-7A)

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SUPPORT COMPONENT													
798950	W-CTSHEX-SC-1	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	REFERENCE NO. 762950 FOR 1ST
		F1.40		2 -	-	-	-	C	-	-	-	-	-	AND 2ND INTERVALS.
	W CTS HXRM			3 -	-	-	-	X	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
798960	W-CTSHEX-SC-2	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	REFERENCE NO. 762960 FOR 1ST
		F1.40		2 -	-	-	-	-	-	-	-	X	-	AND 2ND INTERVALS.
	W CTS HXRM			3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	
798970	W-CTSHEX-SC-3	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	REFERENCE NO. 762970 FOR 1ST
		F1.40		2 -	-	-	-	-	-	-	-	X	-	AND 2ND INTERVALS.
	W CTS HXRM			3 -	-	-	-	-	-	-	-	X	-	
				4 -	-	-	-	-	-	-	-	-	-	
798980	W-CTSHEX-SC-4	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	REFERENCE NO. 762980 FOR 1ST
		F1.40		2 -	-	-	-	C	-	-	-	-	-	AND 2ND INTERVALS.
	W CTS HXRM			3 -	-	-	-	X	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

CTS HEAT EXCHANGER EAST

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				-	-	-	O	U	T	A G E	-	-	-	
	SUPPORT COMPONENT													
798990	E-CTSHEX-UL-SC	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	REFERENCE NO. 860000 FOR 1ST
	UPPER LATERAL SUPPORT	F1.40		2 -	-	-	-	-	-	-	C	-	-	AND 2ND INTERVALS.
	E CTS HXRM			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

CTS HEAT EXCHANGER WEST

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SUPPORT COMPONENT													
798995	W-CTSHEX-UL-SC	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	REFERENCE NO. 860100 FOR 1ST
	UPPER LATERAL SUPPORT	F1.40		2 -	-	-	-	-	-	-	-	-	-	AND 2ND INTERVALS.
	W CTS HXRM			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

RHR HEAT EXCHANGER EAST

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SUPPORT COMPONENT (SEE DWG. 12-3944C-3)													
799000	E-RHRHEX-UL-SC	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	REFERENCE NO. 763000 FOR 1ST
	UPPER LATERAL SUPPORT	F1.40		2	-	-	-	-	-	-	-	X	-	AND 2ND INTERVALS.
	E RHR HXRM			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	

RHR HEAT EXCHANGER WEST

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SUPPORT COMPONENT (SEE DWG. 12-3944C-3)													
799100	W-RHRHEX-UL-SC	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	REFERENCE NO. 763100 FOR 1ST
	UPPER LATERAL SUPPORT	F1.40		2 -	-	-	-	-	-	-	-	-	-	AND 2ND INTERVALS.
	W RHR HXRM			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-C-31														
800000	2-GC-L-8	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
800005	2-GC-L-56	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	-	-	-	C	-	-	
	DG PIPE TL			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
800010	2-GC-L-9	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	C	-	-	
	DG PIPE TL			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
800015	2-GC-L-10	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	C	-	-	
	DG PIPE TL			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
800020	2-GC-L-11	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	C	-	-	
	DG PIPE TL			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
800025	2-GC-R-12	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	-	-	-	C	-	-	
	DG PIPE TL			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
800030	2-GC-R-13	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	SEE AEP DWG. NO. 2-C-31														
800035	2-GC-L-48	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	C	-	-	
	ESW PIPE T			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
800040	2-GC-L-49	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	C	-	-	
	ESW PIPE T			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
800045	2-GC-L-50	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	C	-	-	
	ESW PIPE T			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
800050	2-GC-R-51	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	C	-	-	
	ESW PIPE T			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
800055	2-GC-R-52	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	C	-	-	
	ESW PIPE T			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
800060	2-GC-L-53	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
800065	2-GC-R-54	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	C	-	-	
	ESW PIPE T			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	PRESERVICE YEAR INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-C-64													
800100	2-GC-R-39	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	C	-	-	
	AFP HALL			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
800110	2-GC-R-38	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	C	-	-	
	AFP HALL			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-C-66, SH. 1 OF 2													
800210	2-GC-R-47	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	C	-	-	
	TDAFP RM			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
800220	2-GC-L-46	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
800230	2-GC-L-45	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-C-66, SH. 2 OF 2													
800250	2-GC-R-61	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	C	-	-	
	TDAFP RM			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-C-66, SH. 2 OF 2														
800260	2-GC-L-62	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	C	-	-	
	TDAFP RH			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
800270	2-GC-R-63	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	-	-	-	C	-	-	
	TDAFP RH			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-C-68, SH. 1 OF 2														
800275	2-GC-L-41	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
800280	2-GC-L-42	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	C	-	-	
	E MDAFP RH			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
800285	2-GC-R-44	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-C-68, SH. 2 OF 2														
800290	2-GC-R-57	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	C	-	-	
	AFP HALL			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	SEE AEP DWG. NO. 2-C-68, SH. 2 OF 2													
800295	2-GC-R-58	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	-	-	-	-	C	-	-	
	E MDAFP RM			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
800298	2-GC-R-60	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2 -	-	-	-	-	-	-	C	-	-	
	E MDAFP RM			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-C-74, SH. 1 OF 2													
800300	2-GC-V-15	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
800305	2-GC-L-16	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	X	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
800310	2-GC-L-17	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2 C	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
800315	2-AC-R-17A	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
800320	2-GC-R-18	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	FIRST PERIOD 1 2 3	SECOND PERIOD 1 2 3 4	THIRD PERIOD 1 2 3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-C-74, SH. 1 OF 2							
800325	2-GC-L-19	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30B		2	- - -	C - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
800330	2-GC-L-40	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30B		2	- - -	C - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-C-74, SH. 2 OF 2							
800335	2-GC-L-20	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30B		2	- - -	C - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
800340	2-GC-R-21	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2	C - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
800345	2-GC-R-22	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2	- - -	C - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
800350	2-GC-L-23	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30WB		2	- - -	C - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
800355	2-GC-L-808	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2	- - -	C - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	SEE AEP DWG. NO. 2-C-74, SH. 2 OF 2														
800360	2-GC-R-24	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
800365	2-GC-R-25	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-AC-160														
800400	2-AC-R-909	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
800420	2-AC-L-901	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
800430	2-AC-L-902	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	X	-	
	AFP ENC			3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	
800440	2-AC-L-903	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	C	-	-	
	W MDAFP RM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
800450	2-AC-L-904	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	C	-	-	
	W MDAFP RM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	SEE AEP DWG. NO. 2-AC-160														
800460	2-AC-L-905	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
800470	2-AC-L-906	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	C	-	-	
	W MDAFP RM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
800480	2-AC-L-907	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	C	-	-	
	W MDAFP RM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
800490	2-AC-L-908	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	C	-	-	
	W MDAFP RM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-13													
820000	2-GCCW-L-41	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2 -	-	-	-	-	-	-	C	-	-	
	587 AUX			3 -	-	-	-	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
820010	2-GCCW-L-42	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2 -	-	-	-	-	-	-	C	-	-	
	587 AUX			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
820020	2-GCCW-R-43	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	-	-	-	-	C	-	-	
	587 AUX			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
820030	2-GCCW-L-327	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2 -	-	-	-	-	-	-	C	-	-	
	587 AUX			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
820040	2-GCCW-V-326	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
820050	2-GCCW-L-15	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2 -	-	-	-	-	-	-	C	-	-	
	587 AUX			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
820060	2-GCCW-L-14	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2 -	-	-	-	-	-	-	C	-	-	
	587 AUX			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-13																
820070	2-GCCW-L-13	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	C	-	-			
	587 AUX			3	-	-	-	-	-	-	-	-	-	-			
				4	-	-	-	-	-	-	-	-	-	-			
820080	2-GCCW-R-12	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-			
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	C	-	-			
	587 AUX			3	-	-	-	-	-	-	-	-	-	-			
				4	-	-	-	-	-	-	-	-	-	-			
820090	2-GCCW-L-11	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-			
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	C	-	-			
	587 AUX			3	-	-	-	-	-	-	-	-	-	-			
				4	-	-	-	-	-	-	-	-	-	-			
820100	2-GCCW-R-10	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-			
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	-			
				3	-	-	-	-	-	-	-	-	-	-			
				4	-	-	-	-	-	-	-	-	-	-			
820110	2-GCCW-L-9	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-			
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	C	-	-			
	587 AUX			3	-	-	-	-	-	-	-	-	-	-			
				4	-	-	-	-	-	-	-	-	-	-			
820120	2-GCCW-R-8	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-			
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	C	-	-			
	587 AUX			3	-	-	-	-	-	-	-	-	-	-			
				4	-	-	-	-	-	-	-	-	-	-			
820130	AS-6-228	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-			
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	C	-	-			
	587 AUX			3	-	-	-	-	-	-	-	-	-	-			
				4	-	-	-	-	-	-	-	-	-	-			

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-13													
820140	2-GCCW-L-7	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2 -	-	-	-	-	-	-	C	-	-	
	587 AUX			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
820150	2-GCCW-R-6	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	-	-	-	-	C	-	-	
	587 AUX			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
820160	2-GCCW-R-5	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
820170	2-GCCW-L-4	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	-	-	-	-	C	-	-	
	587 AUX			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
820180	2-GCCW-L-3	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	-	-	-	-	C	-	-	
	587 AUX			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
820190	2-GCCW-L-3A	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	-	-	-	-	C	-	-	
	587 AUX			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
820200	2-GCCW-R-2	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2 -	-	-	-	-	-	-	C	-	-	
	587 AUX			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-13																
820210	2-GCCW-R-1	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	C	-	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
820220	2-GCCW-R-1A	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-16																
820300	2-GCCW-L-107	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	C	-	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
820310	2-GCCW-R-108	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	C	-	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
820320	2-GCCW-L-109	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	C	-	-	
	587 AUX			3	-	-	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
820330	2-GCCW-R-110	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	C	-	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
820340	2-GCCW-L-111	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - - OUTAGE - - - - - -										
	SEE AEP DWG. NO. 2-CCW-16													
820350	2-GCCW-16-HANGER	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	ADDITIONAL HANGER, NO I.D.
	PIPE SUPPORT COMPONENT	F1.30A		2 C	-	-	-	-	-	-	-	-	-	NUMBER. SEE DETAIL ON AEP
				3 -	-	-	-	-	-	-	-	-	-	DWG. NO. 2-GCCW-16, REV. 2.
				4 -	-	-	-	-	-	-	-	-	-	
820360	2-GCCW-L-113	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
820370	2-GCCW-L-310	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	-	-	-	-	C	-	-	
	587 AUX			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-17													
820400	2-GCCW-R-305	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	-	-	-	-	C	-	-	
	587 AUX			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
820410	2-GCCW-R-139	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2 -	-	-	-	-	-	-	C	-	-	
	587 AUX			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
820420	2-GCCW-R-138	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	-	-	-	-	C	-	-	
	587 AUX			3 -	-	-	-	-	-	-	X	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
820430	2-GCCW-S-306	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.30B		2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-17																
820440	2-GCCW-R-137	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	C	-		
	587 AUX			3	-	-	-	X	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
820450	2-GCCW-L-136	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	C	-		
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
820460	2-GCCW-R-135	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	C	-		
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
820470	2-GCCW-R-134	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	C	-		
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
820480	2-GCCW-R-133	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	C	-		
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
820490	2-GCCW-L-132	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.30B		2	C	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		
820500	2-GCCW-R-131	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	C	-		
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-	-		

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-17														
820510	2-GCCW-L-130	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	C	-	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
820520	2-GCCW-R-129	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	C	-	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
820530	2-GCCW-L-128	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
820540	2-GCCW-R-127	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	C	-	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
820550	2-GCCW-R-126	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
820560	2-GCCW-R-125	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
820570	2-GCCW-R-124	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-17														
820580	2-GCCW-R-123	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
820590	2-GCCW-L-122	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
820600	2-GCCW-L-121	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
820610	2-GCCW-L-120	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
820620	2-GCCW-17-HANGER	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	ADDITIONAL HANGER, NO I.D.
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	X	-	NUMBER. SEE DETAIL ON AEP
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	DWG. NO. 2-GCCW-17, REV. 5.
				4	-	-	-	-	-	-	-	-	-	-	
820630	2-GCCW-R-119	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
820640	2-GCCW-L-118	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-17														
820650	2-GCCW-R-117	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
820660	2-GCCW-L-116	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
820670	2-GCCW-L-115	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-18														
820700	2-GCCW-V-114	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-19														
820800	2-GCCW-V-16	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
820810	2-GCCW-R-17	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	SEE AEP DWG. NO. 2-CCW-22														
820900	2-GCCW-L-372	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
820910	2-GCCW-R-151	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-38, SH. 2 OF 2														
821000	2-GCCW-V-295	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821010	2-GCCW-R-209	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821020	2-GCCW-V-293	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-38, SH. 1 OF 2														
821030	2-GCCW-R-83	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-38, SH. 1 OF 2													
821040	2-GCCW-R-82	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
821050	2-GCCW-R-81	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
821060	2-GCCW-R-49	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	C	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
821070	2-GCCW-R-51	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
821080	2-GCCW-S-308	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.30B		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
821090	2-GCCW-R-52	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
821100	2-GCCW-R-53	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	PLAN STATUS FIRST PERIOD 2	3	OUTAGE 1	SECOND PERIOD 2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-38, SH. 1 OF 2													
821110	2-GCCW-R-54	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	X	-
	609 AUX			3	-	-	-	-	-	-	-	-	-	-
				4	-	-	-	-	-	-	-	-	-	-
821120	2-GCCW-S-839	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.30S		2	C	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-
				4	-	-	-	-	-	-	-	-	-	-
821130	2-GCCW-R-288	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	C	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-
				4	-	-	-	-	-	-	-	-	-	-
	SEE AEP DWG. NO. 2-CCW-39													
821200	2-GCCW-L-18	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	C	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-
				4	-	-	-	-	-	-	-	-	-	-
821210	2-GCCW-R-20	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-
				4	-	-	-	-	-	-	-	-	-	-
821220	2-GCCW-L-270	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-
				4	-	-	-	-	-	-	-	-	-	-
821230	2-GCCW-L-21	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-
				4	-	-	-	-	-	-	-	-	-	-

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	SEE AEP DWG. NO. 2-CCW-39														
821240	2-GCCW-R-22	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821250	2-GCCW-R-23	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821260	2-GCCW-R-272	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821270	2-GCCW-R-24	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821280	2-GCCW-R-25	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821290	2-GCCW-L-26	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	C	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	
821300	2-GCCW-R-27	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	2	3	PLAN STATUS FIRST PERIOD 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-39														
821310	2-GCCW-S-274	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.30WA		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821320	2-GCCW-L-28	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821330	2-GCCW-L-50	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821340	2-GCCW-R-56	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821350	2-GCCW-S-838	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.30WS		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821360	2-GCCW-R-289	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-41														
821400	2-GCCW-R-290	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	SEE AEP DWG. NO. 2-CCW-41														
821410	2-GCCW-S-840	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.30WS		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821420	2-GCCW-R-65	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	
821430	2-GCCW-S-317	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.30B		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821440	2-GCCW-R-64	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821450	2-GCCW-R-66	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821460	2-GCCW-R-67	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821470	2-GCCW-R-68	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	2	3	PLAN STATUS FIRST PERIOD 1	SECOND PERIOD 2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
							OUTAGE							
	SEE AEP DWG. NO. 2-CCW-41													
821480	2-GCCW-R-63	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
821490	2-GCCW-V-62	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
821500	2-GCCW-R-61	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
821510	2-GCCW-V-60	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
821520	2-GCCW-R-291	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	C	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
821530	2-GCCW-R-84	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
821540	2-GCCW-R-85	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY / ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					-	-	-	O	U	T	A G E	-	-	-	
	SEE AEP DWG. NO. 2-CCW-42, SH. 1 OF 3														
821590	2-GCCW-L-40	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821600	2-GCCW-R-39	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821610	2-GCCW-L-38	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821620	2-GCCW-L-36	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821630	2-GCCW-R-35	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821640	2-GCCW-V-350	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821650	2-GCCW-R-34	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	2	3	PLAN STATUS FIRST PERIOD 1	SECOND PERIOD 2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-42, SH. 1 OF 3													
821660	2-GCCW-L-279	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
821670	2-GCCW-R-33	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
821680	2-GCCW-R-31	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
821690	2-GCCW-V-351	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
821700	2-GCCW-R-30	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
821710	2-GCCW-L-29	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
821720	2-GCCW-L-44	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (FIRST PERIOD / SECOND PERIOD / THIRD PERIOD, OUTAGE 1 2 3 / 1 2 3 4 / 1 2 3)	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-42, SH. 1 OF 3				
821730	2-GCCW-R-45	F-A	VT-3	1 - - - - - - - - - - - -	
	PIPE SUPPORT COMPONENT	F1.30A		2 - - - - - - - - - X -	
	609 AUX			3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	
821740	2-GCCW-L-46	F-A	VT-3	1 - - - - - - - - - - - -	
	PIPE SUPPORT COMPONENT	F1.30B		2 - - - - - - - - - X -	
	609 AUX			3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	
	SEE AEP DWG. NO. 2-CCW-42, SH. 2 OF 3				
821750	2-GCCW-V-352	F-A	VT-3	1 - - - - - - - - - - - -	
	PIPE SUPPORT COMPONENT	F1.30WB		2 - - - - - - - - - X -	
	633 AUX			3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	
821760	2-GCCW-L-47	F-A	VT-3	1 - - - - - - - - - - - -	
	PIPE SUPPORT COMPONENT	F1.30B		2 - - - - - - - - - X -	
	633 AUX			3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	
821770	2-GCCW-R-48	F-A	VT-3	1 - - - - - - - - - - - -	
	PIPE SUPPORT COMPONENT	F1.30A		2 - - - - - - - - - X -	
	633 AUX			3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	
	SEE AEP DWG. NO. 2-CCW-43, SH. 3 OF 3				
821800	2-GCCW-V-362	F-A	VT-3	1 - - - - - - - - - - - -	
	PIPE SUPPORT COMPONENT	F1.30B		2 - - - - - - - - - X -	
	633 AUX			3 - - - - - - - - - - - -	
				4 - - - - - - - - - - - -	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	SEE AEP DWG. NO. 2-CCW-43, SH. 3 OF 3														
821810	2-GCCW-R-363	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	633 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-43, SH. 2 OF 3														
821820	2-GCCW-L-365	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821830	2-GCCW-R-366	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	-	X	-	
	633 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821840	2-GCCW-R-368	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	633 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821850	2-GCCW-V-369	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	633 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
821860	2-GCCW-L-370	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-44														
821900	2-GCCW-L-322	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-44													
821910	2-GCCW-R-58	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
821920	2-GCCW-R-321	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
821930	2-GCCW-R-57	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
821940	2-ACCW-R-57A	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
821950	2-GCCW-S-320	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE RESTRAINT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-45													
822000	2-GCCW-V-193	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	633 AUX			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
822010	2-GCCW-L-192	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	SEE AEP DWG. NO. 2-CCW-45														
822020	2-GCCW-L-191	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	C	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
822030	2-GCCW-R-45-HANGER NO. 1 REV.	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	ADDITIONAL HANGER, NO I.D.
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	-	NUMBER. SEE DETAIL ON AEP
				3	-	-	-	-	-	-	-	-	-	-	DWG. NO. 2-GCCW-45, REV. 3.
				4	-	-	-	-	-	-	-	-	-	-	
822040	2-GCCW-R-190	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	633 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
822050	2-GCCW-45-HANGER NO. 2	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	ADDITIONAL HANGER, NO I.D.
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	-	NUMBER. SEE DETAIL ON AEP
				3	-	-	-	-	-	-	-	-	-	-	DWG. NO. 2-GCCW-45, REV. 3.
				4	-	-	-	-	-	-	-	-	-	-	
822060	2-GCCW-V-277	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	-	-	-	-	X	-	
	633 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-46														
822100	2-GCCW-V-292	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	633 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-47, SH. 1 OF 2														
822200	2-GCCW-V-76	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-47, SH. 1 OF 2														
822210	2-GCCW-R-77	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-47, SH. 2 OF 2														
822220	2-GCCW-R-79	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	633 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
822230	2-GCCW-V-357	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
822240	2-GCCW-R-80	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	-	X	-	
	633 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-79														
822300	2-GCCW-L-186	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
822310	2-GCCW-L-187	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-79																
822320	2-GCCW-L-188	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
822330	2-GCCW-L-189	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
822340	2-GCCW-L-309	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-80																
822400	2-GCCW-L-194	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
822410	2-GCCW-L-195	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-81																
822500	2-GCCW-R-203	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-81														
822510	2-GCCW-L-202	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	
822520	2-GCCW-V-201	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
822530	2-GCCW-R-200	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
822540	2-GCCW-L-199	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
822550	2-GCCW-L-198	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-127, SH. 1 OF 3														
822600	2-GCCW-R-586	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
822610	2-GCCW-R-587	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1 2 3	SECOND PERIOD 1 2 3 4	THIRD PERIOD 1 2 3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-127, SH. 1 OF 3							
822620	2-GCCW-R-522	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30B		2	- - -	C - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
822630	2-GCCW-R-588	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2	- - -	C - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
822640	2-GCCW-R-589	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2	C - -	- - - -	- - -	
				3	X - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
822650	2-GCCW-R-523	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30B		2	- - -	C - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
822660	2-GCCW-R-590	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2	- - -	C - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
822670	2-GCCW-R-591	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2	- - -	C - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
822680	2-GCCW-R-525	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30B		2	- - -	C - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	PRESERVICE YEAR INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-127, SH. 1 OF 3												
822690	2-GCCW-R-574	F-A	VT-3	1	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	
				3	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-127, SH. 2 OF 3												
822700	2-GCCW-R-526	F-A	VT-3	1	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	
822710	2-GCCW-R-594	F-A	VT-3	1	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	
				3	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	
822715	2-GCCW-R-741	F-A	VT-3	1	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	C	-	-	-	-	
				3	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	
822720	2-GCCW-R-595	F-A	VT-3	1	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	
				3	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	
822730	2-GCCW-R-596	F-A	VT-3	1	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	
				3	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	
822740	2-GCCW-R-597	F-A	VT-3	1	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	C	-	-	-	-	
				3	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS / PRESERVICE YEAR: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	THIRD PERIOD (OUTAGE) 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-CCW-131, SH. 2 OF 3												
822800	2-GCCW-R-638	F-A	VT-3	1	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	C	-	-	-	-	
				3	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	
822810	2-GCCW-R-593	F-A	VT-3	1	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	
822820	2-GCCW-R-631	F-A	VT-3	1	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	
				3	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	
822825	2-GCCW-R-740	F-A	VT-3	1	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	C	-	-	-	-	
				3	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-131, SH. 3 OF 3												
822830	2-GCCW-R-567	F-A	VT-3	1	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	C	-	-	-	-	
				3	-	-	-	X	-	-	-	-	
				4	-	-	-	-	-	-	-	-	
822840	2-GCCW-R-630	F-A	VT-3	1	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	
				3	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	
822850	2-GCCW-R-592	F-A	VT-3	1	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	
				3	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				- - - - - -			O U T A G E							
	SEE AEP DWG. NO. 2-CCW-131, SH. 3 OF 3													
822860	2-GCCW-R-628	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
822870	2-GCCW-R-649	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 C	-	-	-	-	-	-	-	-	-	
				3 X	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
822880	2-GCCW-R-627	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
822890	2-GCCW-R-648	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
822900	2-GCCW-R-626	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
822910	2-GCCW-R-647	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
822920	2-GCCW-R-625	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	SEE AEP DWG. NO. 2-CCW-131, SH. 3 OF 3														
822930	2-GCCW-R-573	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-CCW-139														
822980	2-ACCW-L-913	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	X	-	
	587 AUX			3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-ESW-3													
830000	2-GESW-R-80	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
830010	2-GESW-R-81	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-ESW-4													
830020	2-GESW-R-83	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
830030	2-GESW-R-82	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	-	-	-	-	C	-	-	
	ESW PIPE T			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-ESW-25													
830100	12-GESW-V-6	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	-	-	-	-	C	-	-	
	591 TURB			3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-ESW-26													
830110	12-GESW-V-5	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1 2 3	SECOND PERIOD 1 2 3 4	THIRD PERIOD 1 2 3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-ESW-48							
830300	2-GESW-V-1	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30B		2	C - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
830310	2-GESW-R-2	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30B		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
830315	2-GESW-L-93	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30B		2	- - -	- - - -	C - -	
	609 AUX			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
830320	2-GESW-R-3	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2	- - -	- - - -	C - -	
	609 AUX			3	- - -	- - - -	X - -	
				4	- - -	- - - -	- - -	
830330	2-GESW-L-91	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
830350	2-GESW-L-92	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30WA		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
830360	2-GESW-R-5	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2	- - -	- - - -	C - -	
	609 AUX			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-ESW-49													
830400	2-GESW-R-19	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
830410	2-GESW-R-20	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
830415	2-GESW-L-94	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
830420	2-GESW-R-21	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	
830425	2-GESW-L-22	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
830430	2-GESW-R-25	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
830435	2-GESW-R-26	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	C	-	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	2	3	PLAN STATUS FIRST PERIOD 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-ESW-49														
830440	2-GESW-L-95	F-A	VT-3	1	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
830445	2-GESW-V-27	F-A	VT-3	1	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	X	-		
	609 AUX			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
830455	2-GESW-R-23	F-A	VT-3	1	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	C	-	-		
	609 AUX			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
830460	2-GESW-L-24	F-A	VT-3	1	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
	SEE AEP DWG. NO. 2-ESW-50														
830510	2-GESW-V-801	F-A	VT-3	1	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
830520	2-GESW-R-802	F-A	VT-3	1	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		
830540	2-GESW-V-804	F-A	VT-3	1	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	PLAN STATUS FIRST PERIOD 2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-ESW-53																
830610	2-GESW-V-6	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	C	-	-	
	W CTS HXRM			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
830620	2-GESW-R-7	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
830630	2-GESW-L-96	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
830640	2-GESW-R-8	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	C	-	-	
	609 AUX			3	-	-	-	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
830650	2-GESW-L-97	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
830660	2-GESW-R-9	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	C	-	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-ESW-54																
830700	2-GESW-R-10	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	C	-	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-ESW-54														
830705	2-GESW-R-11	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
830710	2-GESW-L-98	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	
830715	2-GESW-R-12	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
830720	2-GESW-R-13	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
830725	2-GESW-R-14	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
830730	2-GESW-L-18	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
830740	2-GESW-V-17	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	-	-	-	C	-	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	SEE AEP DWG. NO. 2-ESW-54														
830745	2-GESW-R-15	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
830750	2-GESW-R-16	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	C	-	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
830760	2-GESW-L-99	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	C	-	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
830770	2-AESW-R-4000	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	ADDED PER RFC-DC-12-3081.
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-ESW-55														
830810	2-GESW-V-806	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	C	-	-	
	609 TURB			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
830820	2-GESW-L-807	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
830840	2-GESW-V-809	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	-	-	-	-	X	-	
	591 TURB			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL 1	2	3	PLAN STATUS FIRST PERIOD 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-ESW-58														
830900	2-GESW-L-28	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
830910	2-GESW-V-100	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
830920	2-GESW-R-29	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
830930	2-GESW-58-HANGER	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	ADDITIONAL HANGER, NO I.D.
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	-	NUMBER. SEE SKETCH NO. 1 ON
				3	-	-	-	-	-	-	-	-	-	-	AEP DWG. NO. 2-GESW-58, REV.
				4	-	-	-	-	-	-	-	-	-	-	2.
830940	2-GESW-L-79	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	C	-	-	
	609 AUX			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
830950	2-GESW-L-30	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
830960	2-GESW-R-31	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	SEE AEP DWG. NO. 2-ESW-58														
830970	2-GESW-R-32	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-ESW-59														
831000	2-GESW-V-101	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	C	-	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
831010	2-GESW-L-34	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
831020	2-GESW-L-70	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
831030	2-GESW-L-35	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
831040	2-GESW-R-36	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
831050	2-GESW-L-37	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
				1 2 3	1 2 3 4 (OUTAGE)	1 2 3	
	SEE AEP DWG. NO. 2-ESW-63						
831100	2-GESW-R-90	F-A	VT-3	1 - - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2 - - -	- - - -	C - -	
	AFP HALL			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
831110	2-GESW-R-89	F-A	VT-3	1 - - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
831120	2-GESW-L-155A	F-A	VT-3	1 - - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2 - - -	- - - -	- X -	
	TDAFP RM			3 - - -	- - - -	- X -	
				4 - - -	- - - -	- - -	
831130	2-GESW-R-88	F-A	VT-3	1 - - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
831140	2-GESW-R-87	F-A	VT-3	1 - - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30WB		2 - - -	- - - -	C - -	
	TDAFP RM			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-ESW-66, SH. 1 OF 2						
831200	2-GESW-L-66	F-A	VT-3	1 - - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2 - - -	- - - -	- - -	
				3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	
831210	2-GESW-V-78	F-A	VT-3	1 - - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2 - - -	- - - -	C - -	
	609 AUX			3 - - -	- - - -	- - -	
				4 - - -	- - - -	- - -	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-ESW-66, SH. 1 OF 2													
831230	2-GESW-L-60	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
831240	2-GESW-R-64	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
831250	2-GESW-L-63	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
831260	2-GESW-L-76	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	C	-	-	
	633 AUX			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-ESW-66, SH. 2 OF 2													
831290	2-GESW-L-58	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
831300	2-GESW-R-57	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
831310	2-GESW-L-56	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	C	-	-	
	633 AUX			3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-ESW-66, SH. 2 OF 2													
831320	2-GESW-L-55	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
831340	2-GESW-L-53	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
831350	2-GESW-L-52	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	-	-	
	633 AUX			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-ESW-67, SH. 1 OF 2													
831410	2-GESW-V-73	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	609 AUX			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
831430	2-GESW-L-60	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
831440	2-GESW-R-61	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-ESW-67, SH. 2 OF 2													
831500	2-GESW-R-51	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	C	-	-	
	633 AUX			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

ESSENTIAL SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
					PLAN STATUS			
					1 2 3	1 2 3 4 (OUTAGE)	1 2 3	
	SEE AEP DWG. NO. 2-ESW-67, SH. 2 OF 2							
831510	2-GESW-L-50	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30B		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
831520	2-GESW-R-49	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30B		2	- - -	- - - -	- - -	
	633 AUX			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
831530	2-GESW-L-48	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30B		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
831540	2-GESW-L-47	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30B		2	- - -	- - - -	C - -	
	633 AUX			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
831550	2-GESW-L-46	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30B		2	- - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
831560	2-GESW-V-71	F-A	VT-3	1	- - -	- - - -	- - -	DELETED PER RFC-12-3081.
	PIPE SUPPORT COMPONENT	F1.30WB		2	- - -	- - - -	- - -	
	633 AUX			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
					1 2 3	OUTAGE 1 2 3 4	1 2 3	
	SEE AEP DWG. NO. 2-FW-20							
853000	2-GFW-R-100	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2	C - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
853002	2-GFW-R-101	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30B		2	- - -	- - - -	- X -	
	DG PIPE TL			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
853004	2-GFW-L-102	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30B		2	- - -	- - - -	C - -	
	DG PIPE TL			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
853006	2-GFW-L-103	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30B		2	- - -	- - - -	C - -	
	DG PIPE TL			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
853008	2-GFW-L-104	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30B		2	- - -	- - - -	C - -	
	DG PIPE TL			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
853010	2-GFW-L-105	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30WA		2	- - -	- - - -	- X -	
	DG PIPE TL			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
853016	2-GFW-L-825	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30WA		2	- - -	- C - -	- - -	
				3	- - -	X - - -	- - -	
				4	- - -	- - - -	- - -	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-20														
853018	2-GFW-L-107	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853020	2-GFW-R-108	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853022	2-GFW-R-826	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853024	2-GFW-L-109	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853026	2-GFW-L-110	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853028	2-GFW-R-827	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853030	2-GFW-L-111	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL ASME SEC. XI CATGY ITEM NO	NDE METH	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-20													
853032	2-GFW-R-112	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
853034	2-GFW-R-113	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
853036	2-GFW-L-828	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
853038	2-GFW-V-829	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-32													
853050	2-GFW-V-242	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
853052	2-GFW-L-243	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
853054	2-GFW-R-244	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-32														
853056	2-GFW-L-245	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853058	2-GFW-L-246	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853060	2-GFW-R-247	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853062	2-GFW-L-248	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853064	2-GFW-R-249	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853066	2-GFW-L-250	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853068	2-GFW-L-251	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-32														
853070	2-GFW-L-252	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	-	X	-	
	DG PIPE TL			3	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	
853072	2-GFW-L-253	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853074	2-GFW-L-254	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	C	-	-	
	DG PIPE TL			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853076	2-GFW-L-255	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	C	-	-	
	DG PIPE TL			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853078	2-GFW-R-256	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30		2	-	-	-	-	-	-	-	C	-	-	
	DG PIPE TL			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853080	2-GFW-L-257	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	C	-	-	
	DG PIPE TL			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-33														
853100	2-GFW-V-224	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY	NDE ITEM NO	METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS. **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-33														
853105	2-GFW-L-225	F-A		VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A			2 C	-	-	-	-	-	-	-	-	-	
					3 -	-	-	-	-	-	-	-	-	-	
					4 -	-	-	-	-	-	-	-	-	-	
853110	2-GFW-R-226	F-A		VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A			2 -	-	-	-	C	-	-	-	-	-	
					3 -	-	-	-	-	-	-	-	-	-	
					4 -	-	-	-	-	-	-	-	-	-	
853115	2-GFW-L-227	F-A		VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB			2 -	-	-	-	C	-	-	-	-	-	
					3 -	-	-	-	-	-	-	-	-	-	
					4 -	-	-	-	-	-	-	-	-	-	
853120	2-GFW-L-228	F-A		VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B			2 -	-	-	-	C	-	-	-	-	-	
					3 -	-	-	-	-	-	-	-	-	-	
					4 -	-	-	-	-	-	-	-	-	-	
853125	2-GFW-R-229	F-A		VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A			2 -	-	-	-	C	-	-	-	-	-	
					3 -	-	-	-	-	-	-	-	-	-	
					4 -	-	-	-	-	-	-	-	-	-	
853130	2-GFW-R-230	F-A		VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A			2 -	-	-	-	C	-	-	-	-	-	
					3 -	-	-	-	-	-	-	-	-	-	
					4 -	-	-	-	-	-	-	-	-	-	
853135	2-GFW-L-231	F-A		VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A			2 C	-	-	-	-	-	-	-	-	-	
					3 -	-	-	-	-	-	-	-	-	-	
					4 -	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-33														
853140	2-GFW-R-232	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853145	2-GFW-R-233	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	-	-	-	
	DG PIPE TL			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853155	2-GFW-L-235	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	C	-	-	
	DG PIPE TL			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853160	2-GFW-R-236	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	C	-	-	
	DG PIPE TL			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853165	2-GFW-L-237	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	DG PIPE TL			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853170	2-GFW-L-238	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853180	2-GFW-L-240	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	C	-	-	
	DG PIPE TL			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
					PLAN STATUS			
					OUTAGE			
					1 2 3	1 2 3 4	1 2 3	
	SEE AEP DWG. NO. 2-FW-37							
853200	2-GFW-L-117	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2	- - -	- - - -	C - -	
	TDAFP RM			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
853210	2-GFW-L-116	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30B		2	- - -	- - - -	- - -	
	TDAFP RM			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
853220	2-GFW-L-115	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2	- - -	- - - -	- X -	
	TDAFP RM			3	- - -	- - - -	- X -	
				4	- - -	- - - -	- - -	
853230	2-GFW-L-114	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30WB		2	C - -	- - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
853235	2-AFW-R-4008	F-A	VT-3	1	- - -	- - - -	- - -	ADDED PER RFC-DC-12-3081.
	PIPE SUPPORT COMPONENT	F1.30A		2	- - -	- - - -	- - -	
				3	X - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
	SEE AEP DWG. NO. 2-FW-45							
853250	2-GFW-L-122	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2	- - -	- - - -	C - -	
	E MDAFP RM			3	- - -	- - - -	X - -	
				4	- - -	- - - -	- - -	
853260	2-GFW-L-121	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30B		2	- - -	- - - -	C - -	
	E MDAFP RM			3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL ASME SEC. XI CATGY	NDE ITEM NO METH	PLAN STATUS FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-45																
853270	2-GFW-L-120	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	C	-	-	
	AFP HALL			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
853280	2-GFW-R-119	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	C	-	-	
	AFP HALL			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-48																
853300	2-GFW-L-133	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
853310	2-GFW-L-132	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
853320	2-GFW-L-131	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	-	X	-	
	E MDAFP RM			3	-	-	-	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
853330	2-GFW-L-130	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	
853340	2-GFW-L-129	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	C	-	-	
	AFP HALL			3	-	-	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	SEE AEP DWG. NO. 2-FW-48														
853350	2-GFW-R-128	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-53, SH. 1 OF 4														
853400	2-GFW-R-178	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853410	2-GFW-L-179	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853420	2-GFW-R-180	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853440	2-GFW-R-181	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853450	2-GFW-R-182	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853460	2-GFW-L-183	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	SEE AEP DWG. NO. 2-FW-53, SH. 1 OF 4														
853470	2-GFW-L-184	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-53, SH. 2 OF 4														
853500	2-GFW-L-185	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853505	2-GFW-R-186	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853510	2-GFW-R-187	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853515	2-GFW-L-188	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853520	2-GFW-L-189	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853525	2-GFW-R-190	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				-	-	-	O	U	T	A G E	-	-	-	
	SEE AEP DWG. NO. 2-FW-53, SH. 2 OF 4													
853530	2-GFW-L-191	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
853535	2-GFW-R-192	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
853540	2-GFW-R-193	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
853545	2-GFW-L-194	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
853550	2-GFW-R-195	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 C	-	-	-	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
853555	2-GFW-R-196	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	
853560	2-GFW-R-197	F-A	VT-3	1 -	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2 -	-	-	C	-	-	-	-	-	-	
				3 -	-	-	-	-	-	-	-	-	-	
				4 -	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-53, SH. 3 OF 4														
853600	2-GFW-L-803	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853650	2-GFW-L-802	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853652	2-GFW-L-801	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853654	2-GFW-L-800	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-53, SH. 4 OF 4														
853656	2-GFW-L-806	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853658	2-GFW-L-805	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853660	2-GFW-L-804	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	SEE AEP DWG. NO. 2-FW-54, SH. 1 OF 2														
853662	2-GFW-R-807	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853664	2-GFW-L-808	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-54, SH. 2 OF 2														
853666	2-GFW-R-809	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853668	2-GFW-L-810	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	C	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853670	2-GFW-L-811	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-55, SH. 1 OF 4														
853700	2-GFW-R-141	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL ASME SEC. XI CATGY ITEM NO	NDE METH	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	SEE AEP DWG. NO. 2-FW-55, SH. 1 OF 4													
853710	2-GFW-R-142	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
853720	2-GFW-L-143	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
853730	2-GFW-L-144	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
853740	2-GFW-R-145	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
853750	2-GFW-R-146	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	
				3	-	-	-	X	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
853760	2-GFW-L-147	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-55, SH. 2 OF 4													
853805	2-GFW-R-148	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1 2 3	SECOND PERIOD 1 2 3 4	THIRD PERIOD 1 2 3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-55, SH. 2 OF 4							
853810	2-GFW-L-149	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2	- - -	C - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
853815	2-GFW-R-150	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2	- - -	C - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
853820	2-GFW-L-152	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30WB		2	- - -	C - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
853825	2-GFW-L-153	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2	- - -	C - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	
853830	2-GFW-55-HANGER-1	F-A	VT-3	1	- - -	- - - -	- - -	ADDITIONAL HANGER, NO I.D.
	PIPE SUPPORT COMPONENT	F1.30A		2	- - -	C - - -	- - -	NUMBER. SEE DETAIL "A-1" ON
				3	- - -	- - - -	- - -	AEP DWG. NO. 2-GFW-55, SH. 2
				4	- - -	- - - -	- - -	OF 4, REV. 2.
853835	2-GFW-55-HANGER-2	F-A	VT-3	1	- - -	- - - -	- - -	ADDITIONAL HANGER, NO I.D.
	PIPE SUPPORT COMPONENT	F1.30A		2	- - -	C - - -	- - -	NUMBER. SEE DETAIL "A-2" ON
				3	- - -	- - - -	- - -	AEP DWG. NO. 2-GFW-55, SH. 2
				4	- - -	- - - -	- - -	OF 4, REV. 2.
853840	2-GFW-R-154	F-A	VT-3	1	- - -	- - - -	- - -	
	PIPE SUPPORT COMPONENT	F1.30A		2	- - -	C - - -	- - -	
				3	- - -	- - - -	- - -	
				4	- - -	- - - -	- - -	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
				OUTAGE										
	SEE AEP DWG. NO. 2-FW-55, SH. 2 OF 4													
853842	2-GFW-55-HANGER-3	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	ADDITIONAL HANGER, NO I.D.
	PIPE SUPPORT COMPONENT	F1.30		2	-	-	-	C	-	-	-	-	-	NUMBER. SEE DETAIL "A-3" ON
				3	-	-	-	-	-	-	-	-	-	AEP DWG. NO. 2-GFW-55, SH. 2
				4	-	-	-	-	-	-	-	-	-	OF 4, REV. 2.
853845	2-GFW-R-155	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
853850	2-GFW-R-156 REV. 2	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
853855	2-GFW-L-157	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
853860	2-GFW-55-DET. B	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	ADDITIONAL HANGER, NO I.D.
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	NUMBER. SEE DETAIL "B" ON AEP
				3	-	-	-	-	-	-	-	-	-	DWG. NO. 2-GFW-55, SH. 2 OF
				4	-	-	-	-	-	-	-	-	-	4,REV. 2.
853865	2-GFW-R-158	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
853870	2-GFW-R-160	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	FIRST PERIOD 1	FIRST PERIOD 2	FIRST PERIOD 3	SECOND PERIOD 1	SECOND PERIOD 2	SECOND PERIOD 3	SECOND PERIOD 4	THIRD PERIOD 1	THIRD PERIOD 2	THIRD PERIOD 3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-55, SH. 3 OF 4														
853900	2-GFW-L-812	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853910	2-GFW-R-813	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853920	2-GFW-L-814	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853925	2-GFW-L-815	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853930	2-GFW-L-816	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-55, SH. 4 OF 4														
853935	2-GFW-L-817	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
853940	2-GFW-L-818	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-55, SH. 4 OF 4															
853945	2-GFW-L-819	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-		
	SEE AEP DWG. NO. 2-GFW-56, SH. 1 OF 2															
854000	2-GFW-L-820	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.30WA		2	C	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-		
	SEE AEP DWG. NO. 2-FW-56, SH. 1 OF 2															
854010	2-GFW-L-241	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	C	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-		
	SEE AEP DWG. NO. 2-FW-56, SH. 2 OF 2															
854020	2-GFW-R-821	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-		
854030	2-GFW-L-822	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	C	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-	-		

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (FIRST PERIOD 1 2 3 / SECOND PERIOD 1 2 3 / THIRD PERIOD 1 2 3)	PRESERVICE YEAR INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-AFW-88				
854110	2-AFW-88-HANGER-1-DET. E PIPE SUPPORT COMPONENT W MDAFP RM	F-A F1.30A	VT-3	1 - - - - - - - - - - - - 2 - - - - - - - - C - - 3 - - - - - - - - - - - 4 - - - - - - - - - - -	ADDITIONAL HANGER, NO I.D. NUMBER. SEE DETAIL "E" ON AEP DWG. NO. 2-AFW-88, REV. 1.
854115	2-AFW-L-901 PIPE SUPPORT COMPONENT	F-A F1.30WB	VT-3	1 - - - - - - - - - - - 2 - - - - - - - - - - - 3 - - - - - - - - - - - 4 - - - - - - - - - - -	
854120	2-AFW-L-902 PIPE SUPPORT COMPONENT W MDAFP RM	F-A F1.30B	VT-3	1 - - - - - - - - - - - 2 - - - - - - - - C - - 3 - - - - - - - - - - - 4 - - - - - - - - - - -	
854125	2-AFW-L-903 PIPE SUPPORT COMPONENT	F-A F1.30WB	VT-3	1 - - - - - - - - - - - 2 - - - - - - - - - - - 3 - - - - - - - - - - - 4 - - - - - - - - - - -	
854130	2-AFW-88-HANGER-2-DET. F PIPE SUPPORT COMPONENT	F-A F1.30A	VT-3	1 - - - - - - - - - - - 2 - - - - - - - - X - - 3 X - - - - - - - - - - 4 - - - - - - - - - - -	ADDITIONAL HANGER NO I.D. NUMBER. SEE DETAIL "F" ON AEP DWG. NO. 2-AFW-88, REV. 1.
854135	2-AFW-L-904 PIPE SUPPORT COMPONENT	F-A F1.30B	VT-3	1 - - - - - - - - - - - 2 - - - - - - - - - - - 3 - - - - - - - - - - - 4 - - - - - - - - - - -	
854140	2-AFW-88-HANGER-3-DET. G PIPE SUPPORT COMPONENT W MDAFP RM	F-A F1.30A	VT-3	1 - - - - - - - - - - - 2 C - - - - - - - C - - 3 - - - - - - - - - - - 4 - - - - - - - - - - -	ADDITIONAL HANGER, NO I.D. NUMBER. SEE DETAIL "G" ON AEP DWG. NO. 2-AFW-88, REV. 1.

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-AFW-88													
854145	2-AFW-L-905	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
854150	2-AFW-L-906	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	INACCESSIBLE DUE TO SEISMIC
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	X	-	ENCLOSURE.
	AFP ENC			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
854155	2-AFW-L-907	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
854160	2-AFW-L-912	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	C	-	-	
	AFP HALL			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-38													
855000	2-GFW-L-200	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	DG PIPE TL			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	
855100	2-GFW-L-201	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	DG PIPE TL			3	-	-	-	-	-	-	-	X	-	
				4	-	-	-	-	-	-	-	-	-	
855200	2-GFW-R-202	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	DG PIPE TL			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-38													
855300	2-GFW-L-203	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	X	-	
	DG PIPE TL			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
855310	2-GFW-L-204	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	X	-	
	DG PIPE TL			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
855320	2-GFW-R-205	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	DG PIPE TL			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
855330	2-GFW-L-206	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	X	-	
	DG PIPE TL			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
855350	2-GFW-L-208	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	ESW PIPE T			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
855360	2-GFW-R-209	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	ESW PIPE T			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
855370	2-GFW-L-210	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	X	-	
	ESW PIPE T			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-38													
855380	2-GFW-R-211	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	ESW PIPE T			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
855390	2-GFW-R-212	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	ESW PIPE T			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
855400	2-GFW-L-213	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	X	-	
	ESW PIPE T			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
855410	2-GFW-L-214	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	X	-	
	ESW PIPE T			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
855420	2-GFW-R-215	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	ESW PIPE T			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
855430	2-GFW-L-216	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	X	-	
	ESW PIPE T			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
855440	2-GFW-R-217	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	ESW PIPE T			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY	ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS (OUTAGE) FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-38														
855450	2-GFW-R-218	F-A		VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A			2	-	-	-	-	-	-	-	X	-	
	ESW PIPE T				3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	
855460	2-GFW-V-219	F-A		VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A			2	-	-	-	-	-	-	-	X	-	
	ESW PIPE T				3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	
855470	2-GFW-L-220	F-A		VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A			2	-	-	-	-	-	-	-	X	-	
	ESW PIPE T				3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	
855480	2-AFW-L-928	F-A		VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A			2	-	-	-	-	-	-	-	X	-	
	ESW PIPE T				3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	
855490	2-AFW-R-4001	F-A		VT-3	1	-	-	-	-	-	-	-	-	-	ADDED PER RFC-DC-12-3081.
	PIPE SUPPORT COMPONENT	F1.30B			2	-	-	-	-	-	-	-	X	-	
	DG PIPE TL				3	X	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-44														
855700	2-GFW-L-123	F-A		VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B			2	-	-	-	-	-	-	-	X	-	
	AFP HALL				3	-	-	-	-	-	-	-	X	-	
					4	-	-	-	-	-	-	-	-	-	
855710	2-GFW-R-124	F-A		VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A			2	-	-	-	-	-	-	-	X	-	
	TDAFP RH				3	-	-	-	-	-	-	-	-	-	
					4	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	OUTAGE 1	2	3	4	SECOND PERIOD 1	2	3	THIRD PERIOD	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-44														
855720	2-GFW-R-125	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30		2	-	-	-	-	-	-	-	-	X	-	
				3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
855730	2-GFW-L-126	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	-	-	-	-	X	-	
	TDAFP RM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
855740	2-GFW-L-127	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	-	X	-	
	TDAFP RM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
855750	2-GFW-L-223	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	TDAFP RM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-50														
856000	2-GFW-L-134	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	X	-	
	AFP HALL			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
856100	2-GFW-L-135	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	AFP HALL			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
856200	2-GFW-R-136	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	TDAFP RM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-50														
856220	2-GFW-L-138	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	X	-	
	TDAFP RM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
856230	2-GFW-R-139	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	-	-	-	-	X	-	
	TDAFP RM			3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
856249	2-GFW-L-140	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WA		2	-	-	-	-	-	-	-	-	X	-	
	TDAFP RM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-57 SH. 1														
856500	2-GFW-R-161	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
856510	2-GFW-R-162	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
856520	2-GFW-L-163	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
856530	2-GFW-R-164	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F-A		2	-	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**F1.30A**

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	SEE AEP DWG. NO. 2-FW-57 SH. 1														
856540	2-GFW-L-165	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
856550	2-GFW-R-166	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F-A		2	-	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	**F1.30B**
856560	2-GFW-R-167	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	X	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
856570	2-GFW-L-168	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	X	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
856580	2-GFW-R-169	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	X	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
856590	2-GFW-L-199	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
856600	2-AFW-L-921	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL / PLAN STATUS: FIRST PERIOD 1	2	3	SECOND PERIOD (OUTAGE) 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-57 SH. 1													
856610	2-AFW-L-922	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
856620	2-AFW-L-924	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
856630	2-AFW-L-925	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
856640	2-AFW-L-926	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
856650	2-AFW-L-927	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-57 SH. 2													
856660	2-GFW-L-170	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
856670	2-GFW-L-171	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	THIRD PERIOD 1	2	3	PRESERVICE YEAR INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE									
	SEE AEP DWG. NO. 2-FW-57 SH. 2													
856680	2-GFW-L-172	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
856690	2-GFW-R-173	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
856700	2-GFW-L-174	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
856710	2-GFW-R-175	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
856720	2-GFW-R-176	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
856730	2-GFW-V-177	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	** SPRING HANGER
	PIPE SUPPORT COMPONENT	F1.30**		2	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	
856740	2-GFW-L-198	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
	SEE AEP DWG. NO. 2-FW-57 SH. 2														
856750	2-AFW-L-916	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
856760	2-AFW-L-917	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
856780	2-AFW-L-918	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
856790	2-AFW-L-919	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
856800	2-AFW-L-920	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30A		2	-	-	-	-	-	-	-	-	X	-	
	RWST TUN			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
	SEE AEP DWG. NO. 2-FW-89														
856810	2-AFW-R-908	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	X	-	
	W MDAFP RM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
856820	2-AFW-L-909	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30WB		2	-	-	-	-	-	-	-	-	X	-	
	W MDAFP RM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATGY ITEM NO	NDE METH	INSPECTION INTERVAL	PLAN STATUS FIRST PERIOD 1	2	3	SECOND PERIOD 1	2	3	4	THIRD PERIOD 1	2	3	INSTRUCTIONS **CALIBRATION BLOCK**
					OUTAGE										
	SEE AEP DWG. NO. 2-FW-89														
856830	2-AFW-L-910	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	X	-	
	W MDAFP RM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	
856840	2-AFW-L-911	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	
	PIPE SUPPORT COMPONENT	F1.30B		2	-	-	-	-	-	-	-	-	X	-	
	W MDAFP RM			3	-	-	-	-	-	-	-	-	-	-	
				4	-	-	-	-	-	-	-	-	-	-	