

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9807150254 DOC. DATE: 98/06/30 NOTARIZED: NO DOCKET #
 FACIL: 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana M 05000316
 AUTH. NAME AUTHOR AFFILIATION
 MINOR, J.W. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 CENTER, J.F. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 COOPER, D.E. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for June 1998 for DC Cook Nuclear
 Plant Unit 2.W/980706 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD3-3 PD	1 1	STANG, J	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	<u>FILE CENTER 01</u>	1 1
	OC/DBA/PAD	1 1	RGN3	1 1
EXTERNAL:	LITCO BRYCE, J H	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 9 ENCL 9

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200

American Electric Power
Cook Nuclear Plant
One Cook Place
Bridgman, MI 49106
616 465 5901



U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

July 6, 1998

Gentlemen,

Pursuant to the requirements of Donald C. Cook Nuclear Plant Unit 2
Technical Specification 6.9.1.10, the attached Monthly Operating Report
for the month of June 1998 is submitted.

Sincerely,

A handwritten signature, likely of D.E. Cooper, is written over the word 'Sincerely,'.

D.E. Cooper
Plant Manager

/jc

Attachment

c: NRC Region III
INPO Records Center
ANI Nuclear Engineering Department
D.R. Hahn
S. Hamming
B. Lewis
J.R. Sampson
B.L. Bartlett
P.A. Barrett
S.J. Brewer
D.W. Paul
D.L. Noble
W.H. Schalk
D.G. Turner
G. John
D.P. Lynch
R.G. Pickard
G.T. Gaffney

140087

9807150254 980630
PDR ADDCK 05000316
R PDR

N.R.C. OPERATING DATA REPORT

DOCKET NO.	50 - 316
DATE	July 6, 1998
COMPLETED BY	JW Minor
TELEPHONE	616-465-5901

OPERATING STATUS

1. Unit Name	D. C. Cook Unit 2
2. Reporting Period	Jun-98
3. Licensed Thermal Power (MWt)	3411
4. Name Plate Rating (Gross MWe)	1133
5. Design Electrical Rating (Net MWe)	1090
6. Maximum Dependable Capacity (GROSS MWe)	1100
7. Maximum Dependable Capacity (Net MWe)	1060

Notes:

8. If Changes Occur in Capacity Ratings (Items no. 3 through 7) Since Last Report Give Reasons:

9. Power Level To Which Restricted, If Any (Net MWe):

10. Reasons For Restrictions, If Any:

	This Month	Year-to-Date	Cumulative
11. Hours in Reporting Period	720.0	4344.0	179664.0
12. No. of Hrs. Reactor Was Critical	0.0	0.0	121771.0
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator on Line	0.0	0.0	118153.4
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Gen. (MWH)	0.0	0.0	366007650.4
17. Gross Electrical Energy Gen. (MWH)	0.0	0.0	118584640.0
18. Net Electrical Energy Gen. (MWH)	0.0	0.0	114257779.0
19. Unit Service Factor	0.0	0.0	66.6
20. Unit Availability Factor	0.0	0.0	66.6
21. Unit Capacity Factor (MDC Net)	0.0	0.0	60.7
22. Unit Capacity Factor (DER Net)	0.0	0.0	59.1
23. Unit Forced Outage Rate	100.0	100.0	16.9

24. Shutdowns Scheduled over Next Six Months (Type, Date, and Duration):
None

25. If Shut Down At End of Report Period, Estimated Date of Startup:
To be Determined.

26. Units in Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY		
INITIAL ELECTRICITY		
COMMERCIAL OPERATION		

DOCKET NO.
UNIT NAME
DATE
COMPLETED BY
TELEPHONE

50 - 316
D.C. Cook Unit 2
July 6, 1998
JW Minor
616-465-5901

AVERAGE DAILY POWER LEVEL (MWe-Net)

June 1998

DAY	AVERAGE DAILY POWER LEVEL	DAY	AVERAGE DAILY POWER LEVEL
6/1/98	0	6/17/98	0
6/2/98	0	6/18/98	0
6/3/98	0	6/19/98	0
6/4/98	0	6/20/98	0
6/5/98	0	6/21/98	0
6/6/98	0	6/22/98	0
6/7/98	0	6/23/98	0
6/8/98	0	6/24/98	0
6/9/98	0	6/25/98	0
6/10/98	0	6/26/98	0
6/11/98	0	6/27/98	0
6/12/98	0	6/28/98	0
6/13/98	0	6/29/98	0
6/14/98	0	6/30/98	0
6/15/98	0		
6/16/98	0		

DOCKET NO.
UNIT NAME
DATE
COMPLETED BY
TELEPHONE
PAGE

50 - 316
D.C. Cook Unit 2
July 6, 1998
JF Center
616-697-5098
1 of 1

MONTHLY OPERATING ACTIVITIES - June 1998

HIGHLIGHTS

The unit entered this reporting period in Mode 6 at 0% RTP.

The unit exited this reporting period in Mode 5 at 0% RTP.

There were no challenges to the pressurizer safety valves or power operated relief valves.

Gross electrical generation for the month of June was 0 MWh.

DETAILS*

06/01/98

Unit remained shutdown the entire reporting period to resolve design basis questions discovered during the NRC Architect and Engineering (AE) Inspection.

* All time entries are Eastern Standard Time (EST).

DOCKET NO.	50 - 316
UNIT NAME	D.C. Cook Unit 2
DATE	July 6, 1998
COMPLETED BY	JF Center
TELEPHONE	616-697-5098
PAGE	1 of 1

UNIT SHUTDOWNS AND POWER REDUCTIONS - June 1998

NO.	DATE	TYPE ¹	DURATION HOURS	REASON ²	METHOD OF SHUTTING DOWN REACTOR ³	LICENSEE EVENT REPORT NO.	SYSTEM CODE ⁴	COMPONENT CODE ⁵	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
335	010798	F	720.0	F	4	N/A	N/A	N/A	The unit remained shutdown to resolve design basis questions discovered during the NRC Architect and Engineering (AE) Inspection.

1 TYPE: F: Forced S: Scheduled	2 REASON: A: Equipment Failure (Explain) B: Maintenance or Test C: Refueling D: Regulatory Restriction E: Operator Training and License Examination F: Administrative G: Operational Error (Explain) H: Other (Explain)	3 METHOD: 1: Manual 2: Manual Scram 3: Automatic Scram 4: Other (Explain)	4 SYSTEM: Exhibit G - Instructions for preparation of data entry sheets for Licensee Event Report (LER) File (NUREG 0161)	5 COMPONENT: Exhibit I: Same Source
---	---	--	---	---

