

SURVEILLANCE REQUIREMENTS (Continued)

- 4.7.1.2 Each auxiliary feedwater pump shall be demonstrated OPERABLE when tested pursuant to Specification 4.0.5 by:
- a. Verifying that each motor driven auxiliary feedwater pump's developed head at the test flow point is greater than or equal to the required developed head.
 - b. Verifying that the turbine driven auxiliary feedwater pump's developed head at the test flow point is greater than or equal to the required developed head. ~~when the secondary steam supply pressure is greater than 310 psig.~~ The provisions of Specification 4.0.4 are not applicable for entry into MODE 3.
 - c. Verifying that each non-automatic valve in the flow path that is not locked, sealed, or otherwise secured in position is in its correct position.
 - d. Verifying that each automatic valve in the flow path is in the fully open position whenever the auxiliary feedwater system is placed in automatic control or when above 10% RATED THERMAL POWER. This requirement is not applicable for those portions of the auxiliary feedwater system being used intermittently to maintain steam generator water level.
 - e. Verifying at least once per 18 months during shutdown that each automatic valve in the flow path actuates to its correct position upon receipt of the appropriate engineered safety features actuation test signal required by Specification 3/4.3.2.
 - f. Verifying at least once per 18 months during shutdown that each auxiliary feedwater pump starts as designed automatically upon receipt of the appropriate engineered safety features actuation test signal required by Specification 3/4.3.2.
 - g. Verifying at least once per 18 months during shutdown that the unit cross-tie valves can cycle full travel. Following cycling, the valves will be verified to be in their closed positions.

SURVEILLANCE REQUIREMENTS

- 4.7.1.2 Each auxiliary feedwater pump shall be demonstrated OPERABLE when tested pursuant to Specification 4.0.5 by:
- a. Verifying that each motor driven auxiliary feed pump's developed head at the test flow point is greater than or equal to the required developed head.
 - b. Verifying that the turbine driven auxiliary feedwater pump's developed head at the test flow point is greater than or equal to the required developed head, ~~when the secondary steam supply pressure is greater than 210 psig.~~ The provisions of Specification 4.0.4 are not applicable for entry into MODE 3.
 - c. Verifying that each non-automatic valve in the flow path that is not locked, sealed, or otherwise secured in position is in its correct position.
 - d. Verifying that each automatic valve in the flow path is in the fully open position whenever the auxiliary feedwater system is placed in automatic control or when above 10% RATED THERMAL POWER. This requirement is not applicable for those portions of the auxiliary feedwater system being used intermittently to maintain steam generator level.
 - e. Verifying at least once per 18 months during shutdown that each automatic valve in the flow path actuates to its correct position upon receipt of the appropriate engineered safety features actuation test signal required by Specification 3/4.3.2.
 - f. Verifying at least once per 18 months during shutdown that each auxiliary feedwater pump starts as designed automatically upon receipt of the appropriate engineered safety features actuation test signal required by Specification 3/4.3.2.
 - g. Verifying at least once per 18 months during shutdown that the unit cross-tie valves can cycle full travel. Following cycling, the valves will be verified to be in their closed positions.

ATTACHMENT 3 TO AEP:NRC:0906H

PROPOSED REVISED
TECHNICAL SPECIFICATION PAGES

SURVEILLANCE REQUIREMENTS (Continued)

- 4.7.1.2 Each auxiliary feedwater pump shall be demonstrated OPERABLE when tested pursuant to Specification 4.0.5 by:
- a. Verifying that each motor driven auxiliary feedwater pump's developed head at the test flow point is greater than or equal to the required developed head.
 - b. Verifying that the turbine driven auxiliary feedwater pump's developed head at the test flow point is greater than or equal to the required developed head. The provisions of Specification 4.0.4 are not applicable for entry into MODE 3.
 - c. Verifying that each non-automatic valve in the flow path that is not locked, sealed, or otherwise secured in position is in its correct position.
 - d. Verifying that each automatic valve in the flow path is in the fully open position whenever the auxiliary feedwater system is placed in automatic control or when above 10% RATED THERMAL POWER. This requirement is not applicable for those portions of the auxiliary feedwater system being used intermittently to maintain steam generator water level.
 - e. Verifying at least once per 18 months during shutdown that each automatic valve in the flow path actuates to its correct position upon receipt of the appropriate engineered safety features actuation test signal required by Specification 3/4.3.2.
 - f. Verifying at least once per 18 months during shutdown that each auxiliary feedwater pump starts as designed automatically upon receipt of the appropriate engineered safety features actuation test signal required by Specification 3/4.3.2.
 - g. Verifying at least once per 18 months during shutdown that the unit cross-tie valves can cycle full travel. Following cycling, the valves will be verified to be in their closed positions.

SURVEILLANCE REQUIREMENTS

- 4.7.1.2 Each auxiliary feedwater pump shall be demonstrated OPERABLE when tested pursuant to Specification 4.0.5 by:
- a. Verifying that each motor driven auxiliary feed pump's developed head at the test flow point is greater than or equal to the required developed head.
 - b. Verifying that the turbine driven auxiliary feedwater pump's developed head at the test flow point is greater than or equal to the required developed head. The provisions of Specification 4.0.4 are not applicable for entry into MODE 3.
 - c. Verifying that each non-automatic valve in the flow path that is not locked, sealed, or otherwise secured in position is in its correct position.
 - d. Verifying that each automatic valve in the flow path is in the fully open position whenever the auxiliary feedwater system is placed in automatic control or when above 10% RATED THERMAL POWER. This requirement is not applicable for those portions of the auxiliary feedwater system being used intermittently to maintain steam generator level.
 - e. Verifying at least once per 18 months during shutdown that each automatic valve in the flow path actuates to its correct position upon receipt of the appropriate engineered safety features actuation test signal required by Specification 3/4.3.2.
 - f. Verifying at least once per 18 months during shutdown that each auxiliary feedwater pump starts as designed automatically upon receipt of the appropriate engineered safety features actuation test signal required by Specification 3/4.3.2.
 - g. Verifying at least once per 18 months during shutdown that the unit cross-tie valves can cycle full travel. Following cycling, the valves will be verified to be in their closed positions.

