

ATTACHMENT 2 TO AEP:NRC:1284

CURRENT TECHNICAL SPECIFICATIONS  
MARKED UP TO REFLECT PROPOSED CHANGES

9810140060 981008  
PDR ADDCK 05000315  
P PDR

## INSTRUMENTATION

### POST-ACCIDENT INSTRUMENTATION

#### LIMITING CONDITION FOR OPERATION

3.3.3.8 The post-accident monitoring instrumentation channels shown in Table 3.3-11 shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

#### ACTION:

(except item 8)

- a. With the number of OPERABLE post-accident monitoring channels less than required by Table 3.3-11, either restore the inoperable channel to OPERABLE status within 30 days, or be in HOT SHUTDOWN within the next 12 hours.

b.

b.c. The provisions of Specification 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

4.3.3.8 Each post-accident monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK and CHANNEL CALIBRATION operations at the frequencies shown in Table 4.3-7.

- b. With the number of OPERABLE post-accident monitoring channels one less than required by Table 3.3-11, item 8, Refueling Water Storage Tank Water Level:

1. Either restore the inoperable channel to OPERABLE status within 72 hours or be in at least HOT SHUTDOWN within the next 12 hours, and
2. Within one hour, bypass the Residual Heat Removal Pump trip function from the Refueling Water Storage Tank Water Level for the pump associated with the out-of-service instrument.



3/4 BASES  
3/4.3 INSTRUMENTATION

---

3/4.3.3.5 REMOTE SHUTDOWN INSTRUMENTATION

The OPERABILITY of the remote shutdown instrumentation ensures that sufficient capability is available to permit shutdown and maintenance of HOT STANDBY of the facility from locations outside of the control room. This capability is required in the event control room habitability is lost and is consistent with General Design Criteria 19 of 10 CFR 50.

3/4.3.3.5.1 APPENDIX R REMOTE SHUTDOWN INSTRUMENTATION

The OPERABILITY of the Appendix R remote shutdown instrumentation ensures that sufficient instrumentation is available to permit shutdown of the facility to COLD SHUTDOWN conditions at the local shutdown indication (LSI) panel. In the event of a fire, normal power to the LSI panels may be lost. As a result, capability to repair the LSI panels from Unit 2 has been provided. If the alternate power supply is not available, fire watches will be established in those fire areas where loss of normal power to the LSI panels could occur in the event of fire. This will consist of either establishing continuous fire watches or verifying OPERABILITY of fire detectors per Specification 4.3.3.7 and establishing hourly fire watches. The details of how these fire watches are to be implemented are included in a plant procedure.

3/4.3.3.8 POST-ACCIDENT INSTRUMENTATION

The OPERABILITY of the post-accident instrumentation ensures that sufficient information is available on selected plant parameters to monitor and assess these variables during and following an accident. The allowable out-of-service time for the Refueling Water Storage Tank (RWST) level channels is required to provide the overall reliability to support the manual transfer from injection to recirculation following an accident. The bypassing of the Residual Heat Removal (RHR) pump trip from the RWST low level, with a level channel out-of-service, ensures that the RHR pump will be available to meet its Engineered Safety Features (ESF) function of injecting water into the core. The loss of the RHR pump protection will be mitigated by the operator's action to switch from injection to recirculation using the approved Emergency Operating Procedure which causes the RHR pump suction to be realigned well before the RHR pump trip setpoint. The associated RHR Pump can be considered OPERABLE with the RWST level channel out-of-service once the trip function has been bypassed since the pump would be available to fulfill its ESF function.

## INSTRUMENTATION

### POST-ACCIDENT INSTRUMENTATION

#### LIMITING CONDITION FOR OPERATION

3.3.3.6 The post-accident monitoring instrumentation channels shown in Table 3.3-10 shall be OPERABLE.

APPLICABILITY: MODES 1, 2 and 3.

#### ACTION:

- (except item 8)
- a. With the number of OPERABLE post-accident monitoring channels less than required by Table 3.3-10, either restore the inoperable channel to OPERABLE status within 30 days, or be in HOT SHUTDOWN within the next 12 hours.
  - b. ☒ c. The provisions of Specification 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

4.3.3.6 Each post-accident monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK and CHANNEL CALIBRATION operations at the frequencies shown in Table 4.3-10.

- b. With the number of OPERABLE post-accident monitoring channels one less than required by Table 3.3-11, item 8, Refueling Water Storage Tank Water Level:
  1. Either restore the inoperable channel to OPERABLE status within 72 hours or be in at least HOT SHUTDOWN within the next 12 hours, and
  2. Within one hour, bypass the Residual Heat Removal Pump trip function from the Refueling Water Storage Tank Water Level for the pump associated with the out-of-service instrument.

### 3/4 BASES

#### 3/4.3 INSTRUMENTATION

---

##### 3/4.3.3.6 POST-ACCIDENT INSTRUMENTATION

The OPERABILITY of the post-accident instrumentation ensures that sufficient information is available on selected plant parameters to monitor and assess these variables during and following an accident.

##### 3/4.3.3.7 Deleted.

##### 3/4.3.3.9 EXPLOSIVE GAS MONITORING INSTRUMENTATION

This instrumentation includes provisions for monitoring the concentrations of potentially explosive gas mixtures in the Waste Gas Holdup System. The OPERABILITY and use of this instrumentation is consistent with the requirements of General Design Criteria specified in Section 11.3 of the Final Safety Analysis Report for the Donald C. Cook Nuclear Plant.

The allowable out-of-service time for the Refueling Water Storage Tank (RWST) level channels is required to provide the overall reliability to support the manual transfer from injection to recirculation following an accident. The bypassing of the Residual Heat Removal (RHR) pump trip from the RWST low level, with a level channel out-of-service, ensures that the RHR pump will be available to meet its Engineered Safety Features (ESF) function of injecting water into the core. The loss of the RHR pump protection will be mitigated by the operator's action to switch from injection to recirculation using the approved Emergency Operating Procedures which causes the RHR pump suction to be realized well before the RHR pump trip setpoint. The associated RHR pump can be considered OPERABLE with the RWST level out-of-service once the trip function has been by-passed since the pump would be available to fulfill its ESF function.

ATTACHMENT 3 TO AEP:NRC:1284

PROPOSED REVISED TECHNICAL SPECIFICATION PAGES

3/4 LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS  
3/4.3 INSTRUMENTATION

---

POST-ACCIDENT INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.3.3.8 The post-accident monitoring instrumentation channels shown in Table 3.3-11 shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

- a. With the number of OPERABLE post-accident monitoring channels less than required by Table 3.3-11 (except item 8), either restore the inoperable channel to OPERABLE status within 30 days, or be in HOT SHUTDOWN within the next 12 hours.
- b. With the number of OPERABLE post-accident monitoring channels one less than required by Table 3.3-11, item 8, Refueling Water Storage Tank Water Level:
  1. Either restore the inoperable channel to OPERABLE status within 72 hours or be in at least HOT SHUTDOWN within the next 12 hours, and
  2. Within one hour, by-pass the Residual Heat Removal Pump trip function from the Refueling Water Storage Tank Water Level for the pump associated with the out-of-service instrument.
- c. The provisions of Specification 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.3.3.8 Each post-accident monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK and CHANNEL CALIBRATION operations at the frequencies shown in Table 4.3-7.



3/4 BASES  
3/4.3 INSTRUMENTATION

---

3/4.3.3.5 REMOTE SHUTDOWN INSTRUMENTATION

The OPERABILITY of the remote shutdown instrumentation ensures that sufficient capability is available to permit shutdown and maintenance of HOT STANDBY of the facility from locations outside of the control room. This capability is required in the event control room habitability is lost and is consistent with General Design Criteria 19 of 10 CFR 50.

3/4.3.3.5.1 APPENDIX R REMOTE SHUTDOWN INSTRUMENTATION

The OPERABILITY of the Appendix R remote shutdown instrumentation ensures that sufficient instrumentation is available to permit shutdown of the facility to COLD SHUTDOWN conditions at the local shutdown indication (LSI) panel. In the event of a fire, normal power to the LSI panels may be lost. As a result, capability to repair the LSI panels from Unit 2 has been provided. If the alternate power supply is not available, fire watches will be established in those fire areas where loss of normal power to the LSI panels could occur in the event of fire. This will consist of either establishing continuous fire watches or verifying OPERABILITY of fire detectors per Specification 4.3.3.7 and establishing hourly fire watches. The details of how these fire watches are to be implemented are included in a plant procedure.

3/4.3.3.8 POST-ACCIDENT INSTRUMENTATION

The OPERABILITY of the post-accident instrumentation ensures that sufficient information is available on selected plant parameters to monitor and assess these variables during and following an accident. The allowable out-of-service time for the Refueling Water Storage Tank (RWST) level channels is required to provide the overall reliability to support the manual transfer from injection to recirculation following an accident. The bypassing of the Residual Heat Removal (RHR) pump trip from the RWST low level, with a level channel out-of-service, ensures that RHR pump will be available to meet its Engineered Safety Features (ESF) Function of injecting water into the core. The loss of the RHR pump protection will be mitigated by the operator's action to switch from injection to recirculation using the approved Emergency Operating Procedure which causes the RHR pump suction to be realigned well before the RHR pump trip setpoint. The associated RHR pump can be considered OPERABLE with the RWST level channel out-of-service once the trip function has been by-passed since the pump would be available to fulfill its ESF function.

3/4 LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS  
3/4.3 INSTRUMENTATION

---

POST-ACCIDENT INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.3.3.6 The post-accident monitoring instrumentation channels shown in Table 3.3-10 shall be OPERABLE.

APPLICABILITY: MODES 1, 2 and 3.

ACTION:

- a. With the number of OPERABLE post-accident monitoring channels less than required by Table 3.3-10 (except item 8), either restore the inoperable channel to OPERABLE status within 30 days, or be in HOT SHUTDOWN within the next 12 hours.
- b. With the number of OPERABLE post-accident monitoring channels one less than required by Table 3.3-10, item 8, Refueling Water Storage Tank Water Level:
  1. Either restore the inoperable channel to OPERABLE status within 72 hours or be in at least HOT SHUTDOWN within the next 12 hours, and
  2. Within one hour, by-pass the Residual Heat Removal Pump trip function from the Refueling Water Storage Tank Water Level for the pump associated with the out-of-service instrument.
- c. The provisions of Specification 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.3.3.6 Each post-accident monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK and CHANNEL CALIBRATION operations at the frequencies shown in Table 4.3-10.

3/4 BASES  
3/4.3 INSTRUMENTATION

---

3/4.3.3.6 POST-ACCIDENT INSTRUMENTATION

The OPERABILITY of the post-accident instrumentation ensures that sufficient information is available on selected plant parameters to monitor and assess these variables during and following an accident. The allowable out-of-service time for the Refueling Water Storage Tank (RWST) level channels is required to provide the overall reliability to support the manual transfer from injection to recirculation following an accident. The bypassing of the Residual Heat Removal (RHR) pump trip from the RWST low level, with a level channel out-of-service, ensures that the RHR pump will be available to meet its Engineered Safety Features (ESF) Function of injecting water into the core. The loss of RHR pump protection will be mitigated by the operator's action to switch from injection to recirculation using the approved Emergency Operating Procedure which causes the RHR pump suction to be realigned well before the RHR pump trip setpoint. The associated RHR pump can be considered OPERABLE with the RWST level channel out-of-service once the trip function has been by-passed since the pump would be available to fulfill its ESF function.

3/4.3.3.7 Deleted.

3/4.3.3.9 EXPLOSIVE GAS MONITORING INSTRUMENTATION

This instrumentation includes provisions for monitoring the concentrations of potentially explosive gas mixtures in the Waste Gas Holdup System. The OPERABILITY and use of this instrumentation is consistent with the requirements of General Design Criteria specified in Section 11.3 of the Final Safety Analysis Report for the Donald C. Cook Nuclear Plant.

