

# CATEGORY 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9810190240 DOC.DATE: 98/09/30 NOTARIZED: NO DOCKET #  
FACIL:50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana M 05000315  
AUTH.NAME AUTHOR AFFILIATION  
MINOR,J.W. American Electric Power Co., Inc.  
CENTER,J.F. American Electric Power Co., Inc.  
COOPER,D.E. American Electric Power Co., Inc.  
RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Sept 1998 for DC Cook Nuclear  
Plant,Unit 1.With 981005 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 5  
TITLE: Monthly Operating Report (per Tech Specs)

### NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD3-3 PD	1 1	STANG,J	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	FILE CENTER 01	1 1
	OC/DBA/PAD	1 1	RGN3	1 1
EXTERNAL:	LITCO BRYCE,J H	1 1	NOAC	1 1
	NRC PDR	1 1		

### NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS  
OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL  
DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 9 ENCL 9

2  
A  
B  
C  
D  
E  
F  
G  
H  
I  
J  
K  
L  
M  
N  
O  
P  
Q  
R  
S  
T  
U  
V  
W  
X  
Y  
Z

American Electric Power  
Cook Nuclear Plant  
One Cook Place  
Bridgman, MI 49106  
616 465 5901



U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

October 5, 1998

Gentlemen,

Pursuant to the requirements of Donald C. Cook Nuclear Plant Unit 1  
Technical Specification 6.9.1.8, the attached Monthly Operating Report for  
the month of September 1998 is submitted.

Sincerely,

A handwritten signature, likely of D.E. Cooper, is written over a horizontal line.

D.E. Cooper  
Plant Manager

/jc

Attachment

c: NRC Region III  
INPO Records Center  
ANI Nuclear Engineering Department  
D.R. Hahn  
S. Hamming  
B. Lewis  
R.P. Powers  
J.R. Sampson  
B.L. Bartlett  
P.A. Barrett  
D.W. Paul  
D.L. Noble  
W.H. Schalk  
D.G. Turner  
G. John  
D.P. Lynch  
R.G. Pickard  
G.T. Gaffney

100000

11,  
Jery

9810170240 980930  
PDR ADDCK 05000315  
R PDR

# N.R.C. OPERATING DATA REPORT

DOCKET NO.	50 - 315
DATE	October 5, 1998
COMPLETED BY	JW Minor
TELEPHONE	616-465-5901

## OPERATING STATUS

1. Unit Name	D. C. Cook Unit 1
2. Reporting Period	Sep-98
3. Licensed Thermal Power (MWt)	3250
4. Name Plate Rating (Gross MWe)	1152
5. Design Electrical Rating (Net MWe)	1020
6. Maximum Dependable Capacity (GROSS MWe)	1056
7. Maximum Dependable Capacity (Net MWe)	1000

Notes:

8. If Changes Occur in Capacity Ratings (Items no. 3 through 7) Since Last Report Give Reasons:

9. Power Level To Which Restricted, If Any (Net Mwe):

10. Reasons For Restrictions, If Any:

	This Month	Year-to-Date	Cumulative
11. Hours in Reporting Period	720.0	6552.0	208176.0
12. No. of Hrs. Reactor Was Critical	0.0	0.0	151285.3
13. Reactor Reserve Shutdown Hours	0.0	0.0	463.0
14. Hours Generator on Line	0.0	0.0	148821.1
15. Unit Reserve Shutdown Hours	0.0	0.0	321.0
16. Gross Thermal Energy Gen. (MWH)	0.0	0.0	440194814.0
17. Gross Electrical Energy Gen. (MWH)	0.0	0.0	143013940.0
18. Net Electrical Energy Gen. (MWH)	0.0	0.0	137597640.0
19. Unit Service Factor	0.0	0.0	72.2
20. Unit Availability Factor	0.0	0.0	72.2
21. Unit Capacity Factor (MDC Net)	0.0	0.0	65.8
22. Unit Capacity Factor (DER Net)	0.0	0.0	64.2
23. Unit Forced Outage Rate	100.0	100.0	11.1

24. Shutdowns Scheduled over Next Six Months (Type, Date, and Duration):  
None

25. If Shut Down At End of Report Period, Estimated Date of Startup:  
To be Determined.

26. Units in Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY		
INITIAL ELECTRICITY		
COMMERCIAL OPERATION		



DOCKET NO.  
UNIT NAME  
DATE  
COMPLETED BY  
TELEPHONE

50 - 315  
D.C. Cook Unit 1  
October 5, 1998  
JW Minor  
616-465-5901

**AVERAGE DAILY POWER LEVEL (MWe-Net)**

**September 1998**

DAY	AVERAGE DAILY POWER LEVEL	DAY	AVERAGE DAILY POWER LEVEL
9/1/98	0	9/17/98	0
9/2/98	0	9/18/98	0
9/3/98	0	9/19/98	0
9/4/98	0	9/20/98	0
9/5/98	0	9/21/98	0
9/6/98	0	9/22/98	0
9/7/98	0	9/23/98	0
9/8/98	0	9/24/98	0
9/9/98	0	9/25/98	0
9/10/98	0	9/26/98	0
9/11/98	0	9/27/98	0
9/12/98	0	9/28/98	0
9/13/98	0	9/29/98	0
9/14/98	0	9/30/98	0
9/15/98	0		
9/16/98	0		

DOCKET NO.  
UNIT NAME  
DATE  
COMPLETED BY  
TELEPHONE  
PAGE

50 - 315  
D.C. Cook Unit 1  
October 5, 1998  
JF Center  
616-697-5098  
1 of 1

## MONTHLY OPERATING ACTIVITIES - September 1998

### HIGHLIGHTS

The unit entered this reporting period in Mode 5 at 0% RTP.

The unit exited this reporting period in Mode 5 at 0% RTP.

There were no challenges to the pressurizer safety valves or power operated relief valves.

Gross electrical generation for the month of September was 0 MWh.

### DETAILS

09/01/98

The Reactor was shutdown 09/08/97 to resolve design basis questions discovered during the NRC Architect and Engineering (AE) Inspection.

DOCKET NO. 50 - 315  
UNIT NAME D.C. Cook Unit 1  
DATE October 5, 1998  
COMPLETED BY JF Center  
TELEPHONE 616-697-5098  
PAGE 1 of 1

# UNIT SHUTDOWNS AND POWER REDUCTIONS - September 1998

NO.	DATE	TYPE <sup>1</sup>	DURATION HOURS	REASON <sup>2</sup>	METHOD OF SHUTTING DOWN REACTOR <sup>3</sup>	LICENSEE EVENT REPORT NO.	SYSTEM CODE <sup>4</sup>	COMPONENT CODE <sup>5</sup>	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
333	090897	F	720.0	F	2	97-010 97-011 97-012 97-013 97-014 97-016	N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A	The unit was shutdown to resolve design basis questions discovered during the NRC Architect and Engineering (AE) Inspection.

<b>1 TYPE:</b> F: Forced S: Scheduled	<b>2 REASON:</b> A: Equipment Failure (Explain) B: Maintenance or Test C: Refueling D: Regulatory Restriction E: Operator Training and License Examination F: Administrative G: Operational Error (Explain) H: Other (Explain)	<b>3 METHOD:</b> 1: Manual 2: Manual Scram 3: Automatic Scram 4: Other (Explain)	<b>4 SYSTEM:</b> Exhibit G - Instructions for preparation of data entry sheets for Licensee Event Report (LER) File (NUREG 0161)	<b>5 COMPONENT:</b> Exhibit I: Same Source
---	--	--	---	---



