

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

SUBJECT: Forwards LER 99-023-00, "Inadequate TS Surveillance Testing of Essential SWPESF Response Time." Commitments identified in LER are listed.

NOTES:

| RECIPIENT | | COPIES | | RECIPIENT | | COPIES | |
|----------------------------------|--|--------|------|------------------|--|--------|------|
| ID CODE/NAME | | LTTR | ENCL | ID CODE/NAME | | LTTR | ENCL |
| LPD3-1 | | 1 | 1 | STANG, J | | 1 | 1 |
| INTERNAL: FILE CENTER | | 1 | 1 | NRR/DIPM/IOLB | | 1 | 1 |
| NRR/DRTP/REXB | | 1 | 1 | NRR/DSSA/SPLB | | 1 | 1 |
| RES/DET/ERAB | | 1 | 1 | RES/DRAA/OERAB | | 1 | 1 |
| RGN3 FILE 01 | | 1 | 1 | | | | |
| EXTERNAL: L ST LOBBY WARD | | 1 | 1 | LMITCO MARSHALL | | 1 | 1 |
| NOAC POORE, W. | | 1 | 1 | NOAC QUEENER, DS | | 1 | 1 |
| NRC PDR | | 1 | 1 | NUDOCS FULL TXT | | 1 | 1 |

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LIST OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTRL DESK (DCD) ON EXTENSION 415-2083

As 4



October 7, 1999

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Operating License DPR-58
Docket No. 50-315

Document Control Manager:

In accordance with the criteria established by 10 CFR 50.73 entitled Licensee Event Report System, the following report is being submitted:

LER 315/99-023-00, "Inadequate Technical Specification Surveillance Testing of Essential Service Water Pump Engineered Safety Feature Response Time."

The following new commitments were identified in this LER:

- Surveillance tests will be revised and implemented to include the time to achieve prescribed pump discharge pressure/flow and/or discharge valve position as part of the overall ESF response time testing for the ESW system prior to restart of each respective unit.
- The ESW ESF response times in UFSAR Table 7.2-7 will be evaluated and revised, if necessary, prior to restart of each respective unit.

Sincerely,

M. W. Rencheck
Vice President - Nuclear Engineering

/lrp
Attachment

c: J. E. Dyer, Region III
R. P. Powers
P. A. Barrett
R. C. Godley
R. Whale
D. Hahn
Records Center, INPO
NRC Resident Inspector

130041

9910130187 991007
PDR ADDCK 05000315
S PDR

//
IE22