

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9910210161 DOC. DATE: ~~99/09/30~~ NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana M 05000315
 AUTH. NAME AUTHOR AFFILIATION
 MINOR, J.W. Indiana Michigan Power Co.
 RICHARDSON, S.A. Indiana Michigan Power Co.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept ~~for Sept~~ 1999 for DC Cook Nuclear Plant, Unit 1. With 991012 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
STANG, J	1 1		
INTERNAL: FILE CENTER 01	1 1	OC/DBA/PAD	1 1
RES/DRAA/OERAB	1 1	RGN3	1 1
EXTERNAL: LMITCO MARSHALL	1 1	NOAC	1 1
NRC PDR	1 1		

MICROFILMED

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 8 ENCL 8

MRL

" Indiana Michigan
Power Company
Cook Nuclear Plant
One Cook Place
Bridgman, MI 49106
616-465-6901



October 12, 1999

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Document Control Manager:

Pursuant to the requirements of Donald C. Cook Nuclear Plant Unit 1 Technical Specification 6.9.1.8, the attached Monthly Operating Report for September 1999 is submitted.

Sincerely,

R. C. Godley
Regulatory Affairs Director

RCG/mbd

Attachment

c: NRC Region III
NRC Project Manager – NRR
NRC Resident Inspector
ANI Nuclear Engineering Department
INPO Records Center

A. C. Bakken, III
G. T. Gaffney – Canton
D. R. Hahn – Department of Health
S. Hamming – Department of Labor
G. John
B. Lewis – McGraw-Hill Companies
D. H. Malin
T. P. Noonan
D. W. Paul – Lancaster
J. E. Pollock
R. P. Powers
Regulatory Licensing Manager
M. W. Rencheck
W. H. Schalk
D. G. Turner

IE2411

7910210161 790930
PDR ADDCK 05000315
R PDR



1

1. 1990年12月1日

• •

1. *Chlorophyll a* and *Chlorophyll b* were determined by the method of Arar and Collins (1971).

Journal of Management Inquiry 18(6) 709–724
© The Author(s) 2009
Reprints and permissions:
[sagepub.com/journalsPermissions.nav](http://www.sagepub.com/journalsPermissions.nav)

1. *Chlorophyll a* (Chl *a*)

•

1. *Phragmites australis* (Cav.) Trin. ex Steud.

N.R.C. OPERATING DATA REPORT

DOCKET NO.	50 - 315
DATE	October 4, 1999
COMPLETED BY	J. W. Minor
TELEPHONE	616-465-5901

OPERATING STATUS

1. Unit Name	D. C. Cook Unit 1
2. Reporting Period	Sept-99
3. Licensed Thermal Power (MWt)	3250
4. Name Plate Rating (Gross MWe)	1152
5. Design Electrical Rating (Net MWe)	1020
6. Maximum Dependable Capacity (GROSS MWe)	1056
7. Maximum Dependable Capacity (Net MWe)	1000

Notes:

8. If Changes Occur in Capacity Ratings (Items no. 3 through 7) Since Last Report Give Reasons: _____

9. Power Level to Which Restricted, If Any (Net MWe): _____

10. Reasons For Restrictions, If Any: _____

	This Month	Year-to-Date	Cumulative
11. Hours in Reporting Period	720.0	6552.0	216936.0
12. No. of Hrs. Reactor Was Critical	0.0	0.0	151285.3
13. Reactor Reserve Shutdown Hours	0.0	0.0	463.0
14. Hours Generator on Line	0.0	0.0	148821.1
15. Unit Reserve Shutdown Hours	0.0	0.0	321.0
16. Gross Thermal Energy Gen. (MWH)	0.0	0.0	440194814.0
17. Gross Electrical Energy Gen. (MWH)	0.0	0.0	143013940.0
18. Net Electrical Energy Gen. (MWH)	0.0	0.0	137597640.0
19. Unit Service Factor	0.0	0.0	69.2
20. Unit Availability Factor	0.0	0.0	69.2
21. Unit Capacity Factor (MDC Net)	0.0	0.0	63.1
22. Unit Capacity Factor (DER Net)	0.0	0.0	61.5
23. Unit Forced Outage Rate	100.0	100.0	15.6

24. Shutdowns Scheduled over Next Six Months (Type, Date, and Duration): _____
 None

25. If Shut Down At End of Report Period, Estimated Date of Startup: _____
 September 2000

26. Units in Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY		
INITIAL ELECTRICITY		
COMMERCIAL OPERATION		

DOCKET NO.
UNIT NAME
DATE
COMPLETED BY
TELEPHONE

50 - 315
D.C. Cook Unit 1
October 4, 1999
J. W. Minor
616-465-5901

AVERAGE DAILY POWER LEVEL (MWe-Net)

September 1999

DAY	AVERAGE DAILY POWER LEVEL	DAY	AVERAGE DAILY POWER LEVEL
9/1/99	0	9/17/99	0
9/2/99	0	9/18/99	0
9/3/99	0	9/19/99	0
9/4/99	0	9/20/99	0
9/5/99	0	9/21/99	0
9/6/99	0	9/22/99	0
9/7/99	0	9/23/99	0
9/8/99	0	9/24/99	0
9/9/99	0	9/25/99	0
9/10/99	0	9/26/99	0
9/11/99	0	9/27/99	0
9/12/99	0	9/28/99	0
9/13/99	0	9/29/99	0
9/14/99	0	9/30/99	0
9/15/99	0		
9/16/99	0		



10

Number of hauls	<i>P. setiferus</i> (%)	<i>P. setiferus</i> + <i>P. setiferus</i> + <i>P. setiferus</i> (%)	<i>P. setiferus</i> + <i>P. setiferus</i> + <i>P. setiferus</i> (%)
1	~10	~20	~70
2	~15	~25	~60
3	~20	~30	~50
4	~25	~35	~40
5	~30	~40	~30
6	~35	~45	~20
7	~40	~50	~10
8	~45	~55	~5
9	~50	~60	~2
10	~55	~65	~1

[illegible]

1. 2. 3.

1

[illegible]

6

4

4

•

1

11

1

DOCKET NO.	50 - 315
UNIT NAME	D.C. Cook Unit 1
DATE	October 1, 1999
COMPLETED BY	S. A. Richardson
TELEPHONE	616-465-5901
PAGE	1 of 1

UNIT SHUTDOWNS AND POWER REDUCTIONS - September 1999

NO.	DATE	TYPE ¹	DURATION HOURS	REASON ²	METHOD OF SHUTTING DOWN REACTOR ³	LICENSEE EVENT REPORT NO.	SYSTEM CODE ⁴	COMPONENT CODE ⁵	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
333	090897	F	720.0	F	2	97-010 97-011 97-012 97-013 97-014 97-016	N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A	The unit remained shutdown to resolve design basis questions discovered during the NRC Architect and Engineering (AE) Inspection.

1 TYPE:
F: Forced
S: Scheduled

2 REASON:
A: Equipment Failure (Explain)
B: Maintenance or Test
C: Refueling
D: Regulatory Restriction
E: Operator Training and License Examination
F: Administrative
G: Operational Error (Explain)
H: Other (Explain)

3 METHOD:
1: Manual
2: Manual Scram
3: Automatic Scram
4: Other (Explain)

4 SYSTEM:
Exhibit G - Instructions for preparation of data entry sheets for Licensee Event Report (LER) File (NUREG 0161)

5 COMPONENT:
Exhibit I: Same Source

