

A002

REGULATORY INFORMATION DISTRIBUTION SYSTEM

DOCKET NBR: 50-251 TURKEY PT 4
RECIPIENT: OREILLY, J.P.
ORIGINATOR: SCHOPPMAN, M.A.
COMPANY NAME: EL PWR & LIGHT
SUBJECT:

DOC DATE: 781027
ACCESSION NBR: 7811060157
COPIES RECEIVED:
LTR 1 ENCL 1
SIZE: 1+1

LER#78-013/03E-0 on 780929: condensate storage tank held less than 185,000
gallons for about 8 hours. Caused by leaks in condenser tubes, necessitating
increased steam generator blowdown flow. Demand exceeded output of treatment
plant.

DISTRIBUTION CODE: A002
DISTRIBUTION TITLE:
INCIDENT REPORTS

NOTARIZED _____

NAME	ENCL?
BR CHIEF	W/4 ENCL
<u>REG FILE</u>	W/ENCL
NRC PDR	W/ENCL
I & E	W/2 ENCL
MIPC	W/3 ENCL
I & C SYSTEMS BR	W/ENCL
NOVAK/CHECK	W/ENCL
EEB	W/ENCL
AD FOR ENG	W/ENCL
PLANT SYSTEMS BR	W/ENCL
HANAUER	W/ENCL
AD FOR PLANT SYSTEMS	W/ENCL
AD FOR SYS & PROJ	W/ENCL
REACTOR SAFETY BR	W/ENCL
ENGINEERING BR	W/ENCL
KREGER/J. COLLINS	W/ENCL
POWER SYS BR	W/ENCL
E. Jordan	W/ENCL
LPDR	W/ENCL
NSIC	W/ENCL
ACRS	W/16 ENCL

FOR ACTION

ORB#4 BC

TOTAL NUMBER OF COPIES REQUIRED:


LTR
ENCL

42
42

NOTES:

NOV 8 1978

404
ccp



FLORIDA POWER & LIGHT COMPANY

October 27, 1978

PRN-LI-78-308

Mr. James P. O'Reilly, Director, Region II
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303


Dear Mr. O'Reilly:

REPORTABLE OCCURRENCE 251-78-13
TURKEY POINT UNIT 4
DATE OF OCCURRENCE: September 29, 1978

TECHNICAL SPECIFICATION 3.8.1.c
CONDENSATE STORAGE TANK

The attached Licensee Event Report is being submitted
in accordance with Technical Specification 6.9.2 to pro-
vide 30-day notification of the subject occurrence.

Very truly yours,


A. D. Schmidt
Vice President
Power Resources

REGULATORY DOCKET FILE COPY

MAS/dep

Attachment

cc: Robert Lowenstein, Esquire
Director, Office of Inspection and Enforcement (30)
Director, Office of Management Information and
Program Control (3)

REGULATORY DOCKET FILE COPY

7811060157

PEOPLE...SERVING PEOPLE

Handwritten: A002
5/11

