

A002

## REGULATOR INFORMATION DISTRIBUTION SYSTEM

DOCKET NBR: 50-251 TURKEY PT 4  
 RECIPIENT: \_\_\_\_\_  
 ORIGINATOR: SCHMIDT, A.D.  
 COMPANY NAME: FLA PWR & LIGHT  
 SUBJECT: \_\_\_\_\_

DOC DATE: 781120  
 ACCESSION NBR: 7812040221  
 COPIES RECEIVED: \_\_\_\_\_  
 LTR 1 ENCL 1  
 SIZE: 1+3

LER#78-015/01T-0 on 781106: Boron Injection Tank (BIT) sample showed low Boron level.

Exact cause is unknown, but it is suspected the actual BIT concentration was proper  
 & the sample was diluted & invalid.

DISTRIBUTION CODE: A002  
 DISTRIBUTION TITLE:  
 INCIDENT REPORTS

NOTARIZED \_\_\_\_\_

NAME	ENCL?
BR CHIEF	W/4 ENCL
REG FILE	W/ENCL
NRC PDR	W/ENCL
I & E	W/2 ENCL
MIPC	W/3 ENCL
I & C SYSTEMS BR	W/ENCL
NOVAK/CHECK	W/ENCL
EEB	W/ENCL
AD FOR ENG	W/ENCL
PLANT SYSTEMS BR	W/ENCL
HANAUER	W/ENCL
AD FOR PLANT SYSTEMS	W/ENCL
AD FOR SYS & PROJ	W/ENCL
REACTOR SAFETY BR	W/ENCL
ENGINEERING BR	W/ENCL
KREGER/J. COLLINS	W/ENCL
POWER SYS BR	W/ENCL
E. Jordan	W/ENCL
LPDR	W/ENCL
NSIC	W/ENCL
ACRS	W/16 ENCL

## FOR ACTION

ORB#1 BC

TOTAL NUMBER OF COPIES REQUIRED:

LTR  
 ENCL

42  
 42

DEC 5 1978

NOTES:

A0/I -4

DEPT. OF THE ARMY  
WASHINGTON, D. C.



November 20, 1978

PRN-LI-78-339

Mr. James P. O'Reilly, Director, Region II  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

REPORTABLE OCCURRENCE 251-78-15  
TURKEY POINT UNIT 4  
DATE OF OCCURRENCE: NOVEMBER 6, 1978

TECHNICAL SPECIFICATION 3.4.1.a.2  
BORON INJECTION TANK

The attached Licensee Event Report is being submitted in accordance with Technical Specification 6.9.2 to provide prompt notification of the subject occurrence.

Very truly yours,

*E. D. Woody*  
A. D. Schmitt  
Vice President  
Power Resources

MAS/cpc.

Attachment

cc: Robert Lowenstein, Esquire  
Director, Office of Inspection and Enforcement (40)  
Director, Office of Management Information and  
Program Control (3)

REGULATORY DOCKET FILE COPY

7812040 221

*A002  
5/11*

REGULATORY DOCUMENT