

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

790 22000 23



January 17, 1979

PRN-LI-79-18

Mr. James P. O'Reilly, Director, Region II
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

REPORTABLE OCCURRENCE 250-78-17
TURKEY POINT UNIT 3
DATE OF OCCURRENCE: DECEMBER 18, 1978

TECHNICAL SPECIFICATION 6.9.2.b(4)
CVCS HOLDUP TANK

The attached Licensee Event Report is being submitted in accordance with Technical Specification 6.9.2 to provide 30-day notification of the subject occurrence.

Very truly yours,

J.R. Benzen
for A. D. Schmidt
Vice President
Power Resources

MAS/cpc

Attachment

cc: Director, Office of Inspection and Enforcement (30)
Director, Office of Management Information and Program Control (3)
Robert Lowenstein, Esquire
File 933.1TP

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

09		SYSTEM CODE P C		CAUSE CODE E		CAUSE SUBCODE B		COMPONENT CODE V E I S I S E L				COMP. SUBCODE X		VALVE SUBCODE Z	
7	8	9	10	11	12	12	13	13	14	15	16	17	18	19	20
17 LER/RO REPORT NUMBER		EVENT YEAR 7 8		SEQUENTIAL REPORT NO. 0 1 1 7		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0		ACTION TAKEN D		FUTURE ACTION X	
21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36
EFFECT ON PLANT Z		SHUTDOWN METHOD Z		HOURS 0 0 0 0		ATTACHMENT SUBMITTED Y		VPRO-4 FORM SUB. N		PRIME-MP. SUPP. E		COMPONENT MANUFACTURER N T 5 0		37	
37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1	5	E	1	0	1	0	NA	A	Operator Observation
1	5	Z	Z				NA		
1	7	0	0	0	Z		NA		
1	3	0	0	0			NA		
1	9	Z					NA		
2	0	N					NA		

NAME OF PREPARER M. A. Schoppman

PHONE: (305) 552-3802

REPORTABLE OCCURRENCE 250-78-17
LICENSEE EVENT REPORT
PAGE TWO

Additional Cause Description and Corrective Action

Corrective action will include repair of the defect and evaluation of cover pressure control and monitoring methods.

Tank Data: 13,000 ft³
15 psig internal pressure
200°F
0 psig external pressure

