



USNRC F...

19 AUG 30 A 9:13

August 27, 1979
L-79-237


Mr. James P. O'Reilly, Director, Region II
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

Re: RII:JPO
50-250, 50-251
IE Bulletin 79-17

The attached information is submitted in response to Items 1 and 5 of the subject Bulletin.

Very truly yours,



Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU/MAS/cph

Attachment

cc: Director, Division of Operating Reactors; Office of Inspection
and Enforcement (w/o drawings)
Robert Lowenstein; Esquire (w/o drawings)

7910090 109

ATTACHMENT

Re: RII:JPO
 50-250, 50-251
IE Bulletin 79-17

Item 5 of the subject Bulletin requires a written report to the Director of the Region II Office of Inspection and Enforcement addressing the results of Florida Power & Light Company's review of Item 1 of the Bulletin. The following information represents the result of our review of Item 1:

1. Units 3 and 4

Two sets of color coded drawings are enclosed. One set is for Unit 3 and one is for Unit 4. The drawing numbers are the same for both units. The safety related Type 304 stainless steel piping systems that contain stagnant oxygenated borated water are color coded in pink.

Drawings

FPL	5610-T-E-4510	Sheet 1
FPL	5610-T-E-4510	Sheet 2
FPL	5610-T-E-4515	
FPL	5610-T-E-4503	
FPL	5610-T-E-4518	
FPL	5610-T-E-4505	Sheet 1
FPL	5610-T-E-4505	Sheet 2

(a) Unit 3

The extent of the examination of these systems is marked in green adjacent to the appropriate components.

Examination of Class 1 components and systems (and their supports) were conducted to the ASME Code Section XI (1970 Edition through the Winter 1970 Addenda) during the Fall 1974, 1975, & 1976 and Winter 1977, & 1979 refueling outages.

The examinations were performed by Westinghouse (W) in 1974 and by Southwest Research Institute (SwRI) thereafter. The nondestructive examination procedures (for Class 1 components and systems) and the results of examinations are on file at the plant site. The procedures have been qualified by W and SwRI and contain acceptance criteria for each examination. There were no reportable examination findings.

Unit 4

The extent of the examination of these systems is marked in green adjacent to the appropriate components.

Examination of Class 1 components and systems (and their supports) was conducted to the ASME Code Section XI (1970 Edition through the Winter 1970 Addenda) during the Spring 1975 and the Spring 1976 refueling outages.

Examination of Class 1 and Class 2 components and systems (and their supports) was conducted to the Technical Specifications and the ASME Code Section XI (1974 Edition through the Summer 1975 Addenda) during the Summer 1978 and the Spring 1979 refueling outages.

The examinations were performed by Southwest Research Institute (SwRI). The nondestructive examination procedures (for Class 1 and Class 2 components and systems) and the results of examinations are on file at the plant site. The procedures have been qualified by SwRI and contain acceptance criteria for each examination. There were no reportable examination findings.

(b) Units 3 and 4Chemistry Parameters and Surveillance Schedule

RWST - Weekly

pH
Cl⁻ (ppm)
F⁻ (ppm)
Cond (μmhos)
B (ppm)

Accumulators - 2 times per month

Cl⁻ (ppm)
F⁻ (ppm)
B (ppm)

Boron Injection Tank - 2 times per month

B (ppm)

(recirculated 3 times per day for 15 min., 15 min., and 45 min.; one recirc period per shift)

Boric Acid Storage Tanks - Weekly

Cl⁻ (ppm)
- 3 times per week
B (ppm)

(also sampled after transfers from the Batching Tank)

(c) Units 3 and 4

Preservice examinations of Class 1 systems and components were conducted to the ASME Code Section XI (1970 Edition through the Winter 1970 Addenda).

Nondestructive examinations were performed on Class 1 components by Westinghouse. The acceptance criteria of these examinations are incorporated in the nondestructive examination procedures and are on file at the plant site.

(d) Units 3 and 4

Not applicable.