


Central File
USNRC REGION II
ATLANTA, GEORGIA

P.O. BOX 529100, MIAMI, FL 33152



79 OCT 1 A 9: 52

September 25, 1979
L-79-272


Mr. James P. O'Reilly, Director, Region II
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

Re: RII:JPO
50-250, 50-251, 50-335
IE Bulletin 79-19

We have reviewed the subject Bulletin and a response is attached.

Very truly yours,


Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU/MAS/cph

Attachment

cc: Office of Inspection and Enforcement, Division of Fuel Facility
and Materials Safety Inspection
Robert Lowenstein, Esquire
Harold Reis, Esquire

cep

7910280203

OFFICIAL COPY

No. 2

PEOPLE...SERVING PEOPLE

ATTACHMENT

Re: RII:JPO
50-250, 50-251, 50-335
IE Bulletin 79-19

1. A current set of DOT and NRC regulations is maintained at the St. Lucie Plant, the Turkey Point Plant, and the Florida Power & Light Company (FPL) General Office.
2. A current copy of the waste burial firm's requirements and license is maintained at the St. Lucie Plant, the Turkey Point Plant, and the FPL General Office.
3. The personnel responsible for the safe transfer, packaging and transport of low-level radioactive material include the Health Physics Supervisor or his designee at each nuclear plant site.
4. Management approved instructions and procedures for the transfer, packaging and transport of low-level radioactive material are used and are periodically reviewed and revised as necessary.
5. Training for handling radioactive materials will be completed by March 1, 1980 for personnel involved in the transfer, packaging and transport of radioactive material. Retraining will be conducted on a periodic basis not to exceed once every two years.
6. Training for maintaining low-level radioactive waste volume at a minimum will be completed by March 1, 1980 for personnel who operate the processes which generate waste. Retraining will be conducted on a periodic basis not to exceed once every two years.
7. A management-controlled audit function of all transfer, packaging and transport activities performed under FPL licenses will be established and implemented to assure that these activities are in compliance with regulatory requirements. This program will be implemented by December 31, 1979.
8. The activities described in Items 1 through 6 will be audited (within the required time frame) to verify that these items are addressed in plant procedures.

NOTE: In addition to the specific actions described above for Items 7 and 8, FPL has an established audit program to ensure that low-level radioactive waste is handled safely in accordance with approved plant procedures.

9. (1) This information is submitted semi-annually in accordance with Technical Specifications.
- (2) This information is submitted semi-annually in accordance with Technical Specifications.
- (3) St. Lucie does not solidify low-level liquid waste. Turkey Point uses cement for solidification.

