

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 F L T P S 3 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

CONT

01 L 6 0 5 0 0 0 2 5 0 7 0 9 1 9 7 9 3 1 0 1 9 7 9 9

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During power operation, the line starter of the E. fire pump was upgraded

03 to NFPA 20 requirements with a UL/FM approved unit. The pump remained

04 inoperable for 30 days. This is reportable pursuant to T.S. 3.14.2.b.1.

05 The E. pump was tested and returned to service. The redundant W. fire

06 pump was operable during this event.

07

08

09 A B 11 X 12 Z 13 P U M P X X 14 B 15 Z 16

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

17 7 9 0 2 7 0 3 L 0

21 22 23 24 25 26 27 28 29 30 31 32

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NRC-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

18 C 19 Z 20 Z 21 0 0 0 0 22 N 23 N 24 A 25 X 9 9 9 26

33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The duration of the inoperability was greater than anticipated due to

11 difficulties encountered in mounting the upgraded line starter and due

12 to the fact that cable from meteorological instrumentation is routed

13 through the line starter enclosure. Maintenance and modifications were

14 performed in accordance with approved procedures.

15 E 1 0 0 29 NA B 31 During preventative maintenance

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

16 Z 33 Z 34 NA NA 36

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

17 0 0 0 37 Z 38 NA

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

PERSONNEL INJURIES NUMBER DESCRIPTION

18 0 0 0 40 NA

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

19 Z 42 NA

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

PUBLICITY ISSUED DESCRIPTION

20 N 44 NA

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

NAME OF PREPARER M. A. Schoppman PHONE: (305) 552-3802

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

