

HENRO REIS  
ATLANTA, GA



OCT 29 AM 10:09

October 25, 1979  
L-79-302

*Central File*  
*50-250*  
*251*

Mr. James P. O'Reilly, Director, Region II  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

Re: RII:JPO  
50-250, 50-251  
IE Bulletin 79-17

The ASME Section XI visual examinations requested by Item 2(a) of the subject Bulletin have been completed with the exception of the discharge portion of the Containment Spray Pumps. The results have been satisfactory, and are available for detailed review at the plant site. The remaining visual examinations will be completed by October 31, 1979. We will advise you if any of the results are unsatisfactory.

We have learned, through informal contacts with the NRC and other utilities, that Bulletin 79-17 is being revised. Therefore, to permit the most efficient use of our resources, we plan to reschedule further work on the Bulletin after we have received and reviewed the revision.

Please contact me if you have any questions regarding our response to IE Bulletin 79-17.

Very truly yours,

Robert E. Uhrig  
Vice President  
Advanced Systems & Technology

REU/MAS/cph

cc: Harold Reis, Esquire  
Director, Division of Operating Reactors,  
Office of Inspection and Enforcement

7911160 072

Q

790782<sup>102</sup>  
OFFICIAL COPY  
cop

