



October 31, 1979
L-79-311

Central File
50-250
251

Mr. James P. O'Reilly, Director, Region II
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

Re: RII:JP0
50-250, 50-251
IE Bulletin 79-24

We have reviewed the subject Bulletin for applicability to Turkey Point Units 3 and 4, and have determined that the geographical location of the site obviates the need for special protection against prolonged sub-freezing temperatures. The climate at the site is subtropical with long warm summers and short mild winters. A review of FSAR Section 2.6 (Meteorology) indicates that, in the vicinity of the plant, the average daily minimum temperature during the winter months ranges from approximately 57°F to 60°F.

Please call if you have further questions regarding freeze protection at the Turkey Point site.

Very truly yours,

J. A. De Massey
ev

Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU/MAS/cph

cc: Harold Reis, Esquire

AOI
2

CCP

790790

7911230 011

Q