

## LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 FLTPS3 2 00-0000-00 3 41111 4 5

LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 32

CON'T 01 REPORT SOURCE L 6 050000 250 7 1031 79 3 113079 9

DOCKET NUMBER 58 59 EVENT DATE 74 75 REPORT DATE 30

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 A periodic surveillance of the control on valves, locks, and switches

03 disclosed that Circuit Breaker Nos. 30532 & 30631 (power supplies to

04 discharge motor operated valves from Accumulators A & B to the RCS cold

05 legs) were not locked. This is contrary to procedural requirements and

06 is reportable pursuant to TS 6.9.2.b.3. The breakers, although in proper

07 position, were cycled and locked.

08

09 SYSTEM CODE SF 11 CAUSE CODE A 12 CAUSE SUBCODE B 13 COMPONENT CODE ZZZZZ 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16

17 LER/RO REPORT NUMBER 79 EVENT YEAR 79 SEQUENTIAL REPORT NO. 032 OCCURRENCE CODE 03 REPORT TYPE L REVISION NO. 0

ACTION TAKEN X 18 FUTURE ACTION G 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0000 ATTACHMENT SUBMITTED N 23 NRC-4 FORM SUB. N 24 PRIME COMP. SUPPLIER Z 25 COMPONENT MANUFACTURER Z999

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 The breakers not being locked appears to have resulted from personnel error

11 in that either a procedural requirement was not verified or the locking

12 mechanism was not properly inspected. A revised procedure now requires

13 independent verification of ESF valve positions. Personnel involved

14 have been reinstructed regarding procedural requirements.

15 FACILITY STATUS E 28 % POWER 1000 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Quality Control Surveillance 32

15 ACTIVITY RELEASED Z 33 CONTENT Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

17 PERSONNEL EXPOSURES NUMBER 0000 37 TYPE Z 38 DESCRIPTION NA 39

17 PERSONNEL INJURIES NUMBER 0000 40 DESCRIPTION NA 41

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

20 PUBLICITY DESCRIPTION NA 45

ISSUED N 44 NRC USE ONLY

NAME OF PREPARER H. A. Schoppman PHONE: (305) 552-3802

7912180536

4-11-68

