



January 25, 1977
L-77-32

Director of Nuclear Reactor Regulation
Attention: Mr. Victor Stello, Director
Division of Operating Reactors
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Stello:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Proposed Amendment to Facility
Operating Licenses DPR-31 and DPR-41

In accordance with 10 CFR 50.30, Florida Power and Light Company submits herewith three (3) signed originals and forty (40) copies of a request to amend Appendix A of Facility Operating Licenses DPR-31 and DPR-41.

The proposed change is described below and shown on the accompanying Technical Specification page bearing the date of this letter in the lower right hand corner.

Table 4.1-1 (Sheet 1)

Item 1, Remark 1 is revised to read

"Load vs. flux curve, or ΔT vs. reactor power curve".

The proposed change has been reviewed by the Turkey Point Plant Nuclear Safety Committee and the Florida Power & Light Company Nuclear Review Board. They have concluded that it does not involve an unreviewed safety question. A safety evaluation is attached.

Very truly yours,

ROBERT E. UHRIG
Vice President

REU/MAS/cmp

Attachment

cc: Norman C. Moseley, Region II
Robert Lowenstein, Esquire

8003240538

