

**LICENSEE EVENT REPORT**

CONTROL BLOCK:										(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)									
F I L T P S I 4 2 0 0 - 0 0 0 0 0 - 0 0 0 4 1 1 1 1 4 5																			
LICENSSE CODE										LICENSE NUMBER									
CONC										CAT									
REPORT SOURCE										DOCKET NUMBER									
EVENT DESCRIPTION AND PROBABLE CONSEQUENCES										EVENT DATE									
During normal operation, process radiation monitors R-11 and R-12 were out of service for about 11 hours. Operation in this mode is allowed for 48 hours by Tech Spec 3.1.3.f provided two other redundant means of RCS leak detection (not sensitive to radiation) are available. The redundant RCS leak detection capability was available, so this event had no adverse affect on public health and safety. Similar occurrences were reported as LER 250-79-30, 251-79,2, 251-78-17, and 251-79-5.																			
SYSTEM CODE										CAUSE CODE									
B B 11										E 12									
COMPONENT CODE										VALVE SUBCODE									
B I O W E R 14										Z 15									
LER/RO REPORT NUMBER										REVISION NO.									
8 0 1										0									
ACTION TAKEN										FUTURE ACTION									
C Z 19										Z 20									
SHUTDOWN METHOD										HOURS									
Z 21										0 0 0 0 22									
ATTACHMENT SUBMITTED										NPRO-4 FORM SUB.									
N 23										N 24									
PRIME COMP. SUPPLIER										COMPONENT MANUFACTURER									
N 25										T 2 6 0 26									
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS																			
An air sampling blower which supplies monitors R-11 and R-12 failed due to normal wear. The blower was replaced and the monitors were returned to service.																			
FACILITY STATUS										METHOD OF DISCOVERY									
E 23										A 31 Operator Observation									
ACTIVITY CONTENT RELEASED OF RELEASE										DISCOVERY DESCRIPTION									
Z 33 Z 34										32									
PERSONNEL EXPOSURES										LOCATION OF RELEASE									
NUMBER TYPE DESCRIPTION										36									
0 0 0 37 Z 38										NA									
PERSONNEL INJURIES																			
NUMBER DESCRIPTION																			
0 0 0 40										NA									
LOSS OF OR DAMAGE TO FACILITY																			
TYPE DESCRIPTION																			
Z 42										NA									
PUBLICITY DESCRIPTION																			
N 44										NA									
NAME OF PREPARER										PHONE									
M. A. Schoppman										(305) 552-3802									

NAME OF PREPARER M. A. Schoppman

PHONE: (305) 552-3802

