



JUN 6 10:05

May 30, 1980
L-80-161*Central File*
50-250
251

Mr. James P. O'Reilly, Director, Region II
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

Re: RII: JPO
50-250, 50-251
IE Bulletin 79-25

The following information supplements our response of December 20, 1979 (1-79-356) to Item 3 of the subject bulletin.

3. The relays are tested monthly by licensed operations personnel as required by Technical Specification Table 4.1-1, Item 24. (Reference FSAR Section 8.5.) The procedures which implement the testing are OP 1004.2, Reactor Protection System - Periodic Test, and OP 4004.2, Safeguard, Relay Train A, B, and Emergency Load Sequencer Time - Periodic Test. Additionally, OP 4104.2 Engineered Safeguards and Emergency Power Systems - Integrated Test, is performed following each refueling shutdown to verify automatic operation of the system pursuant to the requirements of Technical Specifications Table 4.1-1 Item 8, Table 4.2-1 Item 8, and 4.8.1.b.

Relay failures, maintenance, and testing are documented. These reports are maintained in our General Equipment Modification System (GEMS) data base.

Please call if you have further questions on this subject.

Very truly yours,

Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU/MAS/pa

Attachment

OFFICIAL COPY

8006260129

Q

