


USNRC REGION II
ATLANTA, GEORGIA

23 AUG 12 A10:13



August 8, 1980
L-80-262

Mr. James P. O'Reilly, Director, Region II
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

Re: RII:JPO
50-250, 50-251
IE Bulletin 79-03A

Florida Power & Light Company has reviewed the subject Bulletin and our preliminary information indicates that the seam welded piping in safety-related systems will meet the Code allowable stress criteria. This information is being documented by our Architect-Engineer and is not complete at this time. We expect to complete our documentation and forward our completed answer to the Bulletin by October 1, 1980.

Very truly yours,

A handwritten signature in cursive script, appearing to read 'R. E. Uhrig', is written over the typed name.

Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU/PLP/ms

cc: Director, Office of Inspection and Enforcement
Harold Reis, Esquire

OFFICIAL COPY

8:009020 195

PEOPLE...SERVING PEOPLE



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA ST., N.W., SUITE 3100
ATLANTA, GEORGIA 30303

In Reply Refer To:

RII:JPO

50-335, 50-389

50-250, 50-251


AUG 7 1980

Florida Power and Light Company
ATTN: R. E. Uhrig, Vice President
Advanced Systems and Technology
P. O. Box 529100
Miami, FL 33152

Gentlemen:

This Information Notice is provided as an early notification of a possible significant matter. It is expected that recipients will review the information for possible applicability to their facilities. No specific action or response is requested at this time. If further NRC evaluations so indicate, an IE Circular or Bulletin will be issued to recommend or request specific licensee actions. If you have questions regarding this matter, please contact the Director of the appropriate NRC Regional Office.

Sincerely,


James P. O'Reilly
Director

Enclosures:

1. IE Information Notice
No. 80-29
2. List of Recently Issued
Information Notices

cc w/encl:

C. M. Wethy, Plant Manager
Nat Weems, Assistant QA Manager
H. E. Yaeger, Plant Manager

80080150 487

