

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8010010542 DOC. DATE: 80/07/22 NOTARIZED: NO DOCKET # 05000250
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH. NAME AUTHOR AFFILIATION
 UHRIG, R.E. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 EISENHUT, D. Division of Licensing

SUBJECT: Application to amend Licenses DPR-31 & DPR-41 changing Tech Specs re RHR sys testing frequency to 18 months.

DISTRIBUTION CODE: A0018 COPIES RECEIVED: LTR 1 ENCL 3 SIZE: 1+3
 TITLE: General Distribution for after Issuance of Operating Lic

NOTES:

ACTION:	RECIPIENT		COPIES		RECIPIENT	COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME	LTTR
ACTION:	VARGA, S.	04	13	13			
INTERNAL:	D/DIR, HUM	FAC08	1	1	I&E	06	2
	NRC PDR	02	1	1	OELD	11	1
	OR ASSESS BR	10	1	0	<u>REG FILE</u>	01	1
EXTERNAL:	ACRS	09	16	16	LPDR	03	1
	NSIC	05	1	1			

OCT 2 1980

TOTAL NUMBER OF COPIES REQUIRED: LTTR 39 ENCL 37

000000



July 22, 1980
L-80-230

Office of Nuclear Reactor Regulation
Attention: Mr. Darrell Eisenhut, Director
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Eisenhut:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Proposed Amendment to Facility
Operating Licenses DPR-31 and DPR-41

In accordance with 10 CFR 50.30, Florida Power & Light Company submits herewith three (3) signed originals and forty (40) copies of a request to amend Appendix A of Facility Operating Licenses DPR-31 and DPR-41.

This proposal addresses testing of the RHR system "at least once per 18 months" instead of "annually" as presently required.

The proposed amendment is shown on the accompanying Technical Specification page bearing the date of this letter in the lower right hand corner.

The proposed amendment has been reviewed by the Turkey Point Plant Nuclear Safety Committee and the Florida Power & Light Company Nuclear Review Board. They have concluded that it does not involve an unreviewed safety question.

Very truly yours,

Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU/MAS/paf

Attachment

cc: J. P. O'Reilly, Region II
Harold Reis, Esquire

A001
S
1/1

8010010 542

P

