

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8010150263 DOC.DATE: 80/10/07 NOTARIZED: NO  
 FACIL:50-250 Turkey Point Plant, Unit 3, Florida Power and Light C  
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C  
 AUTH.NAME AUTHOR AFFILIATION  
 UHRIG,R.E. Florida Power & Light Co.  
 RECIP.NAME RECIPIENT AFFILIATION  
 EISENHUT,D.G. Division of Licensing

DOCKET #  
 05000250  
 05000251

SUBJECT: Submits info re 800507 commitment to design reactor coolant pressure oil collection sys to prevent loss of operability of safety-related equipment during SSE.Sys attachments will protect safety-related equipment.

DISTRIBUTION CODE: A006S COPIES RECEIVED:LTR 3 ENCL 0 SIZE: 1  
 TITLE: Fire Protection Information (After Issuance of OP. Lic.)


## NOTES:

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
ACTION:	VARGA,S.	04	3				
INTERNAL:	CHEM ENG BR-A	7	5		I&E	06	2
	NRC RDR	02	1		OELD		1
	REG FILE	01	1		WAMBACH,T.	10	1
EXTERNAL:	ACRS	09	16	1	LPDR	03	1
	NSIC	05	1				

OCT 16 1980

TOTAL NUMBER OF COPIES REQUIRED: LTTR 32 ENCL 0





October 7, 1980  
L-80-336

Office of Nuclear Reactor Regulation  
Attention: Mr. Darrel G. Eisenhut, Director  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dear Mr. Eisenhut:

Re: Turkey Point Units 3 & 4  
Docket Nos. 50-250 and 50-251  
Fire Protection (SER item 3.2.2)

In a letter (L-80-140) dated May 7, 1980, Florida Power & Light committed to designing the Turkey Point RCP oil collection system to prevent loss of operability of safety related equipment during a SSE. To meet this commitment we have verified that the oil collection system attachments will prevent the oil collection enclosures from falling and damaging safety related equipment. It is our judgment based on an engineering review, that these enclosures will also remain functional during an SSE. We have conducted analyses to show that the oil reservoir and oil drain piping will withstand a SSE. We feel that these measures satisfy our commitment on the oil collection system.

Very truly yours,

A handwritten signature in dark ink, appearing to read "Robert E. Uhrig", is written over the typed name.

Robert E. Uhrig  
Vice President  
Advanced Systems & Technology

REU/PLP/ras

cc: J. P. O'Reilly, Region II  
Harold F. Reis, Equire

*Handwritten:* Aook  
5/10

8010150263

*Handwritten:* F

