

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8010200454 DOC. DATE: 80/10/05 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 AUTH. NAME AUTHOR AFFILIATION
 UHRIG, R.E. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 EISENHUT, D.G. Division of Licensing

SUBJECT: Forwards info re inservice insp program in response to NRC
 800414 ltr.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 3 ENCL 3 SIZE: 2
 TITLE: General Distribution for after Issuance of Operating License


NOTES:

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
ACTION:	VARGA, S. 04		13 13				
INTERNAL:	D/DIR, HUM FAC08		1 1		I&E 06		2 2
	NRC PDR 02		1 1		OELD 11		1 0
	OR ASSESS BR 10		1 0		<u>RZG FILE</u> 01		1 1
EXTERNAL:	ACRS 09		16 16		LPDR 03		1 1
	NSIC 05		1 1				

OCT 21 1980

[Handwritten signature]

TOTAL NUMBER OF COPIES REQUIRED: LTTR 38 ENCL 36



October 15, 1980
L-80-341

Office of Nuclear Regulation
Attention: Mr. Darrell G. Eisenhut, Director
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Eisenhut:

Re: Turkey Point Unit 3
Docket No. 50-250
Inservice Inspection

The Inservice Inspection Program information requested in an NRC letter dated April 14, 1980 is attached.

Very truly yours,

for *E. F. Adamat*
Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU/PLP/pah

cc: Mr. J. P. O'Reilly, Region II
Harold F. Reis, Esquire

*Acc
5/3*

P 8010200 454

ATTACHMENT

Re: Turkey Point Unit 3
Docket No. 50-250
Inservice Inspection

1. Our request in Section 6.2.1.2 of the Turkey Point Unit 3 ISI Program to use Appendix III for the inspection of ferritic piping systems will be modified to include the staff guidelines provided in your request for additional information.
2. The examinations proposed for repairs outlined in Section 8.2.1 and 8.2.2 will include the examination method that detected the flaw requiring repair. Pressure tests in accordance with IWA-5000 will be included for repair examination except in those circumstances where it is determined to be impractical in accordance with Section 50.55a (g)(5)(IV) of 10 CFR 50.
3. We foresee no conflicts between the pressure and temperature requirements of IWB-5000 and the Turkey Point Technical Specifications. If a conflict should arise in the future, Technical Specification changes or code relief will be requested.
4. Paragraph IWB-1220(b)(1) was not used as a criterion for exempting lines based on pipe size in this submittal of the Turkey Point Unit No. 3 ISI Program.
5. Paragraph IWC-1220(c) was not used as a criterion for exempting components based on control of the chemistry of the contained fluid by periodic sampling and test in this submittal of the Turkey Point Unit No. 3 ISI Program.

Paragraph IWC-1220(b) was not used as a criterion for exempting ECCS components based on nonoperation during normal reactor operation in the submittal of the Turkey Point Unit No. 3 ISI Program.

