

## LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 F L T P S 3 2 0 0 1 0 0 0 0 1 0 0 3 4 1 1 1 1 4 1 3

LICENSEE CODE 14 LICENSE NUMBER 25 LICENSE TYPE 30 37-CAF 38

CON'T 01 REPORT SOURCE L 5 0 5 0 0 0 2 5 0 7 0 9 1 8 8 0 3 1 0 2 0 8 0 3

50 61 COCKET NUMBER 68 73 EVENT DATE 74 75 REPORT DATE 30

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 During power operation, the reactor power as indicated by the Power

03 Range Nuclear Instrumentation System (NIS) on Channel N-43 was

04 determined to be low. The channel was placed in the "tripped" condition,

05 which also puts Reactor Protection Set III overpower delta-T, over-

06 temperature delta-T, and the NIS high flux signal in a trip condition.

07 No safety limits were exceeded. This is reportable pursuant to TS

08 6.9.2.b.

09 SYSTEM CODE I F 11 CAUSE CODE E 12 CAUSE SUBCODE A 13 COMPONENT CODE E L E C O N 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16

17 LER/RO REPORT NUMBER 8 0 21 22 SEQUENTIAL REPORT NO. 0 1 7 24 25 OCCURRENCE CODE 0 3 29 30 REPORT TYPE L 31 REVISION NO. 0 32

ACTION TAKEN X 33 FUTURE ACTION A 34 EFFECT ON PLANT Z 35 SHUTDOWN METHOD Z 36 HOURS 0 0 0 37 ATTACHMENT SUBMITTED N 41 NPRO-4 FORM 503 Y 42 PRIME COMP. SUPPLIER A 43 COMPONENT MANUFACTURER A 3 8 0 44

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 The root cause of the problem was determined to be a partial ground

11 on the cable associated with channel N-43. The unit is currently in

12 cold shutdown and the cable will be replaced prior to return to power.

13 The cables on the other NIS channels were examined and found to be in

14 acceptable condition.

15 FACILITY STATUS E 23 % POWER 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operator observation 32

16 ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

17 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39

18 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

20 PUBLICITY ISSUED N 44 DESCRIPTION NA 45

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

NRC USE ONLY

NAME OF PREPARER P.L. PacePHONE: (305) 552-3801

8010810 398

