

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8011140134 DOC. DATE: 80/11/10 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light Co. 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light Co. 05000251
 AUTH. NAME AUTHOR AFFILIATION
 UHRIG, R.E. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 VARGA, S.A. Operating Reactors Branch 2

SUBJECT: Informs that Emergency Operating Procedure 20,000, immediate actions & diagnostics, has been revised to clarify compliance w/fourth paragraph of Section 2.1.4 to TMI Lessons Learned Category A Items.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: General Distribution for after Issuance of Operating License

NOTES:

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
ACTION:	VARGA, S.	04	13	13			
INTERNAL:	D/DIR, HUM FAC08		1	1	I&E	06	2
	NRC PDR	02	1	1	FIELD	11	1
	OR ASSESS BR 10		1	0	REG FILE	01	1
EXTERNAL:	ACRS	09	16	16	LPDR	03	1
	NSIC	05	1	1			

NOV 17 1980

NOV 17 1980

TOTAL NUMBER OF COPIES REQUIRED: LTR 38 ENCL 36

54

ADVANCED DISTRIBUTION
SERVICES UNIT

1200 NOV 13 AM 8 58

US NRC
DISTRIBUTION SERVICES
BRANCH



November 10, 1980
L-80-378

Office of Nuclear Reactor Regulation
Attention: Mr. S.A. Varga, Chief
Operating Reactors Branch #1
Division of Operating Reactors
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555


Dear Mr. Varga:

Re: Turkey Point Units 3 & 4
Docket Nos. 50-250 & 50-251
TMI Lessons Learned

An April 7, 1980 letter from Mr. A. Schwencer forwarded the NRC Staff's evaluation of the actions we have taken to satisfy the TMI Lessons Learned Category "A" items. The fourth paragraph of section 2.1.4 (Containment Isolation) states that "those penetrations with normally closed manual isolation valves will be locked closed and administratively controlled such that at any time they are open during plant operation, a dedicated person will be assigned to close it immediately in the event of an emergency or when the operation is complete."

We would like to clarify our compliance with the intent of this position by advising you that we have revised Emergency Operating Procedure 20,000 (Immediate Actions and Diagnostics) to require that the Nuclear Control Center Operator close the appropriate valves under specified accident conditions.

Very truly yours,


Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU/MAS/md

cc: J.P. O'Reilly, Region II
Harold F. Reis, Esquire
W. Marsh, Resident Inspector

A001
S
1/0

8011140

134

