

LICENSEE EVENT REPORT

CONTROL BLOCK:                      (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 FLTP S3 2 00 -0 10 00 00 00 -0 00 3 4 1 1 1 1 3 1 3

CON'T 01 REPORT SOURCE L 6 05 10 10 02 5 0 7 1 10 8 8 0 3 1 2 08 8 0 2

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 Contrary to TS 4.1 (Table 4.1-1, Item 15), the surveillance Check of the  
03 Refueling Water Storage Tank level was not completed within the required  
04 time interval. The cause of the occurrence was personnel error resulting  
05 in missing an entry on the surveillance check list. This resulted in  
06 exceeding the TS interval (of 7 days +/- 25 %) by 1 day. During the above  
07 interval, redundant level indication was available in the Control Room and  
08 the tank level was well within specification throughout the interval.

09 SYSTEM CODE S F 11 CAUSE CODE A 12 CAUSE SUBCODE A 13 COMPONENT CODE Z Z Z Z Z Z 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16

17 LSR/RO REPORT NUMBER 8 2 3 EVENT YEAR 8 0 SEQUENTIAL REPORT NO. 0 2 3 OCCURRENCE CODE 0 3 REPORT TYPE L REVISION NO. 0

ACTION TAKEN X 18 FUTURE ACTION H 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 ATTACHMENT SUBMITTED N 23 APPROX. FORM 305 N 24 PRIME COMP. SUPPLIER Z 25 COMPONENT MANUFACTURER Z 9 9 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The surveillance was successfully completed on November 11, 1980. The  
11 personnel involved have been reinstructed on strict compliance to  
12 procedures.

13

14 FACILITY STATUS E 28 % POWER 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Quality Control surveillance 32

15 ACTIVITY CONTENT RELEASED OR RELEASE Z 33 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

16 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39

17 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41

18 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

19 PUBLICITY ISSUED DESCRIPTION N 44 NA 45

20 N 44 NA 45

NAME OF PREPARER P.L. Pace

PHONE: (305) 552-3801

8101050363