

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 FLTPS3 2 00 - 00 00 00 - 00 0 4 11 11 11 4 3

LICENSE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 32

CONT. 01 REPORT SOURCE 0 5 0 5 0 0 0 2 5 0 7 0 1 1 0 1 8 1 8 0 1 1 2 9 8 1 9

60 61 OCKET NUMBER 62 63 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 While performing the surveillance on B Emergency Diesel Generator (EDG) to
03 implement TS 4.8.1.a, a loss of voltage control was experienced. The EDG
04 was manually shutdown. An investigation revealed that two fuses
05 associated with the 120 VAC supply and voltage regulator transformer had
06 failed open. The fuses were replaced, and the EDG tested and returned to
07 service within 12 hours. The redundant A EDG was available to supply ESF
08 equipment as discussed in FSAR Section 8.

09 SYSTEM CODE E 11 CAUSE CODE E 12 CAUSE SUBCODE A 13 COMPONENT CODE ENGINE 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16

17 LER/RO REPORT NUMBER 8 1 EVENT YEAR 8 1 SEQUENTIAL REPORT NO. 0 0 1 OCCURRENCE CODE 0 3 REPORT TYPE L REVISION NO. 0

ACTION TAKEN A 18 FUTURE ACTION G 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 ATTACHMENT SUBMITTED N 23 NPRO-4 FORM SUB. N 24 PRIME COMP. SUPPLIER A 25 COMPONENT MANUFACTURER S 0 6 6 25

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 The cause of the fuse failure could not be determined, however, the
11 contact bands were found to be loose on the fuse body. The 2-six ampere
12 fuses were replaced. The annual surveillance associated with TS 4.8.1.c
13 will be expanded to include checking fuses associated with the EDGs.
14

15 FACILITY STATUS E 28 % POWER 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 Operator Discovery Description 32

16 ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

17 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39

18 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

20 PUBLICITY ISSUED N 44 DESCRIPTION NA 45

NRC USE ONLY

NAME OF PREPARER P.L. Pace PHONE: (305) 552-3801

8102080 421

