

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 FILITPIS 3 2 0 0 1 - 0 0 0 0 0 1 - 0 0 3 4 1 1 1 1 1 4 5
7 3 9 LICENSE CODE 14 15 LICENSE NUMBER 23 28 LICENSE TYPE 30 37 CAT 33

CON'T
01 L 6 0 5 0 0 0 1 2 5 0 7 0 1 1 2 0 8 1 3 0 2 1 1 9 8 1 9
7 3 80 81 COCKET NUMBER 83 89 EVENT DATE 74 75 REPORT DATE 30

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10
02 During Power operations, the "A" Auxiliary Feedwater (AFW) pump failed to
03 meet the acceptance criteria of the surveillance of TS 4.10.1. The "B"
04 and "C" AFW pumps were operable. The problem was corrected and the pump
05 was tested and returned to service within 19 hours. Operations continued
06 pursuant to TS 3.8.3. The most recent occurrences relating to the AFW
07 system were reported as LER 250-80-18 and LER 251-80-6.
08 _____
7 3 9

09 H H 11 E 12 B 13 V A L I V E I X 14 E 15 H 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20

17 LER/RO REPORT NUMBER 8 1 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47
ACTION: FUTURE TAKEN: ACTION: EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-L FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27
10 The acceptance criteria was not met because the valve plug in CV-3705 ("A"
11 AFW steam turbine Pressure Control Valve) was damaged. The root cause of
12 the damage could not be determined. The stem and plug were replaced.
13 _____
14 _____
7 3 9

15 E 23 1 1 0 1 0 29 NA 30 A 31 Operator Observation 32
7 3 9 FACILITY STATUS 10 12 13 OTHER STATUS 30 METHOD OF DISCOVERY 44 45 DISCOVERY DESCRIPTION 32

16 Z 33 Z 34 NA 35 NA 36
7 3 9 ACTIVITY CONTENT 10 11 12 13 AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36

17 0 0 0 37 Z 38 NA 39
7 3 9 PERSONNEL EXPOSURES 10 11 12 13 DESCRIPTION 39

18 0 0 0 40 NA 41
7 3 9 PERSONNEL INJURIES 10 11 12 13 DESCRIPTION 41

19 Z 42 NA 43
7 3 9 LOSS OF OR DAMAGE TO FACILITY TYPE 43 DESCRIPTION 43

20 N 44 NA 45
7 3 9 PUBLICITY ISSUED DESCRIPTION 45

NAME OF PREPARER P. L. Pace PHONE: (305) 552-3801

