

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8103190700 DOC. DATE: 81/03/10 NOTARIZED: NO DOCKET #  
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250  
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251  
 AUTH. NAME: KOLB, W.O. AUTHOR AFFILIATION: Florida, State of  
 RECIP. NAME: VARGA, S.A. RECIPIENT AFFILIATION: Operating Reactors Branch 1

SUBJECT: Forwards review comments from Dept of Environ Regulation on DES re steam generator repair at facilities. During preparation of FES for project, comments should be considered & responded to accordingly.

DISTRIBUTION CODE: C002S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3  
 TITLE: Environ. Comments.

## NOTES:

ACTION:	RECIPIENT ID CODE/NAME		COPIES		RECIPIENT ID CODE/NAME		COPIES	
			LTTR	ENCL			LTTR	ENCL
	VARGA, S.	17	7	7	GROTHENHUIS, M	05	1	1
INTERNAL:	ACCIDENT EVAL BR		1	1	EF TREAT SYS BR		1	1
	ENV ENG BR	09	1	1	HYD/GEO BR		1	1
	HYDRO-GEO BR		1	1	I&E	07	2	2
	NRC PDR	02	1	1	DELD		1	0
	RAD ASSESSMT BR		1	1	REG FILE	01	1	1
	SIT ANAL BR	10	1	1	UTIL FINANCE BR		1	1
EXTERNAL:	ACRS		1	0	LPDR	03	1	1
	NATL LAB	20	5	5	NSIC	04	1	1

MAR 20 1981





BOB GRAHAM  
GOVERNOR


STATE OF FLORIDA

# Office of the Governor

THE CAPITOL  
TALLAHASSEE 32301

March 10, 1981

Steven A. Varga, Chief  
Operating Reactors Branch #1  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555



Dear Mr. Varga:

This Office, as required by the Office of Management and Budget Circular A-95 and Council of Environmental Quality guidelines, and functioning as the State planning and development clearinghouse, has reviewed and coordinated a review of your agency's Draft Environmental Statement Related to Steam Generator Repair at Turkey Point Plant Units 3 and 4 (SAI 81-0926E). Copies of this document were sent to the Departments of Commerce, Environmental Regulation, Natural Resources, State, Veteran and Community Affairs, the Game and Fresh Water Fish Commission, and the Florida Public Service Commission.

Attached for your consideration are review comments from the Department of Environmental Regulation. During the preparation of your final environmental statement for this project, these comments should be considered and responded to accordingly.

Thank you for the opportunity to review this document.

Sincerely,

Walter O. Kolb  
Sr. Governmental Analyst

WK/mew  
Attachment

cc: Hamilton S. Oven

COO2  
5/1

8103 190700

An Affirmative Action/Equal Opportunity Employer

D

100

100

100

100



100

100

100

100

TWIN TOWERS OFFICE BUILDING  
2600 BLAIR STONE ROAD  
TALLAHASSEE, FLORIDA 32301




BOB GRAHAM  
GOVERNOR  
JACOB D. VARN  
SECRETARY

STATE OF FLORIDA

## DEPARTMENT OF ENVIRONMENTAL REGULATION

February 3, 1981

Mr. Ron Fahs, Director  
Intergovernmental Coordination  
State Planning and Development  
Clearinghouse  
Office of the Governor  
The Capitol  
Tallahassee, Florida 32301



Dear Mr. Fahs:

Re: Draft Environmental Statement, NUREG-0743,  
Steam Generator Repair at Turkey Point  
Units 3 and 4, SAI No.: 81-0926E

I have reviewed the DES for the steam generator repairs at FPL's Turkey Point nuclear units. The following comments are offered:

1. On page 4-12, section 4.1.2.6, there is a phrase or sentences missing between the last line of page 4-12, and page 4-13.
2. The estimates of alternate disposal methods in sections 4.1.2.3 and 5.5 ignores the quota on volume of low level wastes being imposed at Barnwell, South Carolina. The immediate intact shipment or immediate cut-up and shipment to Barnwell may not be allowed by Chem Nuclear Systems, Inc. Shipment to Beatty Nevada, or Hanford, Washington isn't practical. Costs of shipment by truck or rail to those places probably haven't been considered.
3. FPL's estimates of replacement power costs may be biased exceptionally high, if they considered only peaking units (combustion turbines) as the source of power and ignore the



Mr. Fahs  
Page Two  
February 3, 1981

purchase of coal fired capacity or coal based generation or  
FPL is arranging to do.

Sincerely,

*Hamilton S. Owen, Jr.*

Hamilton S. Owen, Jr., P.E.  
Adminstrator  
Power Plant Siting Section

HSOjr:my

cc: John Outland

