

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8103230617 DOC. DATE: 81/03/10 NOTARIZED: YES DOCKET #  
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light Co 05000250  
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light Co 05000251  
 AUTH. NAME: UHRIG, R.E. AUTHOR AFFILIATION: Florida Power & Light Co.  
 RECIP. NAME: EISENHUT, D.G. RECIPIENT AFFILIATION: Division of Licensing

SUBJECT: Application to amend App A of Licenses DPR-31 & DPR-41,  
 revising Tech Specs re facility fire protection mods  
 described in NRC 790321 safety evaluation. Pages from OL,  
 reflecting proposed changes, encl.

DISTRIBUTION CODE: A006S COPIES RECEIVED: LTR 40 ENCL 40 SIZE: 5+10  
 TITLE: Fire Protection Information (After Issuance of OP. Lic.)

## NOTES:

ACTION:	RECIPIENT		COPIES		RECIPIENT	COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME	LTR
	VARGA, S.	04	7	7			
INTERNAL:	CHEM ENG. BR-A	7	5	5	DIR, DIV OF LIC	1	1
	I&E	06	2	2	NRC PDR	02	1
	FIELD		1	0	OGC		1
	REG FILE	01	1	1	WAMBACH, T.	10	1
EXTERNAL:	ACRS	09	16	16	LPDR	03	1
	NSIC	05	1	1			






March 10, 1981  
L-81-111

Office of Nuclear Reactor Regulation  
Attention: Mr. Darrell G. Eisenhut, Director  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dear Mr. Eisenhut:

Re: Turkey Point Units 3 & 4  
Docket Nos. 50-250 & 50-251  
Proposed License Amendments  
Fire Protection Systems



In accordance with 10 CFR 50.30, Florida Power & Light Company submits herewith three signed originals and forty copies of a request to amend Appendix A of Facility Operating Licenses DPR-31 and DPR-41.

This proposal is submitted to revise Technical Specifications related to facility fire protection modifications described in the Safety Evaluation to the Commission's letter of March 21, 1979, which issued Amendment No. 45 to Facility Operating Licenses No. DPR-31 and Amendment No. 37 to Facility Operating License No. DPR-41. Additionally, this proposal incorporates specific requirements of 10 CFR 50.48 and 10 CFR 50, Appendix R.

The proposed amendment is described below and shown on the accompanying Technical Specification pages bearing the date of this letter in the lower right hand corner.

DPR-31, Page 4

Paragraphs 1 and 2 of License Condition III.G have been deleted. The requirements are now included via 10 CFR 50.48 and 10 CFR 50, Appendix R.

DPR-41, Page 5

Paragraphs 1 & 2 of License Condition III.F have been deleted. The requirements are now included via 10 CFR 50.48 and 10 CFR 50, Appendix R.

Pages 3.14-1 through 3.14-4

Specification 3.14 is revised throughout to incorporate Limiting Conditions of Operation and/or associated Action statements which reflect existing commitments and modifications not previously covered by Technical Specifications. Where applicable, the wording is changed to be consistent with Standard Technical Specifications for Westinghouse Pressurized Water Reactors, NUREG-0452.

APR 6  
5  
40/40

P  
8108230617

PEOPLE...SERVING PEOPLE



Office of Nuclear Reactor Regulation  
Attention: Mr. Darrell G. Eisenhut, Director  
Division of Licensing

Page 4.15-1 through 4.15-3

Specifications 4.15 is revised throughout to incorporate surveillance requirements which reflect existing commitments and modifications not previously covered by Technical Specifications. Where applicable, the wording is changed to conform to NUREG-0452.

Page 6-5

Specification 6.2.2.f is revised to reflect the 10 CFR 50, Appendix R requirement for a five (5) member Fire Brigade. Wording is changed to conform to NUREG-0452.

Page 6-6

Specification 6.4.2 is changed to conform to NUREG-0452.

Page B3.14-1


The Basis is changed to reflect changes to Specification 3.14. Where applicable, the wording is changed to conform to NUREG-0452.

It is also requested that the effective date for the fire door portion of specification 3.14.5.a be after May 4, 1981. This is the approved modification completion date.

In accordance with your letter of March 21, 1979 this Amendment request is exempt from an Amendment fee.

The proposed amendment has been reviewed and approved by the Turkey Point Plant Nuclear Safety Committee and the Florida Power & Light Company Nuclear Review Board.

Very truly yours,



Robert E. Uhrig  
Vice President  
Advanced Systems and Technology

REU/WAK/ras

Attachment

cc: Mr. James P. O'Reilly, Region II  
Harold F. Reis, Esquire




STATE OF FLORIDA    )  
                          )    SS  
COUNTY OF DADE     )

Robert E. Uhrig, being first duly sworn, deposes and says:


That he is a Vice President of Florida Power & Light Company,  
the Applicant herein:

That he has executed the foregoing document; that the statements  
made in this said document are true and correct to the best of  
his knowledge, information and belief, and that he is authorized  
to execute the document on behalf of said Applicant.

  
Robert E. Uhrig


Subscribed and sworn to before me

this 10 day of March, 19 81

  
NOTARY PUBLIC, in and for the County of Dade,  
State of Florida

My commission expires: \_\_\_\_\_

Notary Public, State of Florida at Large  
My Commission Expires October 30, 1983  
Bonded thru Maynard Bonding Agency



RECEIVED  
JAN 15 1964  
U.S. AIR FORCE  
HEADQUARTERS  
WASHINGTON, D.C.



justify continued operation of Unit No 3 beyond the authorized period of operation. Any analysis justifying continued operation must be submitted at least 45 days prior to the expiration date of the authorized period of operation. For the purpose of this requirement equivalent operation is defined as operation with a primary coolant temperature greater than 350°F. NRC approval shall be obtained before resuming power operation following this inspection.

- F. The licensee shall maintain in effect and fully implement all provisions of the Commission-approved physical security plan, including amendments and changes made pursuant to the authority of 10 CFR 50.54 (p). The approved security plan documents, withheld from public disclosure pursuant to 10 CFR 2.790(d) collectively titled: "Turkey Point Plant, Unit Nos. 3 and 4 physical Security Plan", dated October 18 1979, as supplemented February 20 1979.

G.

The licensee is required to develop and implement the administrative controls which are consistent with the licensee's letters of August 28 and November 7, 1978 within three months from the date of this amendment.

- IV. FPL shall proceed with implementation of the recommendations set forth in paragraphs 7b and c of the "Summary and Conclusions" section of the "Final Environmental Statement Related to Operation of Turkey Point, Florida Power and Light Company" Docket Nos. 50-250 and 50-251 " issued July 1972 by the AEC Directorate of Licensing. No later than thirty (30) days from the date of issuance of this license FPL shall submit to the AEC, for review and approval, its plan for the implementation of such recommendations.
- V. This license is effective as of the date of issuance and shall expire at midnight April 27 2007.

[illegible]

10-10-68

•

F.

The licensee is required to develop and implement the administrative controls which are consistent with the licensee's letters of August 28 and November 7, 1978 within three months from the date of this amendment.

4. This license is effective as of the date of issuance, and shall expire at midnight April 27, 2007.



-----

-----