

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 F L T P S 4 2 0 0 1 0 0 0 0 0 0 3 4 1 1 1 1 4 3

LICENSEE CODE 14 15 LICENSE NUMBER 23 25 LICENSE TYPE 30 37 CAT 38

CCNT 01

REPORT SOURCE L R 0 5 0 0 0 2 5 1 7 0 2 1 4 8 1 3 0 1 3 1 3 8 1 9

DOCKET NUMBER 63 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

012 During normal full power operation, boric acid flow in the normal flow-

013 path from the Boric Acid Tanks (BATs) could not be established. Flow

014 from the BATs via the Emergency Boration flowpath was immediately verified,

015 but this event is considered reportable under Tech Spec 6.9.b.2. Flow was

016 restored in 5 hours. On 2/17/81 a low temperature reading was found in

017 the flowpath from the BATs. This was corrected in 14 hours. Similar LERs

018 were 251-74-1, 74-8, 75-2, 77-12, 78-1, and 250-81-2.

09 R B 11 E 12 A 13 E L E C O N 14 Z 15 Z 16

SYSTEM CODE 9 10 CAUSE CODE 11 CAUSE SUBCODE 12 COMPONENT CODE 13 COMP. SUBCODE 19 VALVE SUBCODE 20

17 LER/RO REPORT NUMBER 8 1 0 0 2 0 3 L 0

EVENT YEAR 21 22 SEQUENTIAL REPORT NO. 24 25 OCCURRENCE CODE 28 29 REPORT TYPE 30 31 REVISION NO. 32

ACTION TAKEN B 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 ATTACHMENT SUBMITTED N 23 NPROG FORM SUB. N 24 PRIME COMP. SUPPLIER A 25 COMPONENT MANUFACTURER C 3 3 2 25

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

110 Flow was initially restored by applying external heat to the blender, but

111 when the blockage and the low temperature were investigated, three splices

112 on heat tracing circuits were found to need repair. These items were

113 repaired and to minimize future problems, one section of circuit with

114 numerous splices was replaced.

15 E 23 1 0 0 0 29 NA A 31 Operator Observation

FACILITY STATUS 7 8 9 10 11 12 OTHER STATUS 30 METHOD OF DISCOVERY 45 46 DISCOVERY DESCRIPTION 52

ACTIVITY CONTENT 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29

RELEASED OF RELEASE 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

PERSONNEL EXPOSURES NUMBER 51 TYPE 52 DESCRIPTION 53

17 0 0 0 37 Z 38 NA

PERSONNEL INJURIES NUMBER 41 DESCRIPTION 42

113 0 0 0 40 NA

LOSS OF OR DAMAGE TO FACILITY TYPE 43 DESCRIPTION 44

19 Z 42 NA

PUBLICITY ISSUED DESCRIPTION 45

20 N 44 NA

NAME OF PREPARER P. L. Pace PHONE: (305) 552-3801

8104130324

