

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8105220243 DOC. DATE: 81/05/14 NOTARIZED: YES DOCKET # 05000250
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000251
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C
 AUTH. NAME AUTHOR AFFILIATION
 UHRIG, R.E. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 EISENHUT, D.G. Division of Licensing

SUBJECT: Application for amend to Licenses DPR-31 & DPR-41 App A
 to change Tech Specs 3.13 & 4.14 re shock suppressors
 snubbers.)

DISTRIBUTION CODE: A0015 COPIES RECEIVED: LTR 3 ENCL 3 SIZE: 3+13
 TITLE: General Distribution for after Issuance of Operating License


NOTES:

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
ACTION:	VARGA, S.	04	13 13				
INTERNAL:	D/DIR, HUM FAC	08	1 1		DIR, DIV OF LIC		1 1
	I&E	06	2 2		VRC PDR	02	1 1
	OELD	11	1 0		OR-ASSESS BR	10	1 0
	RAD ASMT BR		1 1		REG FILE	01	1 1
EXTERNAL:	ACRS	09	16 16		LPDR	03	1 1
	NSIC	05	1 1				

MAY 26 1981

TOTAL NUMBER OF COPIES REQUIRED: LTTR 40 ENCL 38

25




FLORIDA POWER & LIGHT COMPANY

May 14, 1981

L-81-206

Office of Nuclear Reactor Regulation
Attention: Mr. Darrell G. Eisenhut, Director
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555



Dear Mr. Eisenhut:

Re: Turkey Point Units 3 & 4
Docket Nos. 50-250 and 251
Proposed Amendment to
Facility Operating License DPR-31 and DPR 41

In accordance with 10 CFR 50.30, Florida Power & Light Company submits herewith three (3) signed originals and forty (40) copies of a request to amend Appendix A of Facility Operating Licenses DPR-31 and DPR-41.

This proposal is submitted in response to your letter of November 20, 1980.

The proposed Amendment is described below and shown on the accompanying pages bearing the date of this letter in the lower right hand corner.

Page 3.13-1

The Specification is changed to comply with the Standard Technical Specification wording.

Tables 3.13-1a and 3.13-1b

A new Table is added to separate hydraulic snubbers from mechanical snubbers.

Pages 4.14-1, 4.14-2 and 4.14-3

Additional surveillance requirements have been added as required by the Standard Technical Specifications.

Approved
5/3/81

8105220 243

P

Mr. Darrel G. Eisenhut, Director
Page 2

Pages B 3.13-1 & B 3.13-2

Bases are rewritten to support the addition of the new requirements.

The proposed amendment has been reviewed by the Turkey Point Nuclear Safety Committee and the Florida Power & Light Company Nuclear Review Board.

Very truly yours,

A handwritten signature in cursive script, reading "Robert E. Uhrig". The signature is written in dark ink and is positioned above the typed name and title.

Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU/JEM/mbd

Attachment


cc: Mr. James P. O'Reilly, Region II
Harold F. Reis, Esquire

STATE OF FLORIDA)
)
COUNTY OF DADE) ss.

Robert E. Uhrig, being first duly sworn, deposes and says:


That he is a Vice President of Florida Power & Light Company,
the Licensee herein;

That he has executed the foregoing document; that the state-
ments made in this said document are true and correct to the
best of his knowledge, information, and belief, and that he
is authorized to execute the document on behalf of said
Licensee.


Robert E. Uhrig

Subscribed and sworn to before me this

14th day of May, 1981



NOTARY PUBLIC, in and for the county of Dade,
State of Florida

My commission expires:

NOTARY PUBLIC STATE OF FLA. IN LARGE
MY COMMISSION EXPIRES AUGUST 24, 1981
BONDED THRU MAYNARD BONDING AGENCY