


USNRC REGION II  
ATLANTA, GEORGIA

81 JUL 23 A 9: 34



July 17, 1981  
L-81-300

Mr. James P. O'Reilly, Director, Region II  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

Re: Turkey Point Units 3 & 4  
Docket No. 50-250, 50-251  
IE Inspection Report 81-13

Florida Power & Light Company has reviewed the subject inspection report and a response is attached.

There is no proprietary information in the report.

Very truly yours,

Robert E. Uhrig  
Vice President  
Advanced Systems & Technology

REU/PLP/ras

cc: Harold F. Reis, Esquire

8109010474 810814  
PDR ADDCK 05000250  
Q PDR

1. The first part of the document discusses the importance of maintaining accurate records of all transactions and activities. It emphasizes the need for transparency and accountability in all financial dealings.

2. The second part of the document outlines the various methods and techniques used to collect and analyze data. It includes a detailed description of the sampling process and the statistical methods employed to interpret the results.

3. The third part of the document presents the findings of the study. It includes a series of tables and graphs that illustrate the trends and patterns observed in the data. The results are discussed in the context of the research objectives and the existing literature.

4. The fourth part of the document provides a conclusion and a summary of the key findings. It also includes a list of recommendations for future research and a discussion of the limitations of the study.

5. The fifth part of the document contains a list of references and a list of appendices. The references include a list of books, articles, and other sources used in the study. The appendices include a list of tables and figures that are not included in the main text.

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250, 50-251  
IE Inspection Report 81-13

FINDING:

Technical Specification 6.8.1 requires implementation of written procedures and administrative policies that meet or exceed the requirement and recommendations of section 5.1 of ANSI 18.7-1972 and USNRC Regulatory Guide 1.33. Administrative Procedure 0103.11, Housekeeping, requires that following maintenance under their cognizance, a supervisor or foreman will verify that the work site is clean and that all trash and debris has been removed from the area.

Contrary to the above during facility tours of units 3 and 4 this inspection period, it was noted that maintenance supervisors failed to implement existing procedures to verify post maintenance cleanliness in that:

1. Debris consisting of several pieces of a replaced waste Gas Compressor were left on the floor of the Auxiliary Building hallway at the four foot elevation for several months after completion of the replacement compressor installation (December 1980 - April 1981), and
2. The defective valve 4-895L and an attached length of contaminated tygon tubing were left on the floor of the Unit 4 spray pump room for several months after the replacement of the valve (May 1980 - April 1981).

RESPONSE:

- (1-1) FPL concurs with the finding.
- (1-2) The reasons for this finding is that the procedure was not fully complied with.
- (1-3) As corrective action, the areas were cleaned.
- (1-4) As corrective action taken to avoid further problems, mechanical maintenance supervisors and foreman were reinstructed in the requirements of Administrative Procedure 0103.11, Housekeeping.
- (1-5) Full compliance was achieved on July 15, 1981.

1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that proper record-keeping is essential for the integrity of the financial system and for the ability to detect and prevent fraud. The text also mentions the need for regular audits and the importance of having a clear chain of custody for all documents.

2. The second part of the document describes the various methods used to collect and analyze data. It includes a detailed discussion of the different types of data that can be collected, such as financial data, operational data, and customer data. It also explains how this data is analyzed to identify trends, patterns, and potential areas of concern. The text highlights the importance of using reliable data sources and the need for careful interpretation of the results.


3. The third part of the document outlines the various steps involved in the decision-making process. It discusses the importance of gathering all relevant information and the need to consider all possible options. The text also explains how to evaluate the risks and benefits of each option and how to make a final decision based on the available information. It emphasizes the importance of documenting the decision-making process and the need to review the results of the decision.

STATE OF FLORIDA     )  
                              )  
COUNTY OF DADE     )     ss.

Robert E. Uhrig, being first duly sworn, deposes and says:


That he is a Vice President of Florida Power & Light Company,  
the Licensee herein;

That he has executed the foregoing document; that the state-  
ments made in this said document are true and correct to the  
best of his knowledge, information, and belief, and that he  
is authorized to execute the document on behalf of said  
Licensee.

  
Robert E. Uhrig

Subscribed and sworn to before me this

17 day of July, 1981

  
NOTARY PUBLIC, in and for the county of Dade,  
State of Florida

My commission expires:

Notary Public, State of Florida at Largo  
My Commission Expires October 30, 1983  
~~Bonded thru Maynard Bonding Agency~~

RECEIVED  
JAN 10 1964  
U.S. AIR FORCE  
HEADQUARTERS  
WASHINGTON, D.C.