REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8111130484 DOC. DATE: 81/11/06 NOTARIZED: NO DOCKET #:
FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light Cl 05000250
50-251 Turkey Point Plant, Unit 4, Florida Power and Light Cl 05000251
AUTH. NAME AUTHOR AFFILIATION
UHRIG, R. E. Florida Power & Light Co.
RECIP. NAME RECIPIENT AFFILIATION
VARGA, S. A. Operating Reactors Branch 1

SUBJECT: Responds to NRC 810917 request for info re Tech Specs 3.14.3.a, 1.15.3.a, 4 & Table 3.14-2. Tech Specs will include table indicating hose stations protecting safety-related areas. Proposed changes provided by 811231.

DISTRIBUTION CODE: A006S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
TITLE: Fire Protection Information (After Issuance of OP. Lic.)

NOTES:

	RECIPIENT ID CODE/NAME		COPIES LTTR	COPIES ENCL	RECIPIENT ID CODE/NAME		COPIES LTTR	COPIES ENCL
ACTION:	OR8I #1 BC	01	7					
INTERNAL:	ELD		1	0	FIORAVANTE, N.	07	2	2
	I&E	06	2	2	NRR/DE/CEB	08	3	3
	NRR/DL DIR		1		OGC		1	1
	REG FILE	04	1		WAMBACH, T.	10	1	1
EXTERNAL:	ACRS	09	16	16	LPDR	03	1	1
	NRC PDR	02	1		NSIC	05	1	1
	NTIS		1					

NOV 17 1981

TOTAL NUMBER OF COPIES REQUIRED: LTTR 39 ENCL ~~38~~ 0

FLORIDA POWER & LIGHT COMPANY

November 6, 1981
L-81-472

Office of Nuclear Reactor Regulation
Attention: Mr. Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Varga:

Re: Turkey Point Units 3 & 4
Docket Nos. 50-250 and 50-251
Proposed Fire Protection
Amendment Modification

Florida Power & Light has reviewed your letter dated September 17, 1981 concerning the following areas of our proposed Technical Specifications for fire protection. The following is our response to those items:

Item 1 (T.S. 3.14.3.a)

As requested we will propose a change to our Technical Specifications so that fire hose stations in the vicinity of safety related equipment shall be operable at all times when the safety related equipment in their area of protection is required to be operable; or within one hour the inoperable hose station shall be made operable or an equivalent capacity fire hose shall be run from an equivalent water source to the inoperable location.

Item 2. (T.S. Table 3.14-2)

As requested, we will propose a change to our Technical Specifications to include in our Technical Specifications a table indicating the appropriate hose stations protecting safety related areas.

Item 3. (T.S. 4.15.3.a.4

As requested, we will propose a change to our Technical Specifications which would require testing our fire hoses at 150 psi or 50 psi above system pressure (whichever is greater).

A006
S/0

We will provide our proposed Technical Specifications pages to address these items by December 31, 1981.

Very truly yours,

Jack E. Vessely for

Robert E. Uhrig
Vice President
Advanced Systems and Technology

REU/JEM/cab

cc: J.P. O'Reilly, Region II
Harold F. Reis, Esquire