

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION: NBR: 8112010176 DOC. DATE: 81/11/24 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light Co. 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light Co. 05000251
 AUTH. NAME: AUTHOR AFFILIATION
 UHRIG, R. E. Florida Power & Light Co.
 RECIP. NAME: RECIPIENT AFFILIATION
 EISENHUT, D. G. Division of Licensing

SUBJECT: Discusses emergency response staff augmentation times.
 Commits to ensure that personnel can be augmented to levels
 specified in Table B-1 of NUREG-0654, Revision 1. Notification
 will be prioritized by emergency coordinator.


DISTRIBUTION CODE: A0455 COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1/1/1/1/1
 TITLE: Emergency Plan Information/NURG 0696 Comments

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL		RECIPIENT ID CODE/NAME	COPIES LTR ENCL
ACTION:	ORR #1 BCI	1		GROTENHUIS, M 01	1
INTERNAL:	IEI 10	2		IE/DEP DIR	1
	IE/DEP/EPDB 12	1		IE/DEP/EPLB 06	4
	NRR/DI/ORAB	1		NRR/DSI/RAB	1
	REG. FILES 04	1			
EXTERNAL:	INPO, J. STARNES	1		LPDR 03	1
	NSIC 05	1		NTIS	1
	PDR 02	1			

DEC 03 1981

TOTAL NUMBER OF COPIES REQUIRED: LTR 18 ENCL 0



November 24, 1981
L-81-497

Office of Nuclear Reactor Regulation
Attention: Mr. Darrell G. Eisenhut, Director
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Eisenhut:

Re: Turkey Point Units 3 & 4
Docket Nos. 50-250 & 50-251,
Emergency Response
Staff Augmentation Times



The Florida Power and Light Company maintains, at all times, the capability to provide timely augmentation of plant staff for response to radiological emergencies. We believe that this capability is adequate to protect the public health and safety and that it meets the intent of 10 CFR 50.47(b)(2).

The Florida Power and Light Company has committed to ensuring that the plant staff can be augmented to the levels specified in Table B-1 of NUREG-0654, Revision 1, within 45 to 75 minutes of notification. In addition, notification will be prioritized by the Emergency Coordinator so that response personnel needed soonest are notified first.

The time required for an individual to respond from home to the plant is composed of several components: (1) preparations to leave home; (2) driving time; (3) entrance into the plant. Driving time alone averages 25 to 45 minutes from the residential communities inhabited by most plant personnel. This will vary with traffic and road conditions. A reasonable estimate for items (1) and (3) is 20 to 30 minutes. This includes dressing, parking, clearing security, and reporting to the individual's duty station. Thus, the response time is 45-75 minutes and is governed primarily by the driving time which is determined by the existing housing pattern around the plant. Shorter response times are neither reasonable nor achievable in our case.

Very truly yours,

Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU/HDJ/cab

cc: Mr. James P. O'Reilly, Region II
Mr. Harold F. Reis, Esquire
Mr. B. Grimes, Director, Emergency Preparedness Division

A045
5/10

8112010176 811124
PDR ADOCK 05000250
F PDR

