

FLORIDA POWER AND LIGHT COMPANY  
TURKEY POINT UNITS 3 AND 4  
EMERGENCY PROCEDURE 20103  
APRIL 23, 1981

1.0 Title:

CLASSIFICATION OF EMERGENCIES

2.0 Approval and List of Effective Pages:

2.1 Approval:

Change dated 4/23/81 Reviewed by PNSC April 23, 1981

Approved by D. H. Haase Plant Mgr-Nuclear, MAY 12 1981

Approved by W. E. Schmidt Vice President  
Power Resources May 19 1981

2.2 List of Effective Pages:

<u>Page</u>	<u>Date</u>	<u>Page</u>	<u>Date</u>	<u>Page</u>	<u>Date</u>	<u>Page</u>	<u>Date</u>
1	4/23/81	4	4/23/81	7	3/26/81	10	3/26/81
2	3/26/81	5	3/26/81	8	3/26/81	11	3/26/81
3	3/26/81	6	3/26/81	9	3/26/81		

3.0 Scope:

3.1 Purpose:

This procedure provides instructions on the classification of emergencies at Turkey Point Plant.

3.2 Discussion:

Four levels of emergency classification are established. In order of increasing seriousness, these are:

Unusual Event  
Alert  
Site Area Emergency  
General Emergency

A graduation is provided to assure fuller response preparations for more serious conditions.

3/26/81

### 3.3 Authority:

This procedure implements the Turkey Point Plant Emergency Plans.

### 3.4 Definitions:

- 3.4.1 Unusual Event - The Usual Event category is restricted to non-emergency conditions. It applies to off-normal events or conditions at the Plant for which no significant degradation of the level of safety of the plant has occurred or is expected. Any release of radioactive material which have occurred or which may be expected are minor and constitute no appreciable health hazard.
- 3.4.2 Alert - This classification is represented by events which involve an actual or imminent substantial degradation of the level of safety of the plant combined with a potential for limited uncontrolled radioactivity from the plant.
- 3.4.3 Site Area Emergency - This classification is composed of events which involve actual or likely major failures of plant functions needed for protection of the public combined with a potential for significant uncontrolled releases of radioactivity from the plant.
- 3.4.4 General Emergency - This classification is composed of events which involve actual or imminent substantial core degradation and potential loss of containment integrity combined with a likelihood of significant uncontrolled releases of radioactivity from the plant.

### 4.0 Precautions:

#### 4.1 Conflicting Information:

When apparently conflicting information is available, the condition shall be classified at the most serious level indicated.

#### 4.2 Judgmental Decision:

If, in the judgment of the Nuclear Plant Supervisor (Emergency Coordinator), a situation is more serious than indicated by instrument readings or other parameters, the emergency condition shall be classified at the appropriate level.