

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8201250415 DOC DATE: 92/01/18 NOTARIZED: YES DOCKET #: 05000250  
 FACIL: 50-250 Turkey Point Plant, Unit 3, Floridal Power and Light CI 05000250  
 50-251 Turkey Point Plant, Unit 4, Floridal Power and Light CI 05000251  
 AUTH NAME: UHRIG, R. E. AUTHOR AFFILIATION: Floridal Power & Light Co.  
 RECIPIENT NAME: EISENHUT, D. G. RECIPIENT AFFILIATION: Division of Licensing

SUBJECT: Application for amend to Licenses DPR-31 & DPR-41 changing  
 Tech Specs re addl filter sys, allowable times for unit  
 operation w/emergency filtering sys inoperable & addl  
 testing requirements for filter sys.


DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 11 ENCL 11 SIZE: 3+9  
 TITLE: General Distribution for after Issuance of Operating License

## NOTES:

ACTION:	RECIPIENT		COPIES		RECIPIENT	COPIES	
	IDI CODE/NAME		LTR	ENCL		IDI CODE/NAME	LTR
INTERNAL:	ORB #1 BCI	01	13	13	IEI	06	2
	ELD		1	0			2
	NRR/DHFS DEPY08		1	1	NRR/DLI DIR		1
	NRR/DL/ORAB		1	0	NRR/DSI/RAB		1
	REGI FILEI	04	1	1			
EXTERNAL:	ACRS	09	10	10	LPDR	03	1
	NRCI POR	02	1	1	NSICI	05	1
	NTIS		1	1			

TOTAL NUMBER OF COPIES REQUIRED: LTR 35 ENCL 33





January 18, 1982  
L-82-17

Office of Nuclear Reactor Regulation  
Attention: Mr. Darrell G. Eisenhut, Director  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dear Mr. Eisenhut:

Re: Turkey Point Units 3 & 4  
Docket Nos. 50-250 & 50-251  
Proposed License Amendment  
Filter System Technical Specifications



In accordance with 10 CFR 50.90, Florida Power & Light Company submits herewith three signed originals and forty copies of a request to amend Appendix A of Facility Operating License DPR-31 and 41.

This amendment was initially submitted via L-77-174 dated June 9, 1977. This submittal contains revisions agreed to by your staff in conference calls on November 16 and 18, 1981.

The proposed amendment is described below and shown on the accompanying Technical Specification pages bearing the date of this letter in the lower right hand corner.

Page 3.0-1

The additional filter systems are included in the applicability section of the Limiting Conditions for Operations.

Page 3.4-4


The allowable times for unit operation with the Emergency Containment Filtering System inoperable have been modified.

Pages 3.4-5 & 3.4-6

The paragraph b. from Page 3.4-6 has been relocated to 3.4-5. Specifications for the Post-Accident Containment Vent System and Control Room Ventilation System have been added.

8201250415 820118  
PDR ADDCK 05000250  
PDR

Aool  
S/1



Pages 4.7-1, 4.7-2, 4.7-3 and 4.7-4

Additional testing requirements have been included in the testing specifications for filter systems.

Page B4.7-1

The bases have been revised to reflect the usage of ANSI N510 (1975) as a basis for that program.

The proposed amendment has been reviewed by the Turkey Point Plant Nuclear Safety Committee and the Florida Power & Light Company Nuclear Review Board.

Very truly yours,



Robert E. Uhrig  
Vice President  
Advanced Systems & Technology

REU/JEM/ras

cc: Mr. J. P. O'Reilly, Region II  
Harold F. Reis, Esquire



STATE OF FLORIDA )  
COUNTY OF DADE )

Robert E. Uhrig, being first duly sworn, deposes and says:  
That he is Vice President of Florida Power &  
Light Company, the herein;

That he has executed the foregoing document; that the statements made in this said document are true and correct to the best of his knowledge, information, and belief, and that he is authorized to execute the document on behalf of said

*Robert E. Uhrig*  
Robert E. Uhrig

Subscribed and sworn to before me this

18 day of January, 1982

Cheryl Z. Francis  
NOTARY PUBLIC, in and for the County of Dade,  
State of Florida

My commission expires: Notary Public, State of Florida at Large  
My Commission Expires October 30, 1983  
Bonded thru Maynard Bonding Agency.

