REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8206140168 DOC.DATE: 82/06/09 NOTARIZED: NO DOCKET #
FACIL:50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
AUTH.NAME AUTHOR AFFILIATION
UHRIG,R.E. Florida Power & Light Co.
RECIP.NAME RECIPIENT AFFILIATION
EISENHUT,D.G. Division of Licensing

SUBJECT: Submits revised schedules for implementation of NUREG-0737, Items II.B.2,II.B.3 & II.F.1,per Generic Ltr 82-05.

DISTRIBUTION CODE: A046S COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 2
TITLE: Response to NUREG -0737/NUREG-0660 TMI Action Plan Rgmts (OL's)

NOTES:

	RECIPIENT ID CODE/NAME		COPIES LTTR	COPIES ENCL	RECIPIENT ID CODE/NAME		COPIES LTTR	COPIES ENCL
	ORB #1 BC	01	7	7				
INTERNAL:	ELD/HDS4		1	0	IE/DEP DIR	33	1	1
	IE/DEP EPDS		1	1	IE/DEP/EPLB		3	3
	NRR/DE DIR	21	1	1	NRR/DE/ADCSE	22	1	1
	NRR/DE/ADMQE	23	1	1	NRR/DHFS DIR	28	1	1
	NRR/DHFS/DEPY	29	1	1	NRR/DL DIR	14	1	1
	NRR/DL/ADL	16	1	1	NRR/DL/ADOR	15	1	1
	NRR/DL/ADSA	17	1	1	NRR/DL/ORAB	18	3	3
	NRR/DSI DIR	24	1	1	NRR/DSI/ADDPS	25	1	1
	NRR/DSI/ADRP	26	1	1	NRR/DSI/ADRS	27	1	1
	NRR/DSI/AEB		1	1	NRR/DSI/ETSB		1	1
	NRR/DSI/RAB		1	1	NRR/DST DIR	30	1	1
	NRR/DST/ADGP	31	1	1	NRR/DST/ADT	32	1	1
	REG FILE	04	1	1	RGN2		1	1
EXTERNAL:	ACRS	34	10	10	FEMA-REP DIV		1	1
	INPO,J.STARNES		1	1	LPDR	03	1	1
	NRC PDR	02	1	1	NSIC	05	1	1
	NTIS		1	1				

TOTAL NUMBER OF COPIES REQUIRED: LTTR 53 ENCL 52

P.O. BOX 529100 MIAMI, FL 33152

FLORIDA POWER & LIGHT COMPANY

June 9, 1982
L-82-241

Office of Nuclear Reactor Regulation
Attention: Mr. Darrell G. Eisenhut, Director
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Eisenhut:

Re: Turkey Point Units 3 & 4
Docket Nos. 50-250 and 50-251
Post-TMI Requirements
Supplement to Response to
Generic Letter No. 82-05

This letter is to supplement letter L-82-175 dated April 27, 1982 which contained our response to Generic Letter No. 82-05. As was discussed briefly with your staff on June 4, 1982, several milestone dates that we provided you in our response have been rescheduled due to equipment delivery delays and/or problems caused by the almost constant rainfall that South Florida has received for over two weeks. The revised schedules for implementation are provided below:

1. PLANT SHIELDING (II.B.2)

The completion date for this item is now scheduled for July 2, 1982. It should be noted that the only equipment not yet installed consists of six valve reach rods and a coupling.

2. POST-ACCIDENT SAMPLING CAPABILITY (II.B.3)

The post-accident sampling system has been installed with the exception of six valve reach rods. These will be installed by July 2, 1982 which is the completion date we stated in letter L-82-175 that the system would be operable. It should be noted that although we consider the system essentially installed, piping is run but not currently connected to the reactor coolant sytem. This prevents the system from becoming contaminated and therefore eases startup testing. Also, current RCS sampling required by the technical specification is not interfered with.

A046

Re: Turkey Point Units 3 & 4
Docket Nos. 50-250 and 50-251
Post-TMI Requirements
Supplement to Response to
Generic Letter No. 82-05

3. CONTAINMENT HYDROGEN MONITORS (II.F.1.)

The containment hydrogen monitors have been installed with the exception of two valve extention stems which have not yet arrived on site. It is scheduled that the extention stems will arrive and be installed prior to July 2, 1982. The startup testing and calibration of the monitors is still scheduled for completion by July 2, 1982 and the schedule for the installation of the heat tracing remains August 16, 1982.

Very truly yours,

Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU/PKG/mbd

cc: Mr. James P. O'Reilly, Region II
Mr. Harold F. Reis, Esquire