REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8208130039 DOC.DATE: 82/08/06 NOTARIZED: NO DOCKET #
FACIL:50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
AUTH.NAME AUTHOR AFFILIATION
UHRIG,R.E. Florida Power & Light Co.
RECIP.NAME RECIPIENT AFFILIATION
EISENHUT,D.G. Division of Licensing

SUBJECT: Application for amend to Licenses DPR-31 & DPR-41,revising Tech Spec Tables 3.5-2 re emergency buses,3.5-4 re undervoltage relay setpoints & 4.1-1 re 4.16-kV & 480-volt load ctr test requirements.

DISTRIBUTION CODE: A015S COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 2+5
TITLE: Onsite Emergency Power Systems

NOTES:

	RECIPIENT ID CODE/NAME		COPIES LTTR	COPIES ENCL	RECIPIENT ID CODE/NAME		COPIES LTTR	COPIES ENCL
	ORB #1 BC	01	7	7				
INTERNAL:	AEOD		1	1	ELD/HDS4	17	1	1
	NRR/DL/ORAB	12	1	1	NRR/DSI/ICSB	09	1	1
	NRR/DSI/PSB	14	1	1	REG FILE	04	1	1
	RGN2		1	1	RM/DDAMI/MIB	18	1	1
EXTERNAL:	ACRS	16	10	10	INPO,J.STARNES		1	1
	LPDR	03	1	1	NRC PDR	02	1	1
	NSIC	05	1	1	NTIS		1	1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 30 ENCL 30

P. O. BOX 14000, JUNO BEACH, FL 33408

FLORIDA POWER & LIGHT COMPANY

August 6, 1982
L-82-334

Office of Reactor Regulation
Attention: Mr. Darrell G. Eisenhut, Director
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Eisenhut:

Re: Turkey Point Units 3 & 4
Docket Nos. 50-250 and 50-251
Adequacy of Station
Distribution System Voltages

In accordance with 10 CFR 50.90, Florida Power & Light Company submits herewith three signed originals and forty copies of a request to amend Appendix A of Facility Operating Licenses DPR 31 and 41.

This amendment is submitted as requested by the NRC Staff. The modifications that we described in our letter (L-82-193) dated May 10, 1982 are still to be completed as provided in that letter. This amendment request should not go into effect until the modifications are complete.

The proposed amendment is described below and shown on the accompanying Technical Specification pages.

Table 3.5-2

Minimum number of operable relays for the 4.16 kV Emergency Busses and the 480v load centers are specified.

Table 3.5-4 (Sheets 1 and 2)

New undervoltage relay setpoints are added on the 4.16 kV busses and the 480 volt load centers. The 480 volt setpoints may be revised lower upon completion of an auxiliary power upgrade effort to be completed in the same time frame.

Table 4.1-1

Channel check, calibration tests, and functional test requirements are added for the 4.16 kV and 480 volt load center undervoltage setpoints.

A015

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Adequacy of Station
Distribution System Voltages

The proposed amendment has been reviewed and approved by the Plant Nuclear Safety Committee and the Florida Power & Light Company Nuclear Review Board.

Very truly yours,

Robert E. Uhrig
Vice President
Advanced systems and Technology

REU/PLP/mbd

Attachment

cc: J.P. O'Reilly, Region II
Harold F. Reis, Esquire