

AJA SC

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8211160272 DOC. DATE: 82/11/05 NOTARIZED: YES DOCKET #
FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
AUTH. NAME AUTHOR AFFILIATION
UHRIG, R.E. Florida Power & Light Co.
RECIP. NAME RECIPIENT AFFILIATION
EISENHUT, D.G. Division of Licensing

SUBJECT: Application to amend Licenses DPR-31 & DPR-41, modifying Tech
Specs re flowrate of auxiliary feedwater sys from 600 gpm to
373 gpm for Model 44F steam generators.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 3 ENCL 40 SIZE: 2+11
TITLE: OR Submittal: General Distribution

NOTES: w/check \$4,400.

| | RECIPIENT ID CODE/NAME | | COPIES LTTR ENCL | | RECIPIENT ID CODE/NAME | | COPIES LTTR ENCL |
|-----------|---------------------------|----|---------------------|---|---------------------------|----|---------------------|
| | NRR ORB1 BC | 01 | 7 | 7 | | | |
| INTERNAL: | ELD/HDS4 | | 1 | 0 | NRR/DL DIR | | 1 1 |
| | NRR/DL/ORAB | | 1 | 0 | NRR/DSI/RAB | | 1 1 |
| | <u>REG FILE</u> | 04 | 1 | 1 | RGN2 | | 1 1 |
| EXTERNAL: | ACRS | 09 | 6 | 6 | LPDR | 03 | 1 1 |
| | NRC PDR | 02 | 1 | 1 | NSIC | 05 | 1 1 |
| | NTIS | | 1 | 1 | | | |

All Extras to NRR ORB1 BC


ADH

TOTAL NUMBER OF COPIES REQUIRED: LTR 23 ENCL 21

ALL INFORMATION CONTAINED HEREIN IS UNCLASSIFIED
DATE 08-19-2010 BY 60322 UCBAW/SJS

231 1.1

[illegible]



November 5, 1982
L-82-483

Office of Nuclear Reactor Regulation
Attention: Mr. Darrell G. Eisenhut, Director
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Eisenhut:

Re: Turkey Point Units 3 & 4
Docket No. 50-250 and 50-251
Proposed License Amendment
Auxiliary Feedwater Flow Requirements

In accordance with 10 CFR 50.90, Florida Power & Light Company submits herewith three signed originals and forty copies of a request to amend Appendix A of Facility Operating License DPR 31 and 41.

This amendment is submitted to modify the required flowrate of the auxiliary feedwater system. Analyses support the reduction of flow from 600 gpm to 373 gpm for the new model 44F steam generators.

The proposed amendment is described below and shown on the accompanying Technical Specification pages.

Page 4.10-1

The requirement for 600 gpm has been modified to 373 gpm.

Page B 3.801

The flowrate of auxiliary feedwater has been modified to 373 gpm.

The proposed amendment has been reviewed by the Turkey Point Plant Nuclear Safety Committee and the Florida Power & Light Company Nuclear Review Board.

Enclosed is a check in the amount of \$4,400.00 for a Class III and a Class I Amendment.

Very truly yours,

A handwritten signature in dark ink, appearing to read "Robert E. Uhrig", is written over the typed name.

Robert E. Uhrig
Vice President
Advanced Systems & Technology
REU/JEM/jk

Attachment

cc: Mr. James P. O'Reilly, Region II
Harold F. Reis, Esquire

Handwritten note:
Aool
w/ check
3/40 \$4,400

8211160272 821105
PDR ADOCK 05000250
P PDR



STATE OF FLORIDA)
)
COUNTY OF DADE) ss.

Robert E. Uhrig, being first duly sworn, deposes and says:


That he is Vice President of Florida Power & Light Company, the licensee herein;

That he has executed the foregoing document; that the statements made in this said document are true and correct to the best of his knowledge, information, and belief, and that he is authorized to execute the document on behalf of said


Robert E. Uhrig

Subscribed and sworn to before me this

5th day of November, 1982


NOTARY PUBLIC, in and for the County of Dade,
State of Florida

My commission expires: Notary Public, State of Florida at Large
My Commission Expires October 30, 1983
Bonded thru Maynard Bonding Agency

