

FLORIDA POWER AND LIGHT COMPANY
TURKEY POINT UNITS 3 AND 4
EMERGENCY PROCEDURE 20107
NOVEMBER 12, 1982

1.0 Title:

FIRE/EXPLOSION EMERGENCIES

2.0 Approval and List of Effective Pages:

2.1 Approval:

Change dated 11/12/82 Reviewed by PNSC November 12, 1982

Approved by J.R. Hayes Plant Mgr-Nuc November 24, 1982

Approved by J. Sullivan Vice President of Nuclear Energy DECEMBER 2 1982

2.2 List of Effective Pages:

<u>Page</u>	<u>Date</u>	<u>Page</u>	<u>Date</u>	<u>Page</u>	<u>Date</u>	<u>Page</u>	<u>Date</u>
1	11/12/82	3	8/19/82	5	8/19/82	7	1/21/82
2	8/19/81	4	11/12/82	6	8/19/82	8	1/21/82

3.0 Scope:

3.1 Purpose:

This procedure provides instructions to control and extinguish fires, to minimize equipment damage from fires or explosions and to prevent personnel injuries.

3.2 Discussion:

3.2.1 The Fire Team is composed of five individuals who are qualified in accordance with Administrative Procedure 15500, Fire Protection Program. The fire team members are personnel from the Operations, Health Physics, and Nuclear Chemistry Departments.

3.2.2 Those personnel initiating and conducting fire drills shall: Notify the Control Room by calling 260 on the PAX phone, announce "This is a drill. This is a drill", give location and classification of simulated fire/explosion, report any simulated injuries and the extent of damage to plant components.

3.2.3 The emergency classification system (see Emergency Procedure 20103, Classification of Emergencies) includes certain fires and explosions. Hence, each fire or explosion shall be evaluated by the Plant Supervisor - Nuclear/Emergency Coordinator to determine if it constitutes an unusual event, an alert, or a site area emergency.

