

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8607290222 DDC DATE: 86/07/18 NOTARIZED: YES DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH. NAME AUTHOR AFFILIATION
 WOODY, C. O. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 THOMPSON, H. L. Division of Pressurized Water Reactor Licensing - A (post 8)

SUBJECT: Application for amends to Licenses DPR-31 & DPR-41, revising
 Tech Specs to allow for reactor vessel level monitoring sys,
 per NUREG-0737 (Generic Ltr 83-37) requirements. Fee paid.

DISTRIBUTION CODE: A003D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+8
 TITLE: OR/Licensing Submittal: Suppl 1 to NUREG-0737 (Generic Ltr 82-33)

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PWR-A ADTS	1 1	PWR-A EB	1 1
PWR-A EICSB	2 2	PWR-A FOB	1 1
PWR-A PD2 LA	1 1	PWR-A PD2 PD	7 7
McDONALD, D	1 1	PWR-A PSB	1 1
PWR-A RSB	1 1		
INTERNAL: ADM/LFMB	1 0	IE/DEPER/EPB	3 3
NRR BWR ADTS	1 1	NRR PAULSON, W	1 1
NRR PWR-B ADTS	1 1	NRR/DSRO EMRIT	1 1
NRR/DSRO/EIB	1 1	NRR/DSRO/RSIB	1 1
<u>REG FILES</u>	1 1	RGN2	1 1
EXTERNAL: LPDR	1 1	NRC PDR	1 1
NSIC	1 1		


Rec'd w/check \$150.00

per PURS 0787 (Annex I to 83-37) requirements. Fee paid
 1000.00 to allow for reactor vessel level monitoring and
 application for amendments to Licenses DP-31 & DP-41, reviewed.

DATE: 08/12/2000 09:00:00 AM
 TO: DIRECTOR, FBI (100-442111)
 FROM: SAC, NEW YORK (100-100000) (P)
 SUBJECT: [REDACTED]
 RE: [REDACTED]
 100-100000-100000

2010

[illegible]



JUL 18 1988

L-86-296

Office of Nuclear Reactor Regulation
Attention: Mr. Hugh L. Thompson, Jr., Director
Division of PWR Licensing - A
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Thompson:

Re: Turkey Point Units 3 and 4
Dockets 50-250 and 50-251
Proposed License Amendment
Reactor Vessel Level Monitoring System
NRC TAC Nos. 45176 and 45177

In accordance with 10 CFR 50.90, Florida Power & Light Company submits herewith three signed originals and forty copies of a request to amend Appendix A of Facility Operating Licenses DPR 31 and 41 to incorporate plant specific technical specifications for the Reactor Vessel Level Monitoring System (RVLMS). The technical specifications for RVLMS are being submitted to comply with NUREG-0737 (Generic Letter No. 83-37) requirements.

The proposed changes are described below and shown on the accompanying Technical Specification pages.

Table 3.5-5

Number of channels and minimum channels operable and action statements for the RVLMS are added to the accident monitoring instrumentation table.

Table 4.1-1 Sheet 4

Surveillance frequencies for RVLMS are added.

T.S. 6.9.3

The special reports referenced in the above action statements are added to the list of special reports.

T.S. B3.5

A section to describe the basis for the RVLMS is added.

8607290222 860718
PDR ADDCK 05000250
P PDR

TCG2/001/1

Rec'd w/check 8/15/88

A003
11



4

2

3

4

5

6

7

8

9

Mr. Hugh L. Thompson, Jr., Director
L-86-296
Page two


It has been determined that the proposed amendment does not involve any significant hazards considerations pursuant to 10 CFR 50.92. A no significant hazards consideration determination is attached.

In accordance with 10 CFR 50.91(b)(1), a copy of this proposed license amendment is being forwarded to the State Designee for the State of Florida.

In accordance with 10 CFR 170.12(c), FPL Check No. 1804 for \$150 is attached.

The proposed amendment has been reviewed by the Turkey Point Plant Nuclear Safety Committee and the Florida Power and Light Company Nuclear Review Board.

Very truly yours,


C. O. Woody
Group Vice President
Nuclear Energy

COW/TCG/gp

cc: Dr. J. Nelson Grace, Region II, USNRC
Harold F. Reis, Esquire

Mr. Alan Schubert
Public Health Physicist
Department of Health and Rehabilitative Services
1323 Winewood Boulevard
Tallahassee, FL 32301

STATE OF FLORIDA)
)
COUNTY OF DADE) ss.

C. O. Woody being first duly sworn, deposes and says:

That he is a Group Vice President of Florida Power & Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information, and belief, and that he is authorized to execute the document on behalf of said Licensee.

C. O. Woody
C. O. Woody

Subscribed and sworn to before me this

18 day of July, 1986.

Bernice M. Salinas

NOTARY PUBLIC, in and for the County
of Dade, State of Florida

My Commission expires: _____
NOTARY PUBLIC STATE OF FLORIDA
MY COMMISSION EXP SEPT 18, 1989
BONDED THRU GENERAL INS. UND.

