

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8707170170 DOC. DATE: 87/06/25 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH. NAME: ROBERTS, E. W. AUTHOR AFFILIATION: EG&G Idaho, Inc. (subs. of EG&G, Inc.)
 ROBERTS, E. W. Idaho National Engineering Laboratory
 RECIP. NAME: CARRINGTON, M. RECIPIENT AFFILIATION: Office of Nuclear Reactor Regulation, Director (Post 870411)

SUBJECT: Forwards EGG-NTA-7664, "Conformance to Generic Ltr 83-28, Item 2.2.2 'Vendor Interface Programs for All Other Safety-Related Components: Turkey Point 3 & 4, 'informal rept. Licensee should describe interface w/NSSS vendor.

DISTRIBUTION CODE: H001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1716
 TITLE: File Location Distribution: NRR Docket 50

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
INTERNAL:	<u>REG FILE</u> 01	1 1		
EXTERNAL:	LPDR	1 1	NRC PDR	1 1

add: P. McDonald Ltr Eval
11

TOTAL NUMBER OF COPIES REQUIRED: LTTR

ENCL



Idaho National Engineering Laboratory

June 25, 1987

50 - 250/251

Mr. M. Carrington, Project Manager
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

TRANSMITTAL OF FINAL REPORT, "CONFORMANCE TO GENERIC LETTER 83-28,
ITEM 2.2.2--VENDOR INTERFACE PROGRAMS FOR ALL OTHER SAFETY-RELATED
COMPONENTS: TURKEY POINT-3 AND -4," EGG-NTA-7664, JUNE 1987 (FIN D6001) -
EWR-163-87

Ref: NRC Form 189, "Evaluation of Conformance to Generic Letter 83-28 For
ORs (Project 2)" (D6001)

Dear Mr. Carrington:

Transmitted herewith is the above subject report.

The report documents INEL's evaluation of the licensee actions in response
to NRC Generic Letter 83-28, Item 2.2.2--Vendor Interface Programs for All
Other Safety-Related Components. Based on the licensee submittal, we
conclude that the licensee should describe their interface with the NSSS
vendor and establish similar interfaces with vendors of key safety-related
equipment.

Very truly yours,

E. W. Roberts, Manager
NRC Headquarters Support

ACU:gp

Enclosure:
As Stated

cc: G. L. Jones, DOE-ID
D. Lasher, NRR-SICB (2)
J. O. Zane, EG&G Idaho, Inc. (w/o Encl.)

Hool Add: D. McDonald Ltr Encl 11

EG&G Idaho, Inc.

11428 Rockville Pike

Suite 410

Rockville, MD 20852

8707170170 870625
PDR ADDCK 05000250
PDR

