

Keith J. Polson
Senior Vice President and CNO

DTE Energy Company
6400 N. Dixie Highway, Newport, MI 48166
Tel: 734.586.6515 Fax: 734.586.4172
Email: keith.polson@dteenergy.com



December 8, 2017
NRC-17-0081

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555-0001

Fermi 2 Power Plant
NRC Docket No. 50-341
NRC License No. NPF-43

Subject: Supplement to Revised Relief Request No. RR-A37, Revision 1, for
the Inservice Inspection Program Third 10-Year Interval

References: 1) DTE Electric Letter to NRC, "Submittal of Revised Relief
Request No. RR-A37, Revision 1, for the Inservice Inspection
Program Third 10-Year Interval," NRC-17-0062, dated
September 26, 2017 (ML17270A036)

In Reference 1, DTE Electric Company (DTE) submitted relief request RR-A37, Revision 1, for the third 10-year interval of the Fermi 2 Inservice Inspection (ISI) Program. The subject revised relief request involves implementation of ASME Code Case N-702, "Alternative Requirements for Boiling Water Reactor (BWR) Nozzle Inner Radius and Nozzle-to-Shell Welds, Section XI, Division 1." Code Case N-702 stipulates that VT-1 examination may be used in lieu of the volumetric examination for the Reactor Pressure Vessel (RPV) nozzle inner radius section (ASME Code, Category B-D, Item B3.100).

As a supplement to relief request RR-A37, Revision 1, DTE will utilize ASME Code Case N-648-1, "Alternative Requirements for Inner Radius Examination of Class 1 Reactor Vessel Nozzles, Section XI, Division 1," with associated required Regulatory Guide 1.147 conditions if VT-1 examinations are performed in lieu of volumetric examinations.

No new commitments are being made in this submittal.

USNRC
NRC-17-0081
Page 2

Should you have any questions or require additional information, please contact Mr. Scott A. Maglio, Manager – Nuclear Licensing, at (734) 586-5076.

Sincerely,

A handwritten signature in black ink, appearing to read 'Keith J. Polson', written in a cursive style.

Keith J. Polson
Senior Vice President and CNO

cc: NRC Project Manager
NRC Resident Office
Reactor Projects Chief, Branch 5, Region III
Regional Administrator, Region III
Michigan Public Service Commission
Regulated Energy Division (kindschl@michigan.gov)