

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)


ACCESSION NBR: 8802170400 DOC. DATE: 88/02/12 NOTARIZED: YES DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH. NAME AUTHOR AFFILIATION
 WOODY, C. O. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 GRACE, J. N. Region 2, Ofc of the Director

SUBJECT: Forwards response to NRC Bulletin 87-002 re receipt insp requirements review & fastener testing to determine conformance w/applicable matl specs. All fasteners acceptable for continued use.

See RIDS
 DISTRIBUTION CODE: IE11D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 92
 TITLE: Bulletin Response (50 DKT)

NOTES:

| | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL | | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL |
|-----------|---------------------------|---------------------|--|---------------------------|---------------------|
| | PD2-2 LA | 1 0 | | PD2-2 PD | 1 1 |
| | EDISON, G | 1 1 | | | |
| INTERNAL: | AEOD/DOA | 1 1 | | AEOD/DSP | 1 1 |
| | AEOD/DSP/TPAB | 1 1 | | NRR/DEST/ADE | 1 1 |
| | NRR/DEST/ADS | 1 1 | | NRR/DEST/MEB | 1 1 |
| | NRR/DOEA/EAB | 1 1 | | NRR/DOEA/GCB | 1 1 |
| | NRR/DREP/EPB | 1 1 | | NRR/PMAS/ILRB | 1 1 |
| | <u>REG FILE</u> 02 | 1 1 | | RES/DE/EIB | 1 1 |
| | RG22 FILE 01 | 1 1 | | | |
| EXTERNAL: | LPDR | 1 1 | | NRC PDR | 1 1 |
| | NSIC | 1 1 | | | |



FEBRUARY 12 1988

L-88-69

Dr. J. Nelson Grace
Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta St., N.W., Suite 2900
Atlanta, GA 30323

Dear Dr. Grace:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
NRC Bulletin 87-02: Fastener Testing to Determine
Conformance with Applicable Material Specifications

NRC Bulletin 87-02 requested licensees to review their receipt inspection requirements and internal controls for fasteners and independently determine, through testing, whether fasteners (studs, bolts, cap screws and nuts) in stores at their facilities meet required mechanical and chemical specification requirements. By letter dated January 12, 1988 (L-88-14), FPL provided a schedule to complete the response by February 12, 1988.

A total of 22 fasteners were independently tested with only slight variations found between the manufacturer's test results and the independent test results. All the fasteners were found to be acceptable for continued use. The attached material contains the answer to the specific questions addressed in the bulletin, the results of the independent test and the Engineering evaluation of the discrepancies identified.

The attached information is provided pursuant to Section 128a of the Atomic Energy Act of 1954, as amended. If further information is required on this topic, please contact us.

Very truly yours,

DA Sager

for C. O. Woody
Executive Vice President

COW/SDF/dh

Attachment

cc: Document Control Desk, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

SDF/012.BUL

8802170400 880212
PDR ADCK 05000250
PDR

an FPL Group company

JEH
11

STATE OF FLORIDA)
)
COUNTY OF PALM BEACH) ss.

D. A. Sager being first duly sworn, deposes and says:

That he is Executive Assistant of Florida Power & Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information, and belief, and that he is authorized to execute the document on behalf of said Licensee.

DA Sager
D. A. Sager

Subscribed and sworn to before me this

12 day of February, 1988.

Bernice M. Salinas

NOTARY PUBLIC, in and for the County
of Palm Beach, State of Florida

My Commission expires:
NOTARY PUBLIC STATE OF FLORIDA
MY COMMISSION EXP. DATE 10.1989
BOUNDED THRU GENERAL INS. UND.

