

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8803310206 DOC. DATE: 88/03/25 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251

AUTH. NAME AUTHOR AFFILIATION
 CONWAY, W.F. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Docketing & Services Branch

SUBJECT: Comment supporting & opposing proposed rule 10CFR50, App J re
 primary reactor containment leakage testing.

DISTRIBUTION CODE: DS10D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1
 TITLE: SECY/DSB Dist: Public Comment on Proposed Rule (PR)-10CFR

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
INTERNAL: ARM/DRR/RPB	1 1	NMSS/IMOB	1 1
NRR/PMAS/IILRB12	1 1	OGC H ST	1 1
OGC/DR 15-B-18	1 1	OGC/SAIP15-B-18	1 1
REG FILE 01	1 1	RES DIR	1 1
EXTERNAL: NRC PDR 02	1 1		

*Add: G Arnold
 NS-302*

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 9

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S



'88 MAR 28 P4:45

MARCH 25 1988

L-88-131

Secretary
U. S. Nuclear Regulatory Commission
Attn: Docketing and Service Branch
1717 H Street, N.W., Room 1121
Washington, D. C. 20555

Mr. Secretary:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Proposed Rule Change - 10 CFR 50 Appendix J

Florida Power & Light Company (FPL) provides the following comments concerning the proposed rule change to 10 CFR 50 Appendix J - Primary Reactor Containment Leakage Testing for Water-Cooled Power Reactors, published in the Federal Register, February 29, 1988.

- (1) FPL endorses the addition of the Mass Point methodology to acceptable leakage rate calculational methods already incorporated into Appendix J.
- (2) FPL disagrees with the coupling of the Mass Point methodology with a 24 hour test period.

Bases: Test period length should be based on the time necessary to gather enough data with a degree of accuracy to obtain a 95% confidence level that the measured leakage rate is accurate. This is a statistical requirement independent of methodology. Coupling this methodology with a minimum 24 hour test period will severely limit its use.

FPL appreciates this opportunity to comment on this rule change.

Very truly yours,

W. F. Conway

W. F. Conway
Acting Group Vice President
Nuclear Energy

WFC/RG/gp

cc: Dr. J. Nelson Grace, Regional Administrator,
Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

RG.PRC

8803310206 880325
PDR PR
50 53FR5985 DCD

acknowledged by card. MAR 29 1988

an FPL Group company

DS 10 %
Add: G. Hendt 115-302



Handwritten marks and scribbles in the top right corner.